

TABLE 24: ASBESTOS ASSESSMENT AND QUANTITIES					
ASBESTOS-CONTAINING MATERIALS					
MATERIAL (CLASSIFICATION)	LOCATION OF MATERIAL	CURRENT CONDITION	POTENTIAL FOR DISTURBANCE	FRIABLE YES/NO	QUANTITY (NESHAP CATEGORY)
Pipe insulation	Bldg's 2,3,6,7,11,13,14,15,16,17,18,19,20, & 25	1	5	Yes	2500 LF
Valve insulation	Bldg. 17	1	5	Yes	50 SF
Pipe joint insulation	Bldg. 18	1	5	Yes	30 LF
Transite Panel	Bldg's 2,3,& 5	10	5	No	6 SF
Heat Shield (cloth)	Bldg.'s 2 & 3	10	5	Yes	11 SF
Heat Shield (hard)	Bldg.'s 6 & 11	8	5	No	7 SF
Stack block insulation	Bldg. 3	5	5	Yes	20 SF
Plaster	Bldg. 3	3	7	No	1000 SF
Debris	Bldg. 3	5	5	Yes	1 SF
Roof tar	Bldg. 3	9	5	No	100 SF
Gasket	Bldg.'s 5,11,12, & 17	8	5	No	120 SF
Fabric	Bldg. 5	2	5	No	2 SF
Duct wrap	Bldg. 6	7	5	Yes	20 SF
Coil wrap	Bldg. 6	2	5	Yes	25 SF

Notes for Table 24:

1. The numerical classification for current condition is from 1 to 10, with 1 being extremely poor condition and 10 being undamaged.
2. The numerical classification for potential for disturbance is from 1 to 10, with 1 being inaccessible and 10 having a high probability of disturbance.
3. "SF" denotes square feet, "LF" denotes linear feet.

**TABLE 24: ASBESTOS ASSESSMENT AND QUANTITIES
ASBESTOS-CONTAINING MATERIALS**

MATERIAL (CLASSIFICATION)	LOCATION OF MATERIAL	CURRENT CONDITION	POTENTIAL FOR DISTURBANCE	FRIABLE YES/NO	QUANTITY (NESHAP CATEGORY)
Small hose	Bldg. 11	10	5	Yes	10 LF
Tar paper	Bldg.'s 13 & 27, debris pile	8	5	Yes	3750 SF
Caulk material	Bldg. 14	5	5	No	500 SF
Paper on rolls	Bldg. 20	8	5	Yes	50 SF
Siding	Bldg. 27	7	3	No	3500 SF
White material on ground	Outside Bldg.'s 7&16, &Tracks	1	10	Yes	50 SF
Gray material on ground	Outside Bldg.'s 16,25, &15	1	10	Yes	65 SF
Pipe wrap	Locomotive	5	10	No	5 SF

Notes for Table 24:

1. The numerical classification for current condition is from 1 to 10, with 1 being extremely poor condition and 10 being undamaged.
2. The numerical classification for potential for disturbance is from 1 to 10, with 1 being inaccessible and 10 having a high probability of disturbance.
3. "SF" denotes square feet, "LF" denotes linear feet.