



ANALYTICAL ENVIRONMENTAL SERVICES, INC.

June 26, 2014

Jessica Vickers
Tetra Tech EM Inc.
950 S. Fourth St.
Baldwyn MS 38824

TEL: (622) 681-5727
FAX: (622) 681-5727

RE: Knoxville College

Dear Jessica Vickers:

Order No: 1406L98

Analytical Environmental Services, Inc. received 4 samples on June 25, 2014 10:35 am for the analyses presented in following report.

Please find enclosed the results of the air sample analyses for the above referenced project. All analyses are performed in accordance with the standard procedures regulated by OSHA (RE: CRF 1910.1001) and NIOSH 7400 Method (as amended 5/15/95.).

AIHA-LAP, LLC Laboratory ID: 100671 for Industrial Hygiene (Organics, Inorganics, PCM Asbestos) effective until 09/01/15.

Sr values are: 0.17 for 5 to 20 fibers in 100 fields; 0.12 for 20.5 to 50 fibers in 100 fields; 0.11 for 50.5 to 100 fibers in 100 fields.

Please note that any unused portion of these samples will be disposed of in 90 days unless otherwise requested.

These results relate only to the items tested. This report may only be reproduced in full.

James Forrest
Project Manager

Airborne Fiber Concentration Report of Analysis

Analytical Environmental Services, Inc

Date: 26-Jun-14

Client: Tetra Tech EM Inc.	Date Sampled: 6/24/2014
Lab Order: 1406L98	Date Received: 6/25/2014
	Date Analyzed: 6/26/2014
Sample Type: Air	Project: Knoxville College
Method Reference: PCM	Analyst: JW

Lab ID	Sample Identification	Air Volume (liters)	LOD (fibers/cc)	Fiber Concentration		
				(fibers/mm2)	(fibers/filter)	(fibers/cc)
1406L98-001A	KC-AA-062414-P1	1009.35	0.003	<7.01	<2700	<0.003
1406L98-002A	KC-AA-062414-B1	1005.26	0.003	<7.01	<2700	<0.003
1406L98-003A	KC-AA-062414-B2	971.031	0.003	<7.01	<2700	<0.003
1406L98-004A	KC-AA-062414-FB		2.7			<2.7

Results are blank corrected where applicable.

These results apply only to those samples actually tested, as submitted by the client.