

Table 1: Asbestos Sample Collection Information and Preliminary Analytical Results  
Old Saratoga Hospital Site  
Providence Township, Saratoga County, New York  
August 4 and September 17, 2015

RST 3 Sample ID	Sample Date	Sample Time	Sample Result	Type	Location	Floor	Analytical Method	Comments
P001-BA-001-01	8/4/2015	11:07	44.40% Chrysotile	Pipe insulation	West Wing	Basement	PLM NYS 198.1 Friable	Pipe insulation along ceiling.
P001-BA-002-01	8/4/2015	11:14	57.10% Chrysotile	Pipe insulation	West Wing	Basement	PLM NYS 198.1 Friable	Pipe insulation along ceiling.
P001-BA-003-01	8/4/2015	11:25	33.30% Chrysotile	Pipe insulation	West Wing	Basement	PLM NYS 198.1 Friable	Storage bags labeled "Asbestos".
P001-BA-004-01	8/4/2015	11:31	ND	Debris Pile	West Wing	Basement	PLM NYS 198.1 Friable	Debris adjacent to floor tile.
P001-BA-005-01	8/4/2015	11:37	15.80% Amosite; 5.26% Chrysotile; 21.06% Total	Insulation	West Wing	Basement	PLM NYS 198.1 Friable	Insulation covering a large suspect boiler tank. Tank is approximately four feet in diameter.
P001-BA-006-01	8/4/2015	11:42	26.70% Chrysotile	Pipe Insulation	West Wing	Basement	PLM NYS 198.1 Friable	Pipe insulation along ceiling.
P001-BA-007-01	8/4/2015	11:47	ND	Drywall	West Wing	Basement	PLM NYS 198.1 Friable	Sample collected from debris pile on the floor. Sample split by lab into skim coat and base coat; both were non-detect.
P001-BA-008-01	8/4/2015	13:24	4.82% Chrysotile	Debris Pile	West Wing	Basement	PLM NYS 198.1 Friable	Sample from debris pile.
P001-BA-009-01	8/4/2015	13:32	ND	Debris Pile	West Wing	Basement	PLM NYS 198.6 NOB and TEM NYS 198.4 NOB	Sample collected from debris pile on the floor.
P001-BA-010-01	8/4/2015	13:48	21.10% Chrysotile	Pipe Insulation	West Wing	Basement	PLM NYS 198.1 Friable	Pipe insulation along ceiling.
P001-BA-011-01	8/4/2015	14:10	ND	Floor Tile	East Wing	Basement	PLM NYS 198.6 NOB and TEM NYS 198.4 NOB	Sample collected from debris pile adjacent to floor tile.
P001-BA-012-01	8/4/2015	14:23	ND	Debris Pile	East Wing	Basement	PLM NYS 198.1 Friable	Sample collected from debris pile on the floor.
P001-BA-013-01	8/4/2015	14:32	19.10% Chrysotile	Insulation	East Wing	Basement	PLM NYS 198.1 Friable	Sample collected from insulation material that was present in bags labeled "Asbestos".
P001-BA-014-01	8/4/2015	14:41	5.4% Chrysotile	Debris Pile	East Wing	Basement	PLM NYS 198.6 NOB	Sample collected from debris pile on floor.
P001-BA-015-01	8/4/2015	16:48	ND	Ceiling Tile	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from ceiling tile that had fallen to the floor.
P001-BA-016-01	8/4/2015	16:53	ND	Ceiling Tile	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from degraded ceiling tile.
P001-BA-017-01	8/4/2015	17:01	ND	Ceiling Tile	West Wing	1st Floor	PLM NYS 198.1 Friable	Collected from ceiling tile that had fallen to the floor.
P001-BA-018-01	8/4/2015	17:12	ND	Drywall	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from degraded drywall material.
P001-BA-019-01	8/4/2015	17:23	ND	Pyrobar/Mortar	East Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from pyrobar mortar material on the wall.
P001-BA-020-01	8/4/2015	17:42	36.40% Chrysotile	Insulation	Outside	NA	PLM NYS 198.1 Friable	Sample collected from insulation on an abandoned boiler tank located outside in a pit approximately 150 feet northeast of the east wing of the building.
P001-BA-021-01	8/4/2015	17:53	36.40% Chrysotile	Debris Pile	Outside	NA	PLM NYS 198.1 Friable	Sample collected from debris pile outside the northwest entrance of the building, adjacent to sample location P001-BA-010.
P001-BA-022-01	9/17/2015	9:40	50.00% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from pipe wrap fallen onto cinder block of broken wall.
P001-BA-023-01	9/17/2015	9:45	40.00% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from pipe wrap on floor.
P001-BA-024-01	9/17/2015	9:50	57.10% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from pipe wrap fallen on floor below pipes.
P001-BA-025-01	9/17/2015	10:00	57.10% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from vertical pipe in room with broken windows.
P001-BA-026-01	9/17/2015	10:05	66.70% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from vertical pipe in room with missing window.
P001-BA-027-01	9/17/2015	10:10	44.40% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from remaining wrap at bottom of vertical pipe.
P001-BA-028-01	9/17/2015	10:15	57.10% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from floor next to broken/open window.
P001-BA-029-01	9/17/2015	10:20	30.80% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected next to open window from pipes partially embeded in wall, with pipe wrap protruding from the wall.
P001-BA-030-01	9/17/2015	10:25	50.00% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from vertical pipe.
P001-BA-031-01	9/17/2015	10:30	57.10% Chrysotile	Pipe Wrap	West Wing	1st Floor	PLM NYS 198.1 Friable	Sample collected from floor of room with abundant pipe wrap hanging from overhead pipes

**Notes:**  
ND: Non Detect; no asbestos found  
All samples from the basement are in blue text.  
All samples from the 1st floor are in red text.  
All samples from outside are in green text.  
PLM: Polarized Light Microscopy  
TEM: Transmission Electron Microscopy  
NYS: New York State  
NOB: Non-friable, Organically Bound  
NA: Not Applicable  
Results greater than one percent asbestos highlighted in pink.