



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8**

1595 Wynkoop Street  
Denver, CO 80202-1129  
Phone 800-227-8917  
[www.epa.gov/region08](http://www.epa.gov/region08)

Ref: Crow Agency Vandalism Site

The attached sample results represent emergency drinking water samples taken in the hours following a vandalism event at the Crow Agency Water Authority Treatment Plant in Crow Agency, MT. The samples were analyzed for standard suites of chemicals following specific drinking water protocols in place to ensure the system is free of contaminants prior to being put back into service.

All results in the following pages are non-detect or below levels of concern for drinking water.

Sample locations are indicated by the Client Sample ID or Sample ID:

- Clearwell TP02 Special is from inside the water treatment plant
- Crow School is from a tap at the school

Questions about these results should be directed to Barb Burkland at (406) 457-5009.



*Printed on Recycled Paper*



Trust our People. Trust our Data.  
www.energylab.com

Billings, MT 800.735.4489 • Casper, WY 888.235.0515  
Gillette, WY 866.686.7175 • Helena, MT 877.472.0711

## LABORATORY ANALYTICAL REPORT

Prepared by Billings, MT Branch

**Client:** US Bureau of Indian Affairs

**Project:** 083090011 TP02

**Client Sample ID:** Clearwell TP02 Special

**PWS ID:** 083090011

**Facility ID:** TP01

**Sample Point ID:** SP01

**Facility Name:** CROW AGENCY WATER SYSTEM

**Lab ID:** B17100295-001A

**Compliance Sample:** YES

**Sample Type:** SP

**Report Date:** 10/05/17

**Collection Date:** 10/04/17 14:20

**Received Date:** 10/04/17 16:40

**Matrix:** Drinking Water

**Sampled By:** Joshua Gust

Analyses	Result	Units	Safe/Unsafe	Qualifier	Method	Analysis Date / By
<b>MICROBIOLOGICAL</b>						
3100 Coliform, Total	Absent	per 100ml	SAFE		A9223 B	10/04/17 17:21 / Idv
3014 Coliform, E-Coli	Absent	per 100ml			A9223 B	10/04/17 17:21 / Idv

**Comments:** The notation "SAFE" indicates that the water was bacteriologically SAFE when sampled.

The notation "UNSAFE" indicates that the water was bacteriologically UNSAFE when sampled.

**Method Reference:** E - EPA / MCAWW Methodology A - Standard Methods 22nd Ed.



Trust our People. Trust our Data.  
www.energylab.com

Billings, MT 800.735.4489 • Casper, WY 888.235.0515  
Gillette, WY 866.686.7175 • Helena, MT 877.472.0711

## LABORATORY ANALYTICAL REPORT

Prepared by Billings, MT Branch

**Client:** US Bureau of Indian Affairs

**Project:** 083090011 TP02

**Client Sample ID:** Crow School

**PWS ID:** 083090011 **Facility ID:** DS001 **Sample Point ID:** DIST

**Facility Name:** CROW AGENCY WATER SYSTEM

**Lab ID:** B17100295-002A

**Compliance Sample:** YES **Sample Type:** SP

**Report Date:** 10/05/17

**Collection Date:** 10/04/17 15:06

**Received Date:** 10/04/17 16:40

**Matrix:** Drinking Water

**Sampled By:** Joshua Gust

Analyses	Result	Units	Safe/Unsafe	Qualifier	Method	Analysis Date / By
<b>MICROBIOLOGICAL</b>						
3100 Coliform, Total	Absent	per 100ml	SAFE		A9223 B	10/04/17 17:21 / Idv
3014 Coliform, E-Coli	Absent	per 100ml			A9223 B	10/04/17 17:21 / Idv

**Comments:** The notation "SAFE" indicates that the water was bacteriologically SAFE when sampled.

The notation "UNSAFE" indicates that the water was bacteriologically UNSAFE when sampled.

**Method Reference:** E - EPA / MCAWW Methodology A - Standard Methods 22nd Ed.