SECTION 07 31 13 - ASPHALT SHINGLES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Glass-fiber-reinforced asphalt shingles.
2. Underlayment materials.
3. Ridge vents.
4. Metal flashing and trim.

1.3 DEFINITIONS

A. Roofing Terminology: See ASTM D1079 for definitions of terms related to roofing Work in this Section.

1.4 ACTION SUBMITTALS

A. Product Data: For the following:

1. Asphalt shingles.
2. Underlayment materials.
3. Ridge vents.
4. Asphalt roofing cement.
5. Elastomeric flashing sealant.

B. Shop Drawings: For metal flashing and trim.

C. Samples for Initial Selection:

1. For each type of asphalt shingle indicated.
2. For each type of accessory involving color selection.

D. Samples for Verification: For the following products, in sizes indicated:

1. Asphalt Shingles: Full size.
2. Ridge and Hip Cap Shingles: Full size.
3. Ridge Vent: 12-inch-long Sample.
4. Exposed Valley Lining: 12 inches square.

1.5 INFORMATIONAL SUBMITTALS

A. Qualification Data: For Installer.

B. Product Test Reports: For each type of asphalt shingle and underlayment product indicated, for tests performed by manufacturer and witnessed by a qualified testing agency.

C. Research Reports: For synthetic underlayment, from an agency acceptable to authorities having jurisdiction, indicating that product is suitable for intended use under applicable building codes.

D. Sample Warranty: For manufacturer's materials warranty.

1.6 CLOSEOUT SUBMITTALS

A. Maintenance Data: For asphalt shingles to include in maintenance manuals.

B. Materials warranties.

C. Roofing Installer's warranty.

1.7 MAINTENANCE MATERIAL SUBMITTALS

A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.

1. Asphalt Shingles: 100 sq. ft. of each type and in each color and blend, in unbroken bundles.

1.8 QUALITY ASSURANCE

A. Installer Qualifications: An authorized installer who is trained and approved by manufacturer.

1.9 DELIVERY, STORAGE, AND HANDLING

A. Store roofing materials in a dry, well-ventilated location protected from weather, sunlight, and moisture in accordance with manufacturer's written instructions.

B. Store underlayment rolls on end, on pallets or other raised surfaces. Do not double-stack rolls.

C. Protect unused roofing materials from weather, sunlight, and moisture when left overnight or when roofing Work is not in progress.

D. Handle, store, and place roofing materials in a manner to prevent damage to roof deck or structural supporting members.

1.10 FIELD CONDITIONS

A. Environmental Limitations: Proceed with installation only when existing and forecasted weather conditions permit product installation and related Work to be performed in accordance with manufacturer's written instructions and warranty requirements.

1. Install self-adhering, polymer-modified bitumen sheet underlayment within the range of ambient and substrate temperatures recommended in writing by manufacturer.

1.11 WARRANTY

A. Materials Warranty: Manufacturer agrees to repair or replace asphalt shingles that fail within specified warranty period.

1. Failures include, but are not limited to, the following:

a. Manufacturing defects.

2. Materials Warranty Period: 30 years from date of Substantial Completion, prorated, with first five years nonprorated.
3. Wind-Speed Warranty Period: Asphalt shingles will resist blow-off or damage caused by wind speeds of up to 60 mph for five years from date of Substantial Completion.
4. Algae-Resistance Warranty Period: Asphalt shingles will not discolor for five years from date of Substantial Completion.
5. Workmanship Warranty Period: Two years from date of Substantial Completion.

B. Roofing Installer's Warranty: On warranty form at end of this Section, signed by Installer, in which Installer agrees to repair or replace components of asphalt shingle roofing that fail in materials or workmanship within specified warranty period.

1. Warranty Period: Two years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

A. Obtain each type of product from single source from single manufacturer.

2.2 PERFORMANCE REQUIREMENTS

A. Exterior Fire-Test Exposure: Provide asphalt shingles and related roofing materials identical to those of assemblies tested for Class A fire resistance in accordance with ASTM E108 or UL 790 by Underwriters Laboratories or another testing and inspecting agency acceptable to authorities having jurisdiction. Identify products with appropriate markings of applicable testing agency.

B. Wind Resistance: Provide asphalt shingles that comply with requirements of ASTM D3161/D3161M, Class F, and with ASTM D7158/D7158M, Class H.

2.3 GLASS-FIBER-REINFORCED ASPHALT SHINGLES

A. Impact-Resistant, Three-Tab-Strip Asphalt Shingles: ASTM D3462/D3462M; glass-fiber reinforced, mineral-granule surfaced, and self-sealing; with tabs regularly spaced and with impact resistance complying with UL 2218, Class 4.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to the following:

   a. CertainTeed Saint-Gobain.
   b. GAF
   c. C. Iko Industries, Inc.

2. Strip Size: Manufacturer's standard.
3. Algae Resistance: Granules resist algae discoloration.
4. Color and Blends: As selected by Architect from manufacturer's full range.

B. Ridge Shingles: Manufacturer's standard units to match asphalt shingles.

2.4 UNDERLAYMENT MATERIALS

A. Synthetic Underlayment: UV-resistant polypropylene, polyolefin, or polyethylene polymer fabric with surface coatings or treatments to improve traction underfoot and abrasion resistance evaluated and documented to be suitable for use as a roof underlayment under applicable codes by a testing and inspecting agency acceptable to authorities having jurisdiction.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into work include, but are not limited to the following:

   a. CertainTeed Saint-Gobain.
   b. GAF.
   c. IKO Industries Inc.

B. Self-Adhering, Polymer-Modified Bitumen Sheet: ASTM D1970/1970M, minimum 55-mil-thick sheet; glass-fiber-mat-reinforced, polymer-modified asphalt; with slip-resistant top surface and release backing; cold applied.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into work include, but are not limited to the following:

   a. CertainTeed Saint-Gobain.
   b. GAF.
   c. IKO Industries Inc.

2. Top Surface: Sand.

2.5 RIDGE VENTS

A. Rigid Ridge Vent: Manufacturer's standard, rigid-section, high-density, UV-stabilized plastic ridge vent for use under ridge shingles.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

   a. CertainTeed Saint-Gobain.
   b. GAF.
   c. Air Vent, Inc.; a Gibraltar Industries company.
   d. Cor-A-Vent, Inc.

2. Minimum Net Free Area: 22 square inches per foot.
3. Width: As required.
4. Thickness: As required.
5. Features:

   a. Nonwoven geotextile filter strips.
   b. External deflector baffles.

2.6 ACCESSORIES

A. Asphalt Roofing Cement: ASTM D4586/D4586M Type II, asbestos free.

B. Elastomeric Flashing Sealant: ASTM C920, Type S, Grade NS, one-part, non-sag, elastomeric polymer sealant; of class and use classifications required to seal joints and remain watertight; recommended in writing by manufacturer for installation of flashing systems.

C. Roofing Nails: ASTM F1667, aluminum, stainless steel, copper, or hot-dip galvanized-steel wire shingle nails, minimum 0.120-inch-diameter, sharp-pointed, with a 3/8- to 7/16-inch-diameter flat head and of sufficient length to penetrate 3/4 inch into solid wood decking or extend at least 1/8 inch through sheathing less than 3/4 inch thick.

1. Where nails are in contact with metal flashing, use nails made from same metal as flashing.

2.7 METAL FLASHING AND TRIM

A. Comply with requirements in Section 07 62 00 "Sheet Metal Flashing and Trim."

1. Sheet Metal: Aluminum, mill finished.

B. Fabricate sheet metal flashing and trim to comply with recommendations in SMACNA's "Architectural Sheet Metal Manual" that apply to design, dimensions, metal, and other characteristics of the item unless otherwise specified in this Section or indicated on Drawings.

1. Apron Flashings: Fabricate with lower flange a minimum of 4 inches over and 4 inches beyond each side of downslope asphalt shingles and 6 inches up the vertical surface.
2. Step Flashings: Fabricate with a headlap of 2 inches and a minimum extension of 4 inches over the underlying asphalt shingle and up the vertical surface.

3. Cricket and Backer Flashings: Fabricate with concealed flange extending a minimum of 18 inches beneath upslope asphalt shingles and 6 inches beyond each side of chimney and 6 inches above the roof plane.
4. Counterflashings: Fabricate to cover 4 inches of base flashing measured vertically; and in lengths required so that no step exceeds 8 inches and overall length is no more than 10 feet.

    a. Provide metal reglets for installation.

5. Drip Edges: Fabricate in lengths not exceeding 10 feet with minimum 2-inch roof-deck flange and 1-1/2-inch fascia flange with 3/8-inch drip at lower edge.
6. Vent-Pipe Flashings: ASTM B749, Type L51121, at least 1/16 inch thick. Provide lead sleeve sized to slip over and turn down into pipe, soldered to skirt at slope of roof, and extending at least 4 inches from pipe onto roof.

PART 3 - EXECUTION

3.1 EXAMINATION

A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.

1. Examine roof sheathing to verify that sheathing joints are supported by framing and blocking or metal clips and that installation is within flatness tolerances.
2. Verify that substrate is sound, dry, smooth, clean, sloped for drainage, and completely anchored and that provisions have been made for flashings and penetrations through asphalt shingles.
3. Verify that vent stacks and other penetrations through roofing are installed and securely fastened.

B. Prepare written report, endorsed by Installer, listing conditions detrimental to performance of the Work.

C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION OF UNDERLAYMENT MATERIALS

A. Comply with asphalt shingle and underlayment manufacturers' written installation instructions and with recommendations in NRCA's "The NRCA Roofing Manual: Steep-Slope Roof Systems" applicable to products and applications indicated unless more stringent requirements are specified in this Section or indicated on Drawings.

B. Self-Adhering, Polymer-Modified Bitumen Sheet: Install, wrinkle free, on roof deck.

1. Comply with low-temperature installation restrictions of underlayment manufacturer.
2. Install lapped in direction that sheds water.

    a. Lap sides not less than 4 inches.
    b. Lap ends not less than 6 inches, staggered 24 inches between succeeding courses.
    c. Roll laps with roller.

3. Prime concrete, masonry, and metal surfaces to receive self-adhering sheet.
4. Cover underlayment within seven days.

3.3 INSTALLATION OF METAL FLASHING AND TRIM

A. Install metal flashings and trim to comply with requirements in Section 07 62 00 "Sheet Metal Flashing and Trim."

1. Install metal flashings in accordance with recommendations in NRCA's "NRCA Guidelines for Asphalt Shingle Roof Systems."
2. Bed flanges of metal flashings using asphalt roofing cement or elastomeric flashing sealant.

B. Apron Flashings: Extend lower flange over and beyond each side of downslope asphalt shingles and up the vertical surface.

C. Step Flashings: Install with a headlap of 2 inches and extend over underlying shingle and up the vertical face.

1. Install with lower edge of flashing just upslope of, and concealed by, butt of overlying shingle.
2. Fasten to roof deck only.

D. Cricket and Backer Flashings: Install against roof-penetrating elements extending concealed flange beneath upslope asphalt shingles and beyond each side.

E. Counterflashings: Coordinate with installation of base flashing and fit tightly to base flashing. Lap joints a minimum of 4 inches secured in a waterproof manner.

1. Install in reglets or receivers.

F. Eave Drip Edges: Install below underlayment materials and fasten to roof deck.

G. Pipe Flashings: Form flashing around pipe penetrations and asphalt shingles. Fasten and seal to asphalt shingles as recommended by manufacturer.

3.4 INSTALLATION OF ASPHALT SHINGLES

A. Install asphalt shingles in accordance with manufacturer's written instructions and recommendations in NRCA's "NRCA Guidelines for Asphalt Shingle Roof Systems."

B. Install starter strip along lowest roof edge, consisting of an asphalt shingle strip with tabs removed with self-sealing strip face up at roof edge.

1. Extend asphalt shingles 1/2 inch over fasciae at eaves and rakes.

C. Install first and remaining courses of laminated asphalt shingles stair-stepping diagonally across roof deck with manufacturer's recommended offset pattern at succeeding courses, maintaining uniform exposure.

D. Install first and remaining courses of three-tab-strip asphalt shingles stair-stepping diagonally across roof deck with manufacturer's recommended offset pattern at succeeding courses, maintaining uniform exposure.

E. Fasten asphalt shingle strips with a minimum of six roofing nails, but not less than the number indicated in manufacturer's written instructions for roof slope and design wind speed indicated on Drawings and for warranty requirements specified in this Section.

1. Locate fasteners in accordance with manufacturer's written instructions.
2. Where roof slope exceeds 18:12, hand seal self-sealing asphalt shingles to improve the shingles' positive bond by applying asphalt roofing cement spots between course overlaps after nailing the upper course.
3. Where roof slope is less than 4:12, hand seal self-sealing asphalt shingles to improve the shingles' positive bond by applying asphalt roofing cement spots between course overlaps after nailing the upper course.
4. When ambient temperature during installation is below 50 deg F, hand seal self-sealing asphalt shingles by applying asphalt roofing cement spots between course overlaps after nailing the upper course.

F. Ridge Vents: Install continuous ridge vents over asphalt shingles in accordance with manufacturer's written instructions. Fasten with roofing nails of sufficient length to penetrate sheathing.

G. Ridge Shingles: Maintain same exposure of cap shingles as roofing-shingle exposure. Lap cap shingles at ridges to shed water away from direction of prevailing winds.

1. Fasten with roofing nails of sufficient length to penetrate sheathing.
2. Fasten ridge cap asphalt shingles to cover ridge vent without obstructing airflow.

END OF SECTION