AUTO DIALER ALARM LIST BAGHURST PUMP HOUSE				
#	Instrument Tag	ALARM	Service	Comments
1	FQIR-101	INSTRUMENT FAILURE	INFLUENT FLOW	
2	AV	ALTITUDE VALVE ALARM	INFLUENT CONTROL	
3	STORAGE TANK	HIGH LEVEL	WATER STORAGE	
4	STORAGE TANK	LOW LEVEL	WATER STORAGE	
5	PDIT-201	INSTRUMENT FAILURE	WATER STORAGE TANK LEVEL	
6	PIT-101	LOW INFLUENT PRESSURE	INFLUENT MONITORING	
7	PIT-101	INSTRUMENT FAILURE	INFLUENT MONITORING	
8	MIXER CONTROLLER	TANK MIXER ALARM	AGITATE STORAGE TANK CONTENTS	
9	CHLORINATOR CONTROLLER	CHLORINATION ALARM	CHLORINE ADDITION	
10	HS PUMP CONTROLLER	HIGH SERVICE PUMP SKID ALARM	HIGH SERVICE PUMP CONTROL	
11	PIT-301	HIGH SERVICE PUMP LOW SUCTION PRESSURE	HIGH SERVICE PUMP SUCTION PRESSURE	
12	PIT-301	INSTRUMENT FAILURE	HIGH SERVICE PUMP SUCTION PRESSURE	
13	PIT-302	INSTRUMENT FAILURE	HIGH SERVICE PUMP DISCHARGE PRESSURE	
14	LEP	LOW EFFLUENT PRESSURE	PUMP STATION EFFLUENT	
15	RS PUMP CONTROLLER	RESIDENTIAL SERVICE PUMP SKID ALARM	RESIDENTIAL SERVICE PUMP CONTROL	
16	PIT-401	RESIDENTIAL SERVICE PUMP LOW SUCTION PRESSURE	RESIDENTIAL SERVICE PUMP SUCTION PRESSURE	
17	PIT-401	INSTRUMENT FAILURE	RESIDENTIAL SERVICE PUMP SUCTION PRESSURE	
18	PIT-402	INSTRUMENT FAILURE	RESIDENTIAL SERVICE PUMP DISCHARGE PRESSURE	
19	YS-401	STANDING WATER ON PUMP FLOOR	FREE WATER MONITOR	
20	FQIR-501	INSTRUMENT FAILURE	EFFLUENT FLOW	
21	ATS-1	GRID POWER SOURCE AVAILABLE	STATION ELECTRICAL	
22	ATS-2	GENERATOR POWER SOURCE AVAILABLE	STATION ELECTRICAL	
23	ATS-3	TRANSFER SWITCH FAULT	STATION ELECTRICAL	
24	ATS-4	GENERATOR FAULT	STATION ELECTRICAL	
25	ATS-5	SWITCH IN GRID POSTION	STATION ELECTRICAL	
26	ATS-6	SWITCH IN GENERATOR POSITION	STATION ELECTRICAL	
27	UPS	UPS ALARM	INSTRUMENT PANEL POWER	