

County Map of MO	Water System Search	Help	Questions/Comments? Contact Us
----------------------------------	-------------------------------------	----------------------	---

Water System Detail Information

Water System No.: MO4010743
 Water System Name: SIKESTON PWS
 Principal County / City Served: SCOTT / SIKESTON
 Local Name:
 Operating Category Code: C3
 GWR Monitoring Status: GWR - Compliance Monitoring

Federal Type: C
 Federal Source: GW
 System Status : A
 Activity Date : 01-01-1930
 Permit Date : 01-01-1930

Sample Number: 2121705		For Compliance? Y						
Other Chemical Sample Results								
Analyte Code	Analyte Name	Method	Less Than Ind.	Level Type	Reporting Level	Concentration	MCL	Mon Period
2981	1,1,1-TRICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L		0.2 MG/L	01-01-2022 03-31-2022
2985	1,1,2-TRICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	01-01-2022 03-31-2022
2977	1,1-DICHLOROETHYLENE	524.2	<	MRL	0.500000000 UG/L		0.007 MG/L	01-01-2022 03-31-2022
2378	1,2,4-TRICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.07 MG/L	01-01-2022 03-31-2022
2931	1,2-DIBROMO-3-CHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L		0.0002 MG/L	
2980	1,2-DICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	01-01-2022 03-31-2022
2983	1,2-DICHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	01-01-2022 03-31-2022
2990	BENZENE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	01-01-2022 03-31-2022
2943	BROMODICHLOROMETHANE	524.2				3.84 UG/L	0.10 MG/L	

2942	BROMOFORM	524.2	<	MRL	0.500000000 UG/L		0.10 MG/L	
2982	CARBON TETRACHLORIDE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	01-01- 2022 03-31- 2022
2989	CHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.1 MG/L	01-01- 2022 03-31- 2022
2941	CHLOROFORM	524.2				4.62 UG/L	0.10 MG/L	
2380	CIS-1,2- DICHLOROETHYLENE	524.2				0.58 UG/L	0.07 MG/L	01-01- 2022 03-31- 2022
2944	DIBROMOCHLOROMETHANE	524.2				1.75 UG/L	0.10 MG/L	
2964	DICHLOROMETHANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	01-01- 2022 03-31- 2022
2992	ETHYLBENZENE	524.2	<	MRL	0.500000000 UG/L		0.7 MG/L	01-01- 2022 03-31- 2022
2946	ETHYLENE DIBROMIDE	524.2	<	MRL	0.100000000 UG/L		0.00005 MG/L	
2251	METHYL TERT-BUTYL ETHER	524.2	<	MRL	1.000000000 UG/L			
2968	O-DICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.6 MG/L	01-01- 2022 03-31- 2022
2997	O-XYLENE	524.2	<	MRL	0.500000000 UG/L		10 MG/L	
2969	P-DICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.075 MG/L	01-01- 2022 03-31- 2022
2996	STYRENE	524.2	<	MRL	0.500000000 UG/L		0.1 MG/L	01-01- 2022 03-31- 2022
2987	TETRACHLOROETHYLENE	524.2				0.87 UG/L	0.005 MG/L	01-01- 2022 03-31- 2022
2991	TOLUENE	524.2	<	MRL	0.500000000 UG/L		1 MG/L	01-01- 2022 03-31- 2022
2979	TRANS-1,2- DICHLOROETHYLENE	524.2	<	MRL	0.500000000 UG/L		0.1 MG/L	01-01- 2022 03-31- 2022

2984	TRICHLOROETHYLENE	524.2				1.06 UG/L	0.005 MG/L	01-01- 2022 03-31- 2022
2976	VINYL CHLORIDE	524.2	<	MRL	0.500000000 UG/L		0.002 MG/L	01-01- 2022 03-31- 2022
2963	XYLENE, META AND PARA	524.2	<	MRL	1.000000000 UG/L			
2955	XYLENES, TOTAL	524.2	<	MRL	0.500000000 UG/L		10 MG/L	01-01- 2022 03-31- 2022