

County Map of MO	Water System Search	Help	Questions/Comments? Contact Us
----------------------------------	-------------------------------------	----------------------	---

Water System Detail Information

Water System No.: MO4010743
 Water System Name: SIKESTON PWS
 Principal County / City Served: SCOTT / SIKESTON
 Local Name:
 Operating Category Code: C3
 GWR Monitoring Status: GWR - Compliance Monitoring

Federal Type: C
 Federal Source: GW
 System Status : A
 Activity Date : 01-01-1930
 Permit Date : 01-01-1930

Sample Number: 090622737-05		For Compliance? Y						
Other Chemical Sample Results								
Analyte Code	Analyte Name	Method	Less Than Ind.	Level Type	Reporting Level	Concentration	MCL	Mon Period
2986	1,1,1,2-TETRACHLOROETHANE	524.2	<	MRL	0.500000000 UG/L			
2981	1,1,1-TRICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L		0.2 MG/L	07-01-2009 09-30-2009
2988	1,1,2,2-TETRACHLOROETHANE	524.2	<	MRL	0.500000000 UG/L			
2985	1,1,2-TRICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	07-01-2009 09-30-2009
2978	1,1-DICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L			
2977	1,1-DICHLOROETHYLENE	524.2	<	MRL	0.500000000 UG/L		0.007 MG/L	07-01-2009 09-30-2009
2410	1,1-DICHLOROPROPENE	524.2	<	MRL	0.500000000 UG/L			
2420	1,2,3-TRICHLOROBENZENE	524.2	<	MRL	1.000000000 UG/L			
2414	1,2,3-TRICHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L			
2378	1,2,4-TRICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.07 MG/L	07-01-2009 09-30-2009
2418	1,2,4-TRIMETHYLBENZENE	524.2	<	MRL	0.500000000 UG/L			
2931	1,2-DIBROMO-3-CHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L		0.0002 MG/L	
2980	1,2-DICHLOROETHANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	07-01-2009 09-30-2009
2983	1,2-DICHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	07-01-2009

								09-30-2009
2424	1,3,5-TRIMETHYLBENZENE	524.2	<	MRL	0.500000000 UG/L			
2412	1,3-DICHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L			
2416	2,2-DICHLOROPROPANE	524.2	<	MRL	0.500000000 UG/L			
2990	BENZENE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	07-01-2009 09-30-2009
2993	BROMOBENZENE	524.2	<	MRL	0.500000000 UG/L			
2430	BROMOCHLOROMETHANE	524.2	<	MRL	0.500000000 UG/L			
2943	BROMODICHLOROMETHANE	524.2	<	MRL	0.500000000 UG/L		0.10 MG/L	
2942	BROMOFORM	524.2	<	MRL	0.500000000 UG/L		0.10 MG/L	
2214	BROMOMETHANE	524.2	<	MRL	2.500000000 UG/L			
2982	CARBON TETRACHLORIDE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	07-01-2009 09-30-2009
2989	CHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.1 MG/L	07-01-2009 09-30-2009
2216	CHLOROETHANE	524.2	<	MRL	5.000000000 UG/L			
2941	CHLOROFORM	524.2	<	MRL	0.500000000 UG/L		0.10 MG/L	
2210	CHLOROMETHANE	524.2	<	MRL	10.000000000 UG/L			
2380	CIS-1,2-DICHLOROETHYLENE	524.2				1.57 UG/L	0.07 MG/L	07-01-2009 09-30-2009
2228	CIS-1,3-DICHLOROPROPENE	524.2	<	MRL	0.500000000 UG/L			
2944	DIBROMOCHLOROMETHANE	524.2	<	MRL	0.500000000 UG/L		0.10 MG/L	
2408	DIBROMOMETHANE	524.2	<	MRL	0.500000000 UG/L			
2212	DICHLORODIFLUOROMETHANE	524.2	<	MRL	1.000000000 UG/L			
2964	DICHLOROMETHANE	524.2	<	MRL	0.500000000 UG/L		0.005 MG/L	07-01-2009 09-30-2009
2992	ETHYLBENZENE	524.2	<	MRL	0.500000000 UG/L		0.7 MG/L	07-01-2009 09-30-2009
2946	ETHYLENE DIBROMIDE	524.2	<	MRL	0.100000000 UG/L		0.00005 MG/L	
2246	HEXACHLOROBUTADIENE	524.2	<	MRL	1.000000000 UG/L			
2994	ISOPROPYLBENZENE	524.2	<	MRL	0.500000000 UG/L			
2967	M-DICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L			
2251	METHYL TERT-BUTYL ETHER	524.2	<	MRL	1.000000000 UG/L			
2422	N-BUTYLBENZENE	524.2	<	MRL	0.500000000 UG/L			

2998	N-PROPYLBENZENE	524.2	<	MRL	0.500000000 UG/L			
2248	NAPHTHALENE	524.2	<	MRL	1.000000000 UG/L			
2965	O-CHLOROTOLUENE	524.2	<	MRL	0.500000000 UG/L			
2968	O-DICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.6 MG/L	07-01- 2009 09-30- 2009
2997	O-XYLENE	524.2	<	MRL	0.500000000 UG/L		10 MG/L	
2966	P-CHLOROTOLUENE	524.2	<	MRL	0.500000000 UG/L			
2969	P-DICHLOROBENZENE	524.2	<	MRL	0.500000000 UG/L		0.075 MG/L	07-01- 2009 09-30- 2009
2030	P-ISOPROPYLTOLUENE	524.2	<	MRL	0.500000000 UG/L			
2428	SEC-BUTYLBENZENE	524.2	<	MRL	0.500000000 UG/L			
2996	STYRENE	524.2	<	MRL	0.500000000 UG/L		0.1 MG/L	07-01- 2009 09-30- 2009
2426	TERT-BUTYLBENZENE	524.2	<	MRL	0.500000000 UG/L			
2987	TETRACHLOROETHYLENE	524.2				5.05 UG/L	0.005 MG/L	07-01- 2009 09-30- 2009
2991	TOLUENE	524.2	<	MRL	0.500000000 UG/L		1 MG/L	07-01- 2009 09-30- 2009
2979	TRANS-1,2-DICHLOROETHYLENE	524.2	<	MRL	0.500000000 UG/L		0.1 MG/L	07-01- 2009 09-30- 2009
2224	TRANS-1,3-DICHLOROPROPENE	524.2	<	MRL	0.500000000 UG/L			
2984	TRICHLOROETHYLENE	524.2				0.89 UG/L	0.005 MG/L	07-01- 2009 09-30- 2009
2218	TRICHLOROFLUOROMETHANE	524.2	<	MRL	0.500000000 UG/L			
2950	TTHM	524.2	<	MRL	2.000000000 UG/L		0.080 MG/L	
2976	VINYL CHLORIDE	524.2	<	MRL	0.500000000 UG/L		0.002 MG/L	07-01- 2009 09-30- 2009
2963	XYLENE, META AND PARA	524.2	<	MRL	0.500000000 UG/L			
2955	XYLENES, TOTAL	524.2	<	MRL	1.000000000 UG/L		10 MG/L	07-01- 2009 09-30- 2009