

DRAFT ANNUAL OPERATIONS REPORT 2007

For The Pemaco Remedial Action

PEMACO SUPERFUND SITE

5050 E. Slauson Avenue
Maywood, California

Prepared for:

U.S. Environmental Protection Agency
Region IX
San Francisco, California



U.S. Army Corps of Engineers
Omaha District
Omaha, Nebraska



Prepared by:

TN & Associates, Inc.
&A Engineering and Science
317 E. Main Street
Ventura, California 93001

January 2008

DRAFT ANNUAL OPERATIONS REPORT 2007

For

PEMACO SUPERFUND SITE MAYWOOD, CALIFORNIA

Prepared for
U.S. Environmental Protection Agency – Region IX
San Francisco, California

U.S. Army Corps of Engineers – Omaha District
Omaha, Nebraska

January 2008

Signature:

Timothy P. Garvey
TN&A Project Manager

Date

Signature:

John Wingate, PE
TN&A Project QC Manager/Project Engineer

Date

Signature:

Dacre Bush
TN&A Project QC Manager/Senior Remediation Specialist

Date

Signature:

Angela Smith, M.Sc.
TN&A Project Environmental Engineer

Date



T N & Associates, Inc.

Engineering and Science

317 E. Main Street

Ventura, CA 93001

EXECUTIVE SUMMARY

This Annual Operations Report (AOR) 2007 has been prepared by T N & Associates, Inc. (TN&A) under the U. S. Army Corps of Engineers (USACE) contract DACA# 4500-D-0066 for the Pemaco Superfund Site Remedial Action to summarize operation and maintenance activities conducted at the vapor and groundwater treatment plant as well as to report on the treatment system performance at the Pemaco Superfund Site (the Site) in Maywood, California. The USACE, Omaha District provides contract management and construction oversight for the United States Environmental Protection Agency (EPA).

The remedial action being implemented according to the Record of Decision (ROD) for the Pemaco Superfund Site dated January 13, 2005 (EPA, 2005) consists of dual-phase extraction (DPE), groundwater extraction, and soil vapor extraction processes. These processes remove volatile organic compounds (VOCs), namely trichloroethene (TCE), from the subsurface. Electrical resistance heating (ERH) is also being used in the source area (the area with the highest TCE concentrations) to expedite the remediation process, which is anticipated to take 5 years. The AOR 2007 focuses on the treatment system performance as the details regarding ERH will be the subject of a separate report. This report covers two (2) phases of the planned remedial action, as described in the Final Design Report (TN&A, 2006):

- Phase I: commissioning and startup of the groundwater (April 25, 2007) and vapor (May 4, 2007) extraction and treatment systems,
- Phase II: operation and maintenance (O&M) of the vapor and groundwater extraction and treatment system during thermal treatment of the source area via ERH, which began on September 25, 2007, is currently underway.

In 2007, not one reportable incident occurred at the Site as a result of operations and TN&A employees successfully completed 17,967.5 incident-free hours. The operation of the vapor and groundwater treatment system was in 100% compliance with the applicable or relevant and appropriate requirements (ARARs) including both the South Coast Air Quality Management District's (SCAQMD's) vapor discharge guidance and the Sanitation District of Los Angeles County's (SDLAC's) sewer discharge permit.

System performance data is collected on a daily basis at the Site to ensure compliance with the discharge permits and to ensure the effective and safe operation of the treatment system. Key performance statistics for the operation of the vapor and groundwater treatment systems from April 25, 2007 through to December 31, 2007 are summarized below:

| Treatment System: | Vapor | Groundwater | TOTAL |
|----------------------------|-----------------|--------------------|---------------|
| Total Mass of TCE Removed | 197 pounds | 26 pounds | 223 pounds |
| Total Mass of VOCs Removed | 12,736 pounds | 47 pounds | 12,783 pounds |
| Average TCE Removal Rate | 0.88 lbs/day | 0.08 lbs/day | 0.96 lbs/day |
| Average VOC Removal Rate | 56 lbs/day | 0.14 lbs/day | 56 lbs/day |
| Average Flow Rate | 553 scfm | 31 gpm | |
| Cumulative Volume Treated | 176,696,475 scf | 11,460,978 gallons | |
| Operating Time | 4,314 hours | 5,667 hours | |
| Percent Uptime | 74% | 94% | |

Notes: gpm – gallons per minute; lbs/day – pounds per day; scf – standard cubic feet; scfm – standard cubic feet per minute

This AOR describes important elements of the treatment system operation, the optimization activities that were performed at the Site in 2007, and the performance of both the vapor and groundwater treatment systems.

TABLE OF CONTENTS

| | | |
|-------------|---|-----------|
| 1.0 | INTRODUCTION..... | 1 |
| 1.1 | SITE BACKGROUND | 1 |
| 1.2 | INVESTIGATIVE SITE HISTORY | 2 |
| 1.3 | REMEDIAL ACTION OBJECTIVES..... | 2 |
| 1.4 | PROJECT TEAM ROLES AND RESPONSIBILITIES..... | 2 |
| 2.0 | REMEDIAL ACTION..... | 4 |
| 2.1 | PHASE I – SYSTEM COMMISSIONING AND ESTABLISHMENT OF HYDRAULIC AND PNEUMATIC CONTROL | 4 |
| 2.2 | PHASE II – ERH AND CONTINUED VAPOR AND GROUNDWATER EXTRACTION | 4 |
| 2.3 | PHASE III – POST-ERH VAPOR AND GROUNDWATER EXTRACTION | 5 |
| 3.0 | VAPOR EXTRACTION AND TREATMENT | 6 |
| 3.1 | WELL FIELD OPERATION AND MONITORING | 6 |
| 3.1.1 | Perched Zone DPE Well Operation..... | 6 |
| 3.1.2 | Exposition Zone and ERH Area Vapor Extraction Well Operation | 7 |
| 3.2 | TREATMENT PLANT OPERATION AND MONITORING | 7 |
| 3.2.1 | Sample Collection and Analysis Methods | 8 |
| 3.2.2 | Process Vapor Analytical Results..... | 9 |
| 3.2.3 | Quality Assurance / Quality Control Summary | 10 |
| 3.2.4 | Performance Evaluation Sampling | 10 |
| 3.3 | SYSTEM PERFORMANCE..... | 11 |
| 4.0 | GROUNDWATER EXTRACTION AND TREATMENT..... | 13 |
| 4.1 | WELL FIELD OPERATION AND MONITORING | 13 |
| 4.2 | TREATMENT PLANT OPERATION AND MONITORING | 13 |
| 4.2.1 | Sample Collection and Analysis Methods | 14 |
| 4.2.2 | Process Water Analytical Results..... | 14 |
| 4.2.3 | Quality Assurance / Quality Control Summary | 15 |
| 4.2.4 | Performance Evaluation Sampling | 15 |
| 4.3 | SYSTEM PERFORMANCE..... | 15 |
| 5.0 | TREATMENT SYSTEM CONTROLS | 17 |
| 5.1 | CONTROL SYSTEM | 17 |
| 5.2 | PLC AND SMC SOFTWARE..... | 17 |
| 5.3 | SYSTEM ALARM OVERVIEW | 18 |
| 6.0 | TREATMENT SYSTEM OPTIMIZATION & MAINTENANCE | 19 |
| 7.0 | DATA MANAGEMENT | 22 |
| 8.0 | RESOURCES AND UTILITIES..... | 23 |
| 9.0 | PERMITTING, COMPLIANCE, AND ENVIRONMENTAL PROTECTION | 24 |
| 9.1 | VAPOR DISCHARGE GUIDANCE | 24 |
| 9.2 | SEWER DISCHARGE PERMIT | 25 |
| 10.0 | WASTE MANAGEMENT | 27 |
| 10.1 | EXAMPLES OF WASTE STREAMS..... | 27 |

| | | |
|-------------|--|-----------|
| 10.2 | WASTE MANIFESTS AND DISPOSAL | 27 |
| 10.3 | OFF-SITE WASTE TRANSPORTATION AND DISPOSAL | 28 |
| 10.4 | RECORD KEEPING | 28 |
| 11.0 | PROJECT DATA COMMUNICATIONS..... | 30 |
| 11.1 | PROJECT WEBSITE | 30 |
| 11.2 | SCHEDULED AND UNSCHEDULED COMMUNICATIONS | 30 |
| 12.0 | HEALTH AND SAFETY MANAGEMENT..... | 32 |
| 12.1 | HEALTH AND SAFETY DOCUMENTS | 33 |
| 12.2 | EMERGENCY RESPONSE ACTIONS | 33 |
| 13.0 | SECURITY AND SITE ACCESS CONTROL..... | 34 |
| 14.0 | REFERENCES..... | 35 |

FIGURES

| | |
|------------|--|
| Figure 1.1 | Site Location Map |
| Figure 1.2 | Pemaco Well Field Map |
| Figure 1.3 | Electrical Resistance Heating (ERH) Map |
| Figure 1.4 | Project Team Organizational Chart |
| Figure 2.1 | General Piping and Instrumentation Diagram |
| Figure 2.2 | General Piping and Instrumentation Diagram – VCP and Compressed Air System |
| Figure 2.3 | Treatment Compound Process Layout |
| Figure 5.1 | System Main Computer Screenshots |
| Figure 7.1 | Data Management Flow Diagram |

TABLES

| | |
|------------|--|
| Table 2.1 | Treatment System Equipment |
| Table 2.2 | Extraction Well Specifications |
| Table 3.1 | Field Form Summary |
| Table 3.2 | Vapor Extraction Well Field Sampling Data |
| Table 3.3 | Vapor Extraction Manifold Sampling Data |
| Table 3.4 | Vapor Sample Ports |
| Table 3.5 | VOC Analytical Results for the Vapor Extraction Manifold |
| Table 3.6 | VOC Analytical Results for the Influent to the Vapor Treatment System |
| Table 3.7 | TIC Analytical Results in Vapor Samples |
| Table 3.8 | Light Hydrocarbon Analytical Results for the Influent to the Vapor Treatment System |
| Table 3.9 | VOC Analytical Results for the Vapor Treatment System Samples |
| Table 3.10 | VOC Analytical Method Comparison for Vapor Samples from SP-104 and SP-109 |
| Table 3.11 | PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a |
| Table 3.12 | QA/QC of Analytical Results for Vapor Samples |
| Table 3.13 | Vapor Treatment System Performance |
| Table 3.14 | Vapor Discharge Analytical Results for Effluent Vapor Samples from SP-104a and SP-109a |
| Table 3.15 | DRE of the Vapor Treatment System |
| Table 4.1 | Groundwater Extraction Well Field and Manifold Sampling Data |
| Table 4.2 | Groundwater Sample Ports |

TABLES CONTINUED

| | |
|------------|---|
| Table 4.3 | VOC Analytical Results for the Groundwater Extraction Manifold |
| Table 4.4 | VOC Analytical Results for the Groundwater Treatment System Samples |
| Table 4.5 | Groundwater Treatment System Performance |
| Table 4.6 | Sewer Discharge Analytical Results for Effluent Groundwater Samples from SP-209 |
| Table 4.7 | DRE of the Groundwater Treatment System |
| Table 6.1 | Optimization and Maintenance of the Treatment System Summary |
| Table 6.2 | Daily and Weekly Maintenance Summary |
| Table 6.3 | Equipment Maintenance Schedule |
| Table 6.4 | FTO Maintenance Schedule |
| Table 8.1 | Resource and Utility Usage Summary |
| Table 10.1 | Waste GAC and Filter Bag Disposal Summary |
| Table 11.1 | Sample Daily Report |
| Table 11.2 | Sample Operations Summary |
| Table 11.3 | Sample Project Schedule |

GRAPHS

| | |
|-----------|---|
| Graph 3.1 | Vapor Influent VOC Concentrations and VOC Mass Removal Trends |
| Graph 3.2 | Vapor Extraction Volumes and Cumulative VOC Mass Removal |
| Graph 4.1 | Groundwater Influent VOC Concentrations and VOC Mass Removal Trends |
| Graph 4.2 | Groundwater Extraction Volumes and Cumulative VOC Mass Removal |

APPENDICES

| | |
|------------|-----------------------------------|
| Appendix 1 | Field Sampling Forms |
| Appendix 2 | Additional Analytical Results |
| Appendix 3 | Performance Evaluation Sampling |
| Appendix 4 | Laboratory Reports |
| Appendix 5 | Vapor and Sewer Discharge Permits |
| Appendix 6 | Waste Characterization |
| Appendix 7 | O&M Reports |

ACRONYMS AND ABBREVIATIONS

| | |
|---------------------|---|
| µg/L | microgram per liter |
| °C | degree Celsius |
| °F | degree Fahrenheit |
| AHA | Activity Hazard Analysis |
| AOR | Annual Operations Report |
| APP | Accident Prevention Plan |
| AST | above ground storage tank |
| BACT | Best Available Control Technology |
| CERCLA | Comprehensive Environmental Response, Compensation, and Liability Act |
| <i>cis</i> -1,2-DCE | <i>cis</i> -1,2-dichloroethene |
| CO | carbon monoxide |
| COCs | chemicals of concern |
| COD | chemical oxygen demand |
| DPE | dual-phase extraction |
| DRE | destruction and removal efficiency |
| dscm | dry standard cubic meter |
| EDD | electronic data deliverable |
| EDMS | Environmental Data Management System |
| EPA | United States Environmental Protection Agency |
| EPP | Environmental Protection Plan |
| ERH | electrical resistance heating |
| ERM | Environmental Resources Management, Inc. |
| FE | flow element |
| FTO | flameless thermal oxidizer |
| GAC | granular activated carbon |
| gpm | gallons per minute |
| HVDPE | high vacuum dual-phase extraction |
| ISMS | Integrated Safety Management System |
| J&H | Jacob & Hefner Associates |
| kWh | kilowatt hours |
| MCP | main control panel |
| mL | milliliter |
| MOMP | Management and Operation and Maintenance Plan |
| NCP | National Contingency Plan |
| NESHAP | National Emission Standard for Hazardous Air Pollutants |
| O&M | operation and maintenance |
| OSHA | Occupational Safety and Health Agency |
| PCDDs | polychlorinated dibenzodioxins |
| PCDFs | polydichlorinated dibenzofurans |
| PID | photo ionization detector |
| PLC | programmable logic controller |
| ppbv | part per billion by volume |
| ppm | part per million |
| ppmv | part per million by volume |
| PPE | personal protective equipment |
| QA/QC | quality assurance / quality control |
| RAO | remedial action objective |

ACRONYMS AND ABBREVIATIONS CONTINUED

| | |
|--------|--|
| RCRA | Resource Conservation and Recovery Act |
| ROD | Record of Decision |
| RPM | Remedial Project Manager |
| SAP | Sampling and Analysis Plan |
| SARA | Superfund Amendments and Reauthorization Act |
| SCADA | system control and data acquisition |
| SCAQMD | South Coast Air Quality Management District |
| scf | standard cubic feet |
| scfm | standard cubic feet per minute |
| SDLAC | Sanitation District of Los Angeles County |
| SIM | selective ion mode |
| SMC | system main computer |
| SQL | Sequel Data Base |
| SSHP | Site Safety and Health Plan |
| SSRL | Site Specific Remediation Level |
| SVE | soil vapor extraction |
| SVOC | semivolatile organic compound |
| TACs | toxic air contaminants |
| TCE | trichloroethene |
| TEQ | toxic equivalent |
| TICs | tentatively identified compounds |
| TMP | temperature monitoring probe |
| TN&A | T N & Associates, Inc. |
| TRS | Thermal Remediation Services, Inc. |
| TSS | total suspended solids |
| UPS | uninterruptable power supply |
| USACE | United States Army Corps of Engineers |
| UST | underground storage tank |
| VE | vapor extraction |
| VOAs | volatile organic analyte vials |
| VOC | volatile organic compound |
| VR | vapor recovery well |

1.0 INTRODUCTION

This Annual Operations Report (AOR) 2007 has been prepared by T N & Associates, Inc. (TN&A) under the U. S. Army Corps of Engineers (USACE) contract DACA# 4500-D-0066 for the Pemaco Superfund Site Remedial Action to summarize operation and maintenance activities conducted at the vapor and groundwater treatment plant as well as to report on the treatment system performance at the Pemaco Superfund Site (the Site) in Maywood, California (Figure 1.1). The USACE, Omaha District provides contract management and construction oversight for the United States Environmental Protection Agency (EPA).

The remedial action is being performed under the authority of the Comprehensive Environmental Response, Compensation and Liability Act (CERCLA, also known as "Superfund") as amended by the Superfund Amendments and Reauthorization Act (SARA) and the CERCLA regulations published in the National Oil and Hazardous Substances Pollution Contingency Plan (NCP). TN&A is performing this work under contracts issued by USACE, Omaha District for the EPA, Region IX.

The remedial action being implemented according to the record of decision (ROD; Record of Decision for the Pemaco Superfund Site [EPA, 2005]) consists of dual-phase extraction (DPE), groundwater extraction, and soil vapor extraction processes. These processes remove volatile organic compounds (VOCs), namely trichloroethene (TCE), from the subsurface (Figure 1.2). A comprehensive description of the extraction and treatment system is provided in the *Final Remedial Design Report, Pemaco Superfund Site*, (TN&A, 2006). Electrical resistance heating (ERH) is also being used in the source area (the area with the highest TCE concentrations) to expedite the remediation process, which is anticipated to take 5 years (Figure 1.3). The AOR 2007 focuses on the treatment system performance as the details regarding ERH will be the subject of a separate report. This report covers two phases of the planned remedial action, as described in the Final Design Report (TN&A, 2006):

- Phase I: commissioning and startup of the groundwater (April 25, 2007) and vapor (May 4, 2007) extraction and treatment systems,
- Phase II: operation and maintenance (O&M) of the vapor and groundwater extraction and treatment system during thermal treatment of the source area via ERH, which began on September 25, 2007, is currently underway.

Progress on the groundwater and soil vapor remediation is documented by the Quarterly Groundwater Monitoring Reports, on-going reports, and real-time website data for the ERH remediation. A final report documenting the remediation of the ERH area will be submitted to the EPA 90 days after the cessation of heating.

This AOR describes important elements of the treatment system operation, the optimization activities that were performed at the Site in 2007, and the performance of both the vapor and groundwater treatment systems.

1.1 SITE BACKGROUND

The Pemaco Superfund Site is comprised of 1.4 acres located in a mixed industrial and residential neighborhood in Maywood, Los Angeles County, California. Figure 1.1 shows the Site location and vicinity map. The facility formally operated as a custom chemical blender from the 1950s until 1991. A wide variety of chemicals were used and stored on site including chlorinated and aromatic solvents, flammable liquids, oils and specialty chemicals. These

chemicals were stored in drums, aboveground storage tanks (ASTs) and underground storage tanks (USTs). In 1991, the facility was abandoned by its owner. Remaining stored chemicals in drums and storage tanks (USTs) were removed by the EPA between 1992 and 1998.

1.2 INVESTIGATIVE SITE HISTORY

Environmental assessments performed between 1990 and 1999 identified soil and groundwater contamination that originated from the blending and storage of chemicals at the Site. A soil vapor extraction (SVE) system was installed as an interim treatment measure in 1998 and operated until 1999, when it was shut down due to community concerns about emissions from the thermal oxidation unit used to treat the extracted vapors.

The EPA enlisted the Pemaco Site into the Superfund program in 1999, and TN&A performed a full-scale remedial investigation between January 2001 and November 2001. TN&A conducted treatability tests including aquifer testing in December 2001 and a high vacuum dual-phase extraction (HVDPE) pilot test in December 2002. Additional source area evaluation was performed in September 2003 via membrane interface probes. The ROD for the soil vapor and groundwater systems was finalized in January 2005. Groundwater monitoring, "data gap" investigations, and pilot-scale activities for the evaluation of remedial technologies have been in progress for the Pemaco Site since May 2001.

1.3 REMEDIAL ACTION OBJECTIVES

The remedial action objectives (RAOs) for the Pemaco Superfund Site are to protect human health and the environment from threats caused by exposure to contaminated soil, soil vapor, indoor air, and groundwater; and to restore groundwater to potential beneficial use as a drinking water source. All chemicals of concern (COCs) have been identified at the Site and are listed with their respective Site Specific Remediation Levels (SSRLs) in the in the Pemaco ROD dated January 13, 2005 (EPA, 2005). In order to meet the RAO for the primary contaminant at Pemaco, TCE, it will be necessary to remediate groundwater to 5 micrograms per liter (µg/L) and soil to 60 parts per billion by volume (ppbv) by the end of the remediation period, which is scheduled for 5 years.

For expedited source reduction to meet the groundwater and soil RAOs within the source area (approximately 30,000 cubic yards), subsurface heating by ERH began on September 25, 2007 to heat the soil and groundwater to the boiling temperature of water. Heating to temperature and holding at temperature for 30 days will require approximately 3.4 million kilowatt hours (kWh) of electricity and approximately 206 days. To meet the RAOs in the soil and groundwater using ERH, an additional 90 days of heating and an additional 3.0 million kWh of electricity would be required.

The City of Maywood, in conjunction with the Trust for Public Land, has developed the northern portion of the Site and adjacent properties as the Maywood Riverfront Park, a public recreational area. The future remedial activities at the Site will be integrated with the existence of this park.

1.4 PROJECT TEAM ROLES AND RESPONSIBILITIES

Detailed explanations of the roles and responsibilities for each of the TN&A project team members directly connected to the operation of the treatment system are provided below.

| Position | Name | Major Roles and Responsibilities |
|--------------------------------|-------------------|---|
| Project Director | Tim Garvey | <ul style="list-style-type: none"> • Ensure sufficient corporate resources for successful operation and completion of the project • Act as a technical resource and manage the bioremediation pilot test |
| Project Manager | Dacre Bush | <ul style="list-style-type: none"> • Manage all project activities and administrate funds • Assign and coordinate project resources • Maintain compliance with environmental, health and safety, and quality assurance • Report to the EPA Remedial Project Manager (RPM) on project progress, expenditures, and spending projections • Review and report cost and schedule variances |
| Senior Engineer | John Wingate | <ul style="list-style-type: none"> • Oversee the extraction and treatment system • Perform site inspections, review all physical and chemical data of the process equipment • Ensure proper staffing for system operation • Directly supervise two (2) full-time operators and the Site Operations Manager |
| Project Chemist | Ewelina Mutkowska | <ul style="list-style-type: none"> • Ensure quality assurance/quality control (QA/QC) of analytical data • Manage hard copy and electronic data • Provide oversight and guidance for the subcontract laboratories through various QA/QC activities, including data review/validation and systems and performance auditing |
| Site Operations Manager | Mark Prostko | <ul style="list-style-type: none"> • Ensure that the extraction and treatment system is staffed with qualified personnel, and that the staff has proper support for health and safety, equipment, and resolution of problems • Ensure proper operational parameters for the system as determined by the Senior Engineer and the technical oversight team • Record daily activities of the team members, track project progress, coordinate the sampling of all effluent streams with TN&A, and communicate with the Senior Engineer and the technical oversight team |
| Site Sampling Manager | David Allen | <ul style="list-style-type: none"> • Record daily activities, coordinate all required sampling, and communicate activities to the Project Manager • Perform inspections of the process equipment and piping/equipment in the well field • Grant access for site visitors, conduct daily health and safety "tailgate" meetings with the site workers, and perform the health and safety overview with site visitors |

To perform O&M and to sample the groundwater and vapor treatment system, four (4) full-time employees are stationed at the Site. An organizational chart of the project team is provided as [Figure 1.4](#). Additional resources from TN&A's office in Ventura, CA are also utilized on an as-needed basis.

2.0 REMEDIAL ACTION

The remediation system for the Site is a semi-automated, vapor and groundwater extraction and treatment system that is designed to reduce the mass of VOCs present in soil and groundwater at the Site. Groundwater is extracted from the subsurface using down well pneumatic submersible pumps in the deep wells and “stingers” in the shallower perched zone wells. Thirty-three (33) total fluid pumps in the exposition aquifer and 23 DPE wells in the perched aquifer extract groundwater. SVE is conducted concurrently from 58 electrodes, 29 vapor recovery (VR) wells, and selected perched zone wells to remove contaminated soil vapor in the ERH area and perched groundwater zone (Figure 1.2 and Figure 1.3).

The remediation system separates the condensate from the extracted vapors and treats the removed condensate and groundwater using liquid-phase granular activated carbon (GAC) adsorption. The carbon adsorption vessels are operated in series prior to discharge of the groundwater to the sanitary sewer. The contaminated soil vapors are treated by a flameless thermal oxidizer (FTO) followed by vapor-phase GAC adsorption units. The vapors exiting the FTO are “conditioned” by removing excess heat and moisture content before entering the two (2) vapor phase GAC vessels, that are operated in series. Vapor extraction is conducted concurrently with groundwater extraction, but the vapor treatment system runs independently of the groundwater treatment system (Figures 2.1 and 2.2).

The remediation system is located within a steel frame building that sits atop a 4-inch high concrete containment berm and foundation (Figure 2.3).

The primary remedies that have been implemented at the Site include DPE, and thermally-enhanced DPE in the source area using ERH in which the subsurface is heated to the boiling temperature of water. Progress on the groundwater and soil vapor remediation is documented by the Quarterly Groundwater Monitoring Reports, on-going reports, and real-time website data for the ERH remediation. The operational phases of the remedial action are described in the following sections.

2.1 PHASE I – SYSTEM COMMISSIONING AND ESTABLISHMENT OF HYDRAULIC AND PNEUMATIC CONTROL

The first phase of active treatment involved the extraction of groundwater and vapors from the subsurface. All extraction, pipelines, valves, and controls were run through their operational routines. The treatment plant influent and effluent streams were measured and the desired removal efficiencies were confirmed. The treatment plant equipment was tested at full capacity to confirm full mechanical and electrical function as well as control sensitivity. The intent of Phase I was to test the equipment at full capacity of the vapor and liquid streams in the field; to identify health and safety issues; and to fix problems with controls, equipment, personnel, data gathering, communication, etc. This phase was also used to establish hydraulic and pneumatic control prior to commencement of ERH. Groundwater extraction and treatment began on April 25, 2007 and vapor extraction and treatment began on May 4, 2007.

2.2 PHASE II – ERH AND CONTINUED VAPOR AND GROUNDWATER EXTRACTION

Phase II of the remediation was signified by the application of full power to the electrodes on September 25, 2007. Phase II is a continuation of the vapor and groundwater extraction, with operational modifications to accommodate the ERH (source area remediation) program. The thermal aspect of Phase II entails the energizing of 58 electrodes. Thermal Remediation

Services, Inc. (TRS) is responsible for the operation, maintenance and performance of the ERH system.

The method for heating the soil at the site is ERH and is accomplished the installation of electrodes into the subsurface in the most contaminated part of the Site (approximately 14,000 square feet). Electrical current flows from one electrode to another and the soil, acting as a “resistor,” heats up. The reasons for heating the soil are 1) to greatly increase the rate of contaminant removal, and 2) to increase soil permeability in order to facilitate contaminant recovery from fine-grained soils. Because of the effectiveness of the heating, the ERH phase of remediation will be significantly shorter than the DPE phase, although some DPE will be operated during the thermal phase. Both DPE and ERH technologies will use the same extraction and treatment equipment.

Attainment of the first temperature goals in the temperature monitoring probes (TMPs) was forecast to occur after 73 days of ERH operation, however, at the time of the submission of the draft AOR, 120 days have passed since full power was applied to the electrodes. Ten percent of the thermocouple readings are validated by TN&A using hand-held instrumentation. Once all the temperature goals have been met simultaneously, the 30-day holding period will begin. If temperature goals are not met, heating will continue until the temperature goals are met. If the temperature goal is met prior to the estimated 73 days, the 30-day holding period will start as soon as the temperature data are validated. At the time of the submission of the draft AOR 2007, the ERH system had reached a temperature of 87.5 degrees Celsius (°C) in 81% of the TMPs.

During the holding period, temperatures cannot drop below the attainment goals. Data gathering and analysis during this phase will help to determine if the ERH portion of the remediation will move forward. The decision-making process of additional ERH is described below.

2.3 PHASE III – POST-ERH VAPOR AND GROUNDWATER EXTRACTION

Phase III will begin after cessation of the active thermal heating. The primary technology for Phase III is DPE, groundwater pump and treat, and SVE from groundwater wells that have gone dry. Many of the exposition A zone wells have dried up and present an excellent opportunity for residual contaminant recovery through SVE, as is currently being performed at wells DA-4, DA-5, DA-10, DA-11, and RW-01-70 ([Figure 1.2](#)). The operations, sampling and data collection, and management of the extraction and treatment system will change significantly because the ERH system and the FTO will not be in operation. In addition, a better understanding of the subsurface conditions from the system operation and data collection from Phases I and II will aid in the optimization of Phase III. Data specific to the operation of the ERH system will not be included in the Sampling and Analysis Plan (SAP) during Phase III.

Because the duration of this phase is estimated to be 5 years, the frequency of the data collection, and in some cases the types of data required, will be evaluated. Operation of the extraction system and treatment will be modified to allow for reduced man-hours, and a significant change in the project personnel. These reductions will be possible because the ERH and FTO systems will not be operated, and the expected concentrations in the vapor and liquid streams should be substantially lower than during Phase I and Phase II.

The operation of Phase III may also include biological augmentation, which will be reflected in a modified O&M plan and SAP to include the biological parameters.

3.0 VAPOR EXTRACTION AND TREATMENT

The soil vapor treatment system was installed to reduce VOC contamination, namely TCE contamination, within the source area. Soil vapors, extracted from 25 DPE perched wells, 33 exposition wells, and 28 VR wells ([Table 2.2](#) and [Figure 1.2](#)), are conveyed to the treatment plant. The vapor treatment system consists of an FTO and two (2) GAC vessels filled with 3,000 pounds of GAC installed in series for polishing purposes. The soil vapor extraction system began operation on May 4, 2007.

The flow rate of the vapors from all vapor extraction (VE) and DPE wells into the FTO is measured by flow element (FE) FE-101. The average flow rate in 2007 was 553 standard cubic feet per minute (scfm). A total of 176,696,475 standard cubic feet (scf) were treated by the vapor treatment system in 2007.

The VOC emission rates in 2007 were significantly lower than the discharge limit of 55 pounds per day allowed by the South Coast Air Quality Management District (SCAQMD). The analytical results showing compliance with the vapor discharge guidance documents are discussed in [Section 3.3](#) below. See [Section 9.1](#) for more information on the vapor discharge compliance.

Field data and vapor samples for laboratory analysis were collected on daily and weekly frequencies during 2007 to ensure efficient operation of the vapor treatment system. These data will be discussed in the following subsections.

3.1 WELL FIELD OPERATION AND MONITORING

Physical parameters were measured in the field at selected meters and gauges using prepared field sampling forms 7 and 12 (see [Table 3.1](#) and [Appendix 1](#)). Well valve operations are recorded on a weekly basis to determine the efficiency of the vapor extraction from each of the wells. The average vacuum, average photoionization detector (PID) concentration, and average temperature for each of the vapor extraction wells during 2007 are summarized in [Table 3.2](#). Perched wells PA-03 and PA-05 had the highest average PID concentrations in 2007 of 480.4 parts per million (ppm) and 976.5 ppm, respectively.

3.1.1 Perched Zone DPE Well Operation

DPE streams from the perched zone enter the treatment plant through the following four (4) headers: DPE-A, DPE-B, DPE-C, and DPE-D ([Table 3.3](#)). At the initiation of the DPE in May 2007, the perched zone water levels were at their highest levels on record and many well screens were submerged, rendering the down well stingers ineffective. The O&M crew overcame this problem by: 1) initially shortening all of the stingers and 2) venting the wells to allow air in and to enable water to be sucked out. Gradually, over a period of months, the stingers were lengthened to their design depths, which is 6 inches from the bottom of the DPE well. As is implied in [Table 3.3](#), average flow from the individual DPE wells exceeded the 10 scfm per well design goal (this average has not been confirmed on a well-by-well basis because the wells continue to produce water at a rate that exceeded the original predictions, i.e., that the perched zone would dry up).

Based on the PID measurements at the DPE headers, the most contaminant mass is being removed by DPE-A, followed by DPE-B, DPE-D and then lastly by DPE-C. As a result of the lowest PID concentrations, DPE-C was frequently turned off so that higher vacuum could be directed to the ERH area, fed by VE-3, to allow for higher flow.

Another O&M challenge common to many DPE networks is the accumulation of scale. Debilitating scale forms mainly in wells PB-1, PB-2, PD-4, PD-5, and PD-6. As a result, the O&M crew must clean the stingers and connecting pipelines using a high-pressure washer with a pipe cleaning spray head and a narrow gauge hose. The condensate sumps and pumps for headers DPE-B and DPE-D must be similarly cleaned to remove scale accumulation.

3.1.2 Exposition Zone and ERH Area Vapor Extraction Well Operation

Vapor extraction from the exposition zone and the ERH area enters the treatment plant through headers VE-1, VE-2, VE-3, and VE-4. During the initial three (3) months of vapor extraction, various vapor extraction scenarios were attempted with the exposition zone wells. In general, when the vacuum to the exposition zone wells was increased, the plant would receive an increased amount of fine-grained sediments that resulted in clogged filters and caused an inordinately high number of unplanned shutdowns. The operators experimented with varying mixes of vacuums and pumping rates; the resulting cost was high (in terms of unplanned shutdowns and increased labor) versus the benefit of slightly higher pumping rates. Since most of the exposition wells are located outside the source area, the estimated increase in the contaminant mass removed as a result of these exercises was minimal.

As a result of continued pumping, several A-zone wells have become mostly dry including DA-1, DA-2, DA-4, DA-5, DA-6, DA-9, DA-10, DA-11, and DA-12. These mostly-dry wells can now be used for vapor extraction without impacting the plant O&M. At the time of the submission of the draft AOR, wells DA-4, DA-5, DA-10, DA-11, and RW-01-70 are being used to facilitate vapor recovery from within and around the ERH area.

In [Table 3.3](#), the header measurements from VE-2 are representative of the ERH perimeter wells DA-4 and DA-5. Header VE-4 measurements are representative of the ERH area wells DA-10 and DA-11. The dry A-zone well RW-01-70 was plumbed into the ERH well extraction network, which joins all flow from the ERH area in header VE-3. The average flow rate from VE-3, located in the ERH area, appears to be lower than the average flow rate of the TRS condenser because VE-4 is occasionally used as a conduit for ERH area flow when the VE-3 condensate sump is full.

The vapor flow from the ERH area averaged 366 scfm (TRS condenser; [Table 3.3](#)). Despite increasing vacuum to the ERH area by shutting down other headers, flow did not increase significantly. Thus, the “current” extraction rate from the ERH area is considered to be maximized given the site geological conditions however, this condition may change as ERH progresses.

Field measurements were collected on a daily basis at the eight (8) influent headers to the vapor manifold (DPE-A, DPE-B, DPE-C, DPE-D, VE-1, VE-2, VE-3, VE-4), and the TRS condenser and were recorded on Form 1 that is provided in [Appendix 1](#). Averages of the field readings for all the manifold data collected in 2007 are summarized in [Table 3.3](#). Average flow rates from each of the manifolds were calculated using the differential pressures, vacuums, and temperatures recorded on Form 1 ([Table 3.1](#)).

3.2 TREATMENT PLANT OPERATION AND MONITORING

The purpose of the operational sampling, analysis, and measurement of physical parameters is to support optimization, maintenance, and operation of the vapor extraction and treatment system. Details on the field data collection are discussed in the Management and Operation and Maintenance Plan (MOMP; TN&A, 2007).

As part of the operation and monitoring of the vapor extraction and treatment system, influent and effluent vapor samples are collected at daily, weekly, and monthly frequencies for laboratory analyses in accordance with the SAP (TN&A, 2007). Additional samples are collected within the treatment compound to ensure efficiency of the remediation system. All vapor sampling ports are listed in [Table 3.4](#) and locations of the meters and gauges are presented in [Figures 2.1](#) and [2.2](#).

3.2.1 Sample Collection and Analysis Methods

In accordance with the SAP, the following samples are collected for laboratory analysis using sample collection techniques described in the SAP (TN&A, 2007):

| Analytes | Method | Sample Container | Laboratory |
|---------------------------------|----------|---|---|
| TCE & 2-6 Highest VOCs by TO-15 | TO-15 | Batch certified 400-milliliter (mL) Summa® canister | EPA Region 9 Laboratory |
| VOCs by TO-15 | TO-15 | Batch certified 400-mL Summa® canister | EPA Region 9 Laboratory |
| VOCs by TO-15SIM | TO-15SIM | Individually certified 6-L Summa® canister | Air Toxics Ltd. |
| C1-C6 TO-3(M) | TO-3(M) | Tedlar® Bag | Calscience Environmental Laboratories, Inc. |
| Dioxins and Furans | CARB 428 | Glass fiber filter, XAD 2 resin trap | Vista Analytical Laboratory |

Notes: CARB – California Air Resources Board; mL – milliliter; SIM – selective ion mode

Further details on the vapor sampling program are provided in [Table 3.4](#). All samples were shipped under appropriate chain of custody protocol to the laboratory with the exception of the samples analyzed by Calscience which are picked up on site by a courier.

All sample types were grab samples with the exception samples collected from SP-104a and SP-109a. Dioxin and furan samples collected from these ports were 4-hour composite samples and the TO-15SIM samples collected from these sample ports were 1-hour composite samples.

In addition to the regular samples collected as shown in [Table 3.4](#), a source test was completed by Almega Environmental and Technical Services from June 20 to 21, 2007 to demonstrate compliance with the EPA and SCAQMD emissions standards. Samples were collected from SP-102 (Pre-FTO), SP-103a (Post-FTO), SP-104a (Post-vapor conditioner), and SP-109a (Post-GAC). Samples were analyzed as follows:

| Parameter | Method | Station ID |
|--|--|---|
| VOCs | EPA TO-15 | SP-102, SP-104a, and SP-109a |
| Dioxins and furans | CARB 428 | SP-104a and SP-109a |
| Hydrochloric acid | CARB 421 | SP-104a, and SP-109a |
| Total VOCs as total gaseous non-methane organics | SCAQMD 25.1 SCAQMD 25.3 | SP-102 SP-104a and SP-109a |
| Nitrous oxides, oxygen and carbon dioxide | SCAQMD 100.1 | SP-104a and SP-109a |
| Carbon monoxide | SCAQMD 10.1 | SP-104a and SP-109a |
| Stack Sampling and Stack Gas Parameters | SCAQMD 1-4 CARB 421/428 SCAQMD 4.1 CARB 421/428 | SP-102 SP-104a SP-103a SP-109a |

The source test results are presented in [Appendix 4](#).

3.2.2 Process Vapor Analytical Results

Vapor samples are collected from the influent streams to the manifold (SP-110 through SP-117) on a weekly basis. These vapor samples are submitted for laboratory analysis of VOCs by method TO-15. Analytes that were commonly detected in the manifold samples during 2007 are shown in [Table 3.5](#). The most commonly detected analytes include TCE, toluene, n-hexane, cyclohexane, propylene, and *cis*-1,2-dichloroethene (*cis*-1,2-DCE). All positively detected analytes are shown in [Table A2.1](#) of [Appendix 2](#).

Vapor samples from SP-801 through SP-805 have been collected since the ERH began in September 2007 and analyzed for VOCs by TO-15 on a weekly basis. Concentrations of TCE ranged from 1.7 ppbv (for SP-804 on 11/20/07 and for SP-805 on 9/27/07) to 19,000 ppbv for SP-805 on November 20, 2007. Analytes that were commonly detected in the ERH zone samples during 2007 are shown in [Table 3.5](#). All positively detected analytes are shown in [Table A2.1](#) of [Appendix 2](#).

Vapor samples are collected from the combined vapor streams at SP-102 to determine the influent concentration to the FTO on a daily basis. All positively detected VOCs in the samples collected from SP-102 for TO-15 analysis are shown in [Table 3.6](#). The most commonly detected VOCs include TCE, toluene, n-hexane, cyclohexane, propylene, and *cis*-1,2-DCE. The concentration of TCE as a function of time is shown in [Graph 3.1](#) as well as the daily mass of TCE and VOCs removed. The concentration of TCE has shown a decreasing trend since the system startup in May 2007; however, the influent TCE concentration is expected to increase as the subsurface temperature increases from ERH. A similar trend is observed in the daily mass of VOCs removed.

In addition to the analytes detected by TO-15 that are listed in [Tables 3.5](#) and [3.6](#), tentatively identified compounds (TICs) such as dimethylbutanes, methylpentane, and methylcyclohexane are listed in [Table 3.7](#). Although significant concentrations of these compounds are detected, the results are still reported as estimated concentrations. For all TIC detections in vapor samples, see [Table A2.2](#) in [Appendix 2](#).

Vapor samples are also collected from SP-102 on a weekly basis for light hydrocarbon analysis by TO-3(M). The analytical results for samples collected from SP-102 for analysis by TO-3(M) are shown in [Table 3.8](#) along with the PID measurements that were collected in the field. Significant concentrations of methane (from 120 parts per million by volume [ppmv] on 10/1/07 to 5,200 ppmv on 6/20/07) and n-hexane (from 130 ppmv on 7/31/07 to 730 ppmv on 9/11/07 and 10/23/07) were detected in 2007.

To determine the FTO efficiency, a vapor sample is collected from SP-104 on a weekly basis. Vapor samples are also collected from SP-106 and SP-108 on a weekly basis to determine GAC efficiency and to facilitate O&M by predicting carbon breakthrough. Prior to discharge to the atmosphere, a vapor sample is collected from SP-109. All data obtained from these sample ports are used as screening-type data. Analytical data for the VOCs that were positively detected in the samples collected from the treatment plant are summarized in [Table 3.9](#). In addition, TICs that were detected in samples collected from SP-109 are listed in [Table 3.7](#).

Samples collected from SP-104 and SP-109 were analyzed by TO-15 and by TO-15SIM. The comparison of these results is shown in [Table 3.10](#). The reporting limits for TO-15SIM are much lower than those for TO-15, and thus, they are considered to be more accurate. In addition, the Summa[®] canisters used to collect the samples for analysis by TO-15SIM are individually certified and not batch certified such as those used for TO-15 analysis.

Samples were also collected from SP-104a and SP-109a twice per month for August and September and monthly thereafter through December 2007 for analysis of polychlorinated dibenzodioxins (PCDDs) and polychlorinated dibenzofurans (PCDFs) by CARB 428. The detected plant dioxin and furan emissions were used in a risk assessment model to show compliance with SCAQMD Rule 1401. This rule specifies limits for maximum individual cancer risk and non-cancer acute and chronic hazard index from new emission sources such as the FTO. The model showed that the risk associated with potential exposure to toxic air contaminants (TACs) at the treatment plant fence line, the nearest residence, and at the closest portion of the park are less than one-in-a-million. The model shows both acute and chronic hazardous indexes from potential exposure to non-cancer TACs at the three distances are less than 1 ([Appendix 4](#)).

The dioxin and furan National Emission Standard for Hazardous Air Pollutants (NESHAP) $2.00\text{E-}04$ μg toxic equivalent (TEQ)/ dry standard cubic meter (dscm) is used solely for the purpose of comparison ([Table 3.11](#)). This limit is not a regulatory standard for the Pemaco treatment plant. Total concentrations of dioxins and furans for SP-104a ranged from $4.38\text{E-}07$ $\mu\text{g}/\text{dscm}$ (12/12/07) to $2.04\text{E-}05$ $\mu\text{g}/\text{dscm}$ (8/16/07); total concentrations of dioxins and furans for SP-109a ranged from $4.68\text{E-}07$ $\mu\text{g}/\text{dscm}$ (8/16/07) to $1.83\text{E-}05$ $\mu\text{g}/\text{dscm}$ (6/20/07). All results were at least one (1) order of magnitude below the NESHAP limit of $2.00\text{E-}04$ $\mu\text{g}/\text{dscm}$ in 2007. The results for the dioxin and furan analyses are presented in [Table 3.11](#).

All laboratory reports are provided in [Appendix 4](#). A copy of the risk assessment model and results are included in [Appendices 4](#) and [5](#).

3.2.3 Quality Assurance / Quality Control Summary

Process vapor data are considered to be screening-type data and therefore field QC samples were not collected (see the SAP for further details [TN&A, 2007]). However, during operation of the system numerous volatile organic compounds were detected, and a trip blank sample labeled SP-900, was included with the weekly vapor samples that were shipped to the EPA Region 9 Laboratory for analysis by TO-15. Trip blanks are used to evaluate if the samples were contaminated by VOCs during shipment, handling, or storage on-site and in the laboratory. The positive detections of VOCs in these trip blank samples are summarized in [Table 3.12](#).

Due to the presence of VOCs, including common laboratory contaminants such as methylene chloride, acetone, 2-butanone, and cyclohexane, the concentrations of the specific trip blank VOC contaminants are used to determine if the analytical results of the samples associated with the particular batch require qualification.

Laboratory method blanks with positive VOC detections are currently being investigated. Due to the low concentration of VOCs in the method blank samples, the sample results are unlikely to be affected.

Laboratory QA/QC procedures were carried out according to EPA method specifications and the data was accepted based on the QA/QC criteria established by the EPA. All samples were shipped under appropriate chain of custody protocol at the method-specified temperature limit. All analyses were conducted within the specified holding time limit for each method.

3.2.4 Performance Evaluation Sampling

Performance evaluation samples were spiked by the EPA Region 9 QA/QC office using an XAD resin trap provided by Vista Analytical Laboratory. Two (2) air samples were collected on November 14, 2007; one was submitted to Vista Analytical Laboratory for analysis and the other

was submitted to Frontier Analytical Laboratory for analysis by CARB 428 under appropriate chain of custody protocol. Validated analytical results for are summarized in [Table A3.1](#) of [Appendix 3](#); lab reports and data validation reports are provided in [Appendix 4](#). The relative percent difference between PE samples ranged from 0% to 38.7%. Further evaluation of the PE samples was conducted by the EPA Region 9 QA/QC office. Preliminary results show that PE results for PCDDs and PCDFs were scored and all were within acceptance limits. The official report summarizing these results will be submitted to the EPA in the near future.

3.3 SYSTEM PERFORMANCE

Since the system start-up on May 4, 2007, a total of 176,696,475 scf soil vapor has been treated by the vapor treatment system. The total volume of vapor extracted from the subsurface is determined using the differential pressure from dPIT-101, the temperature from TIT-102, and the pressure from PT-101. The average flow rate of vapor extracted from the well field was 553 scfm.

In 2007, the average uptime was 74% (4,314 hours of operation); however, due to numerous improvements to the treatment system discussed in [Section 6.0](#) and as shown in [Table 6.1](#), the monthly uptime has increased significantly in September to 100% and has remained above 81% for the remainder of the year ([Table 3.13](#)).

From May through December 2007, approximately 12,736 pounds of vapor-phase VOCs were removed, and approximately 197 pounds of TCE have been removed from the subsurface at the Pemaco Superfund Site ([Table 3.13](#)). The average removal rates of VOCs and TCE in 2007 were approximately 56 pounds per day and 0.88 pounds per day, respectively.

The concentration of TCE, as well as the mass of TCE and VOCs that are removed as a function of time are shown in [Graph 3.1](#). The cumulative mass of total VOCs removed since the system startup as well as the total volume of vapor treated are shown in [Graph 3.2](#). The curve indicates that VOCs continue to be removed by the system, but at a declining rate, possibly due to mass transfer limitations as the subsurface contamination is removed and treated.

To demonstrate that the emission of the treated vapor to the ambient surroundings is in compliance with the SCAQMD guidance ([Appendix 5](#)), analytical results from the effluent stream are summarized in [Table 3.14](#). For further discussion of the guidance documents, see [Section 9.1](#). The VOC emission rates in 2007 were significantly lower (ranging from 3.10E-05 pounds per day on September 19, 2007 to 3.50E-03 pounds per day on September 5, 2007) than the discharge limit of 55 pounds per day allowed by the SCAQMD. The maximum emission limits for specific VOCs are listed in [Table 3.14](#). These limits are based on the results of the Tier 2 Screening Risk Assessment ([Appendix 5](#)). None of the individual limits were exceeded in 2007.

As described in [Section 3.2](#), the dioxin and furan concentrations in 2007 ranged from one (1) to three (3) orders of magnitude below the NESHAP limit of 2.00E-04 µg/dscm.

The destruction and removal efficiency (DRE) of the vapor treatment system is summarized in [Table 3.15](#). Since samples collected from SP-104a and SP-109a are only analyzed for VOCs by TO-15SIM, DREs for light hydrocarbons, and TICs could not be calculated. As a result of the method limitation, the total VOC DREs are biased high. The DRE of total VOCs ranged from 99.9922 % on September 5, 2007 to 99.9999% on September 18, 2007 and October 4, 2007. Since the detection limits are lower for TO-15SIM than for TO-15, and the influent samples were analyzed by TO-15 and the post-FTO and post-GAC samples were analyzed by TO-15SIM, some analytes were positively detected in the post-FTO and post-GAC samples that were not

detected in the influent sample. As a result of the analysis method discrepancy, some individual DREs could not be calculated. The lowest individual DRE was 87.8788 % for acetone on September 5, 2007, which is a common lab contaminant. All other individual DREs were greater than 98.9286 %.

Vapor-phase GAC has not needed replacement in 2007 due to the very low loading it receives since the vapors have already passed through the FTO prior to entering the GAC vessels. Details on the GAC requirements and disposal are discussed in [Sections 8.0](#) and [10.0](#).

4.0 GROUNDWATER EXTRACTION AND TREATMENT

The groundwater treatment system was designed to provide hydraulic containment of the dissolved groundwater plumes and to capture and treat contaminant mass. The groundwater extraction wells that were in operation during 2007 are listed in [Table 4.1](#). The locations of the 24 DPE wells are illustrated in [Figure 1.2](#).

The extracted groundwater is conveyed to the treatment compound where it passes through two (2), 3,000 pound liquid-phase GAC vessels in series to remove VOCs from the groundwater. A carbon life evaluation was performed on April 25, 2007 to determine the service life of the carbon to ensure adequate change-outs (see [Sections 8.0](#) and [10.0](#) for more details on carbon change-outs and [Appendix 4](#) for Calscience's laboratory report). The groundwater is finally discharged into the sanitary sewer (see [Section 9.2](#) for more details on the sewer discharge permit). During 2007, a total of 11,460,978 gallons of groundwater were extracted at an average flow rate of 31 gallons per minute (gpm).

The VOC discharge rate in 2007 was significantly lower than the discharge limit of 1,000 µg/L allowed by the SDLAC.

Field data and groundwater samples for laboratory analysis were collected on daily and weekly schedules during 2007 to ensure the effective performance of the groundwater treatment system. These data will be discussed in the following subsections.

4.1 WELL FIELD OPERATION AND MONITORING

A list of the 33 exposition wells equipped with dedicated QED Environmental pumps is provided in [Table 4.1](#). Groundwater will be continuously extracted for the duration of the remediation process, which is anticipated to take 5 years. However, since the start of the groundwater extraction activities, several wells in the exposition A zone have become dry; namely DA-1, DA-2, DA-4, DA-5, DA-6, DA-8, DA-9, DA-10, DA-11, and DA-12. Exposition B zone wells DB-7 and DB-8 are also mostly dry.

The pumping rates for each of the groundwater extraction wells are calculated using pulse counters located at each of the wells. For each click, an assumed volume of 0.65 gallons of water is pumped. Data from the pulse counters are collected on a weekly basis using Form 13 (see [Table 3.1](#)). The minimum, maximum, and average pumping rates for each well and corresponding manifold are shown in [Table 4.1](#). The average air regulator pressures at each extraction well are also listed in [Table 4.1](#). The average flow rates ranged from 1 gallon per day in DA-8 and DA-9 to 7,572 gallons per day in MW-24-110.

4.2 TREATMENT PLANT OPERATION AND MONITORING

The purpose of the operational sampling, analysis, and measurements of physical parameters is to support optimization, maintenance, and operation of groundwater extraction and treatment system. Details on the field data collection are discussed in MOMP (TN&A, 2007).

As part of the operation and monitoring of the groundwater extraction and treatment system, influent and effluent water samples are collected on a weekly basis for laboratory analyses in accordance with the SAP (TN&A, 2007). Additional samples are collected within the treatment compound to ensure efficiency of the remediation system. The groundwater sampling ports are listed in [Table 4.2](#) and the locations of the meters and gauges are presented in [Figure 2.1](#) and [Figure 2.2](#).

4.2.1 Sample Collection and Analysis Methods

In accordance with the SAP, the following samples are collected for laboratory analysis using the sample collection techniques described in the SAP:

| Analytes | Method | Sample Container | Laboratory |
|----------------------------|-----------|---|------------|
| VOCs + 1,4-dioxane, hexane | EPA 8260B | Three (3) 40-mL VOAs | Calscience |
| 1,4-dioxane | EPA 8270C | 1-liter amber bottle with sodium thiosulfate or unpreserved | Calscience |

Notes: VOAs – volatile organic analysis vials

Glass VOAs with Teflon[®]-lined septums are used for sampling groundwater for VOCs. The sample vials are filled completely so the water forms a convex meniscus at the top and then Teflon[™]-lined cap is screwed on tightly to ensure no air space (i.e., bubbles) is present in the vial and to prevent the container from leaking.

Effluent samples from the treatment system are collected every three (3) months to evaluate compliance with the Self-Monitoring Requirements Permit No. 16961 issued by the SDLAC. In accordance with the permit, grab effluent water samples are collected at sampling port SP-209 ([Figure 2.1](#)). For unstable parameters such as chemical oxygen demand (COD), TSS, and lead, 24-hour composite samples are collected using an automatic sampler that collects uniform aliquots of groundwater over the programmed time to attain the desired analysis volume. Analytical requirements for water samples collected at SP-209 are summarized in [Table 4.6](#).

The effluent groundwater stream is sampled for the following parameters:

- SOM01.1 or SW 8260B for VOCs,
- SOM01.1 or SW 8270C for semivolatile organic compounds (SVOCs),
- EPA 160.2 for Total Suspended Solids (TSS),
- EPA 410.4 for Chemical Oxygen Demand (COD),
- SW 6010B for lead,
- EPA 376.2 for dissolved sulfide, and
- EPA 5520B for oil and grease.

All groundwater samples are picked up on site by a courier from Calscience Environmental Laboratories, Inc.

4.2.2 Process Water Analytical Results

Groundwater samples are collected from the influent streams, GW-1, GW-2, and GW-3, to the manifold (SP-213 through SP-215) on a weekly basis. These samples are submitted for laboratory analysis of VOCs by EPA 8260B. Analytes that were positively detected in the manifold samples during 2007 are shown in [Table 4.3](#).

The extracted groundwater was treated for VOCs using GAC as described in [Section 4.0](#). Samples were collected and analyzed for VOCs by EPA 8260B and for 1,4-dioxane by EPA 8270C, from the following locations on a weekly basis: SP-201, SP-210, SP-212, SP-204, SP-

206, SP-208, SP-210, and SP-212 ([Table 4.6](#)). General diagrams of the GAC vessels, including the sample port locations, are provided in [Figures 2.1](#) and [2.2](#).

All positively detected VOCs in the samples collected from sampling ports located in the plant EPA 8260B analysis are shown in [Table 4.4](#). The most commonly detected VOCs include TCE, toluene, chloroform, and *cis*-1,2-DCE. The concentration of TCE as a function of time is shown in [Graph 4.1](#) as well as the daily mass of TCE and VOCs removed. The concentration of TCE has shown a decreasing trend since the system start-up in April 2007; however, the influent TCE concentration is expected to increase as the subsurface temperature increases with ERH. A similar trend is observed in the daily mass of VOCs removed.

All laboratory reports are provided in [Appendix 4](#).

4.2.3 Quality Assurance / Quality Control Summary

System performance data are considered to be screening-type data and therefore no field QC samples were collected.

Laboratory method blanks with positive VOC detections are currently being investigated. Due to the low concentration of VOCs in the method blank samples, the sample results are unlikely to be affected.

Laboratory QA/QC procedures were carried out according to EPA method specifications and the data was accepted based on the QA/QC criteria established by the EPA. All samples were shipped under appropriate chain of custody protocol at the method-specified temperature limit. All analyses were conducted within the specified holding time limit for each method.

4.2.4 Performance Evaluation Sampling

Performance evaluation samples were also collected using low and high spiked vials prepared by the EPA Region 9 QA/QC office. These samples were submitted to Calscience Environmental Laboratories, Inc. under appropriate chain of custody protocol on November 30, 2007 for analysis of 1,4-dioxane by SW 8270C. Evaluation of the PE samples was conducted by the EPA Region 9 QA/QC Office. Preliminary results show that PE results for 1,4-dioxane were scored and both were within acceptance limits (see [Table A3.2](#) in [Appendix 3](#) for the results). The official report summarizing these results will be submitted to the EPA in the near future.

4.3 SYSTEM PERFORMANCE

Since the system start-up on April 25, 2007, a total of 11,460,978 gallons of contaminated groundwater has been treated by the groundwater treatment system. The average flow rate was 31 gpm in 2007.

In 2007, the average uptime was 94% (5,667 hours of operation) as shown in [Table 4.5](#). The groundwater treatment system was offline due to GAC vessel repair in June 2007 and due to air compressor maintenance in September 2007.

From April through December 2007, approximately 47.1 pounds of VOCs including TCE have been removed and approximately 26.2 pounds of TCE have been removed from the subsurface at the Pemaco Superfund Site ([Table 4.5](#)). The average removal rate of VOCs and of TCE in 2007 were approximately 0.14 pounds per day and 0.08 pounds per day, respectively.

The concentration of TCE as well as the mass of TCE and VOCs that are removed as a function of time, are shown in [Graph 4.1](#). The cumulative mass of total VOCs removed since the system startup as well as the total volume of vapor treated are shown in [Graph 4.2](#). The curve indicates

that VOCs continue to be removed by the system, but at a declining rate, possibly due to mass transfer limitations as the subsurface contamination is removed and treated.

To demonstrate that the discharge of the treated groundwater to the public sanitary sewer is in compliance with the SDLAC's sewer discharge permit, analytical results from the effluent stream are summarized in [Table 4.6](#). The concentration limits on individual VOCs are not exceeded, nor are any of the limits for the additional analytes (SVOCs and general chemistry parameters). The total VOC concentration is calculated using individual VOC concentrations that are greater than 10 µg/L. The only VOCs detected include bromodichloromethane, bromoform, chloroform, dibromochloromethane. The only SVOC that was detected was bis(2-ethylhexyl) phthalate on November 20, 2007. The VOC discharge rate in 2007 ranged from below the reporting limit of 1 µg/L on April 25, 2007 and on November 20, 2007 to 90 µg/L on August 23, 2007 which is significantly lower than the discharge limit of 1,000 µg/L allowed by the SDLAC. For further discussion of the sewer discharge permit, see [Section 9.2](#).

The destruction and removal efficiency (DRE) of the groundwater treatment system is summarized in [Table 4.7](#). The DRE of total VOCs ranged from 87 % on August 23, 2007 to 100% on April 25, 2007. Bromodichloromethane, bromoform, and dibromochloromethane were detected in the post-GAC sample on August 23, 2007 at concentrations that were higher than the influent concentrations and therefore the DREs for these compounds were not calculated. The lowest individual DRE was 51.6 % for chloroform on September 5, 2007. All other individual DREs for the VOCs were 100 %.

Since samples collected from SP-209 were not analyzed for 1,4-dioxane, the 1,4-dioxane concentrations that are reported in [Table 4.7](#) were taken from sample port located after the secondary GAC vessel (SP-208 on 4/25/07 and 8/23/07; and SP-206 on 11/20/07). The DREs for 1,4-dioxane on April 25, 2007 and August 23, 2007 were 100.0% and 62.6%, respectively. A DRE could not be calculated for 1,4-dioxane on 11/20/07 since the concentration in SP-206 was greater than the total influent concentration.

Liquid-phase GAC was replaced twice in 2007 in each of the GAC vessels T-403 and T-404 as shown in [Table 10.1](#). Details on the GAC requirements and disposal are discussed in [Sections 8.0](#) and [10.0](#). Carbon efficiency, calculated as the pounds of contaminants removed divided by the pounds of carbon used times 100%, was calculated at less than 1% for 2007. The low carbon efficiency can be attributed to the premature change-outs necessitated by the clogging of fine soil particles and bio-growth.

5.0 TREATMENT SYSTEM CONTROLS

The Pemaco Superfund Site treatment system is designed for continuous semi-automatic operation, while minimizing the occurrence of alarm conditions. The treatment system is equipped with control devices to detect alarm conditions as they develop and to shut down the system until the alarms are acknowledged and cleared. The treatment system uses a system main computer (SMC) equipped with programming software for the programmable logic controller (PLC) and the SMC. The operation of the treatment system always ensures the safety of the operating personnel and the public as well as the protection of the equipment and the environment.

5.1 CONTROL SYSTEM

The remediation system is controlled and monitored by the SMC located in the treatment plant control room ([Figure 2.3](#)). The SMC provides an interface between the equipment and the operator which allows the operator to start, stop, reset, change set points, view alarms, and monitor the system. By using the mouse and the keyboard, the operator can navigate through various screens and perform system operations as shown in [Figure 5.1](#).

The SMC communicates via an Ethernet network to the main control panel (MCP) PLC. The MCP PLC monitors and controls the physical inputs and outputs (e.g. level switches and turn on motors) of the system and holds all the information that controls the system. The logic path for the instrumentation and control system is illustrated in [Figures 2.1](#) and [2.2](#).

The SMC is configured to data log all process analog signals at 1-minute intervals and also to monitor the trend of all the analog channels of the treatment system. The system control and data acquisition (SCADA) system has a built-in auto dialer that will phone or e-mail selected personnel when any alarm occurs.

The control system is fitted with an uninterruptible power supply (UPS) that will give the PLC and SMC approximately 1 hour of run time in the event of a power failure. This control allows the system to autodial the necessary personnel to inform them that the system went offline.

The system computer can be accessed over the internet using a “virtual network connection” or a Windows remote desktop connection. Connecting to the SMC using either of these methods will allow the user to have full access to the computer as if they were at the console.

5.2 PLC AND SMC SOFTWARE

The remediation system comes complete with a licensed copy of programming software for the system PLC and the SMC. All software is preloaded on the computer and the CD version is located in the control room. All programming software is a product of Rockwell Automation.

The PLC software allows for modifications to the existing program. The PLC software consists of the following two (2) components:

- RSLogix 5000 Mini, ENU, Revision 15.02.00
- RSLogix 5000 MLP, Revision 15.02.00

The SMC software allows for modifications to the existing display program, the data logging feature, and the autodialing feature. The SMC software consists of the following three (3) components:

- RSView32 Messenger Pro (autodialer), Revision: 2.12.00
- RSView32 Works 150, Revision: 7.20.00
- RSLinx Professional, Revision: 2.50.00

5.3 SYSTEM ALARM OVERVIEW

The system is designed to sound specific alarms to ensure the process and components are operating within the specified limits. There are several types of alarms that trigger specific system responses. A list of each of these alarms along with the associated system responses is presented in the CCR as Table 3.5.3 (TN&A, 2007). For activities that were performed to limit the number of alarms, see [Section 6.0](#).

All alarms that occur must be acknowledged and reset before the alarm condition is cleared from the system. All alarms should be investigated to determine the reason for the occurrence. The alarm history is automatically logged to an alarm log file on a monthly basis. The computer is configured with a user name and password to prevent unauthorized access. Currently, TN&A employs three (3) full-time operators to ensure efficient and safe operation of the treatment system.

6.0 TREATMENT SYSTEM OPTIMIZATION & MAINTENANCE

After the initial 30-day shakedown conducted by Jacob & Hefner Associates (J&H) under the direction of Environmental Resources Management, Inc. (ERM), TN&A took over the operation of the treatment system and began troubleshooting the system. The shakedown period focused mostly on leaks, instruments, PLC controls, FTO start-up, and completing the as-built drawings. After the 30-day period, TN&A began to optimize system operation and to identify problems that impacted the operation of the FTO. Because the FTO is the critical component for vapor treatment at the Site, remedial action could not progress until the uptime for the vapor treatment system was improved ([Table 3.13](#)).

Issues with the treatment system addressed by TN&A as well as the optimization and problem remedies that were implemented are discussed below:

- Excessive sediment in the pumped groundwater caused numerous high-level shutdowns of the treatment plant due to the high pressure buildup in the bag filter system. Changing the filter to a larger size resulted in sediment buildup in the liquid-phase GAC. This problem was solved by switching to a dual-walled high efficiency filter bag and eliminating vacuum applied to the non-dry exposition wells.
- Algae buildup in the holding tanks and piping network led to the clogging of the bag filters, and thus, the shutdown of the treatment plant. A chemical maintenance plan was implemented, and an automated chlorine feed system was designed and installed to reduce the algae buildup.
- Excess heat in the FTO was caused by slug flow and/or vacuum in the header system. A modification to the DPE condensate sumps was implemented which involved the installation of four (4) pneumatic pumps with level controls. By keeping the level of water in the DPE condensate pumps low, a more even flow of air and improved uptime for the FTO were achieved.
- Sediment buildup in downhole pumps caused pump shutdown. Seven (7) pumps were pulled, valves were replaced, and the pumps were set several feet higher in the well.
- Tank T-101 collapsed during testing because it could not withstand full vacuum. TN&A specified that the tank needed to be operational at approximately 29 inches of mercury of vacuum. This tank was covered by warranty, and a replacement tank was ordered by ERM. The replacement tank showed signs of stress under operation, and was modified by welding a steel “belt” around the tank (among other welding) for reinforcement.
- While emptying the liquid GAC tanks T-403 and T-404, the fitting attaching the screen/filter to the tank side wall sheared-off under its own weight and the weight of the carbon at the point where it connects to the tank side wall. The shear point was caused by the cantilevered screen section with no under-support. The fittings were Schedule 40, not Schedule 80, as shown in the tank design drawing (see J&H's Draft O&M Manual, 2007). The broken Schedule 40 fittings were repaired and replaced with Schedule 80 fittings.
- The Dekker Liquid Ring pumps, B-101 and B-102, continued oil blow-by to the FTO. This issue incurred FTO high temperature alarms and caused the vapor treatment system to shutdown. As a remedy, six (6) oil scavenge/return lines were installed from F-103/104 oil mist filters, and several locations downstream of the oil mist filters, to return oil to the

vacuum pumps. A leaking Dekker filter was replaced and additional filter inserts were installed in F-103/104 to remedy the oil issue.

- The potable water booster pump variable frequency drive and the P-402 variable frequency drive were reporting high voltage errors that are believed to have been caused by Southern California Edison, Inc. voltage spikes. The errors would occasionally shut down these pumps without notice, sometimes causing a plant shutdown. To attenuate the voltage spikes, line reactors were installed at both locations, thereby eliminating the high voltage errors.
- Groundwater tank high or low level alarms would shut off the air compressor, rendering the double diaphragm pumps for the vapor treatment system inoperable. A stand-alone compressed air line from the air compressor tank to the double-diaphragm pumps was installed to keep the double-diaphragm pumps operating after the groundwater treatment system shuts down (e.g. during GW tank High-High alarm).
- An unidentified T-402 High-High alarm occurred during operation causing the groundwater treatment system to shutdown. By raising the LSHH-402 High Level on T-402, the issue was remedied. This remedy also created additional tank holding capacity.
- Anguil Environmental Systems, Inc. was initially tasked, on two occasions, to inspect and to optimize the gas control valve settings, the burner temperature, the check influent vapor pressure alarms. They also adjusted the quench chamber spray nozzles, replaced the quench chamber insulation and repaired a weld. To facilitate FTO operation, TN&A installed a barometric damper, a vacuum gauge, and a pressure shut-off switch. A PLC interlock was added and various other PLC programming improvements to allow the FTO to operate in tandem with the vapor conditioning package.
- Numerous adjustments to all the level controls and alarm switches for all tanks, vessels and motors in the treatment plant were made. All programming was performed by Aspect Electrical Engineering & Service LLC's lead programmer, Mike Ebner, who worked with the TN&A engineers and operators.
- Oversized sheaves on the Dekker Liquid Ring Pumps B-101 and B-102 caused the two blower motors to run at a higher-than-specified ampacity. The high ampacity caused excess heat in the liquid ring vacuum pump electrical panel, necessitating the replacement of the motor overload protection models, some wiring, and the addition of a panel fan. Dekker did not catch the oversize sheave during QA/QC at the assembly shop. The oversized sheaves (10 7/8 inches) were replaced with new sheaves (9 3/4 inches).
- The FTO bellows insulation failed resulting in a hot spot and several days of FTO downtime. The insulation was worn away by a misdirected quench chamber spray nozzle. The insulation was repaired with a more rigid variation, which also failed after several weeks of operation. The second failure was patched in one day and that patch is currently performing well. Additional insulation upgrades are recommended during the next planned shutdown.

To improve the sustainability of the treatment system operation and to meet EPA's sustainability goals, solar panels were installed providing total of 2,949 kWh of energy in 2007 for an average of 16.2 kWh per day.

A summary of the treatment system optimization & maintenance activities including the changes that were made to the original design to address the aforementioned problems are described in [Table 6.1](#). In addition to the major maintenance and optimization that was performed, daily and weekly maintenance activities performed at the Site are described in [Table 6.2](#). The equipment maintenance schedule and the FTO maintenance schedule are provided as [Tables 6.3](#) and [6.4](#), respectively.

7.0 DATA MANAGEMENT

All field and analytical data collected at the Site will be stored permanently in TN&A's Environmental Data Management System (EDMS), a comprehensive Sequel Server database (SQL) hosted on the company intranet behind a secure firewall. Stored data can be exported out of the EDMS in a variety of formats, including Microsoft Access databases, Microsoft Excel spreadsheets, delimited text files, dBASE files, and others. The format and structure of these files can be customized to meet the export requirements for nomenclature, data structure, and file size. Exported files can be transferred via e-mail, FTP protocol, written to CD or DVD, or other by using means depending upon the final size of the file(s). Integrity of the data stored in EDMS is maintained through software access permissions.

For the purposes related to the database, the collected data will be classified as either manually recorded or electronically recorded. Standard procedures for entering the data into the database have been developed for each classification of data. Data that were manually recorded by field personnel on forms listed in [Table 3.1](#) were hand-entered into a pre-formatted electronic spreadsheet. The electronic spreadsheet is imported into the database using a standard query.

Electronically recorded data includes all data that are automatically recorded by sensors, that are recorded on laboratory equipment or that are output by another database and stored electronically. These data are then saved and transferred as an electronic file or an electronic data deliverable (EDD). Sources of EDDs can include, but are not limited to sub-contractors, (such as analytical laboratories) and data loggers.

The remedial system will be managed via a password-controlled website accessible to the entire project team. The full data management cycle in which data generated as either EDDs or as manually entered readings are imported the EDMS, and are then selectively mirrored to a web database from where the data can be dynamically accessed via specialized interfaces, as shown in [Figure 7.1](#). Further information on the project website is discussed in [Section 11.1](#).

8.0 RESOURCES AND UTILITIES

The resources (consumable materials including potable water, granular activated carbon, filter bags, salt, and caustic solution) and utilities (natural gas, electric power, and solar power) required for the O&M activities in 2007 are summarized in [Table 8.1](#). Monthly usage records are based on the monthly bills or on field readings. Since the startup of the treatment system March 2007, the system has consumed 4,462 thousand gallons of potable water, 59,082 cubic feet of natural gas, 893,764 kWh of electric power, and 2,949 kWh of solar power.

Potable water is supplied to the treatment building from a water meter installed by Maywood Mutual Water Company. Potable water is provided as make-up water for the FTO scrubber, cooling water for the vapor conditioning package, and for other needs.

Natural gas is supplied to the treatment building from a gas meter installed by Southern California Gas Company. Natural gas is provided as supplemental fuel for the FTO. The gas meter is used to record the natural gas consumption of the FTO.

The power service, 480-volt, 800-amperes three phase, is provided by Southern California Edison, Inc. Electricity is obtained from the park transformer and metering cabinet located west of the treatment building.

The number of filter bags used and the carbon change-outs that occurred in 2007 are tracked and shown in [Table 10.1](#). A total of 12,000 pounds of carbon was used in 2007 from the two (2) change-outs at T-403 and the two (2) change-outs at T-404.

As a result of the operation and maintenance of the treatment systems, consumable and disposable materials are generated as summarized in [Table 8.1](#). All waste generated as a result of the treatment system operation is handled, transported and disposed of in accordance with TN&A's Waste Management Plan (2007). Waste management is discussed in [Section 10.0](#) of this report.

9.0 PERMITTING, COMPLIANCE, AND ENVIRONMENTAL PROTECTION

The following documents have been prepared by TN&A to provide the framework for addressing potential environmental releases as a result of the operation of the treatment system:

- Environmental Protection Plan (EPP; TN&A, 2007)
- Waste Management Plan (WMP; TN&A, 2007)
- Emergency Response Actions (TN&A, 2007)

These plans are all part of an integrated approach for the management, operation and maintenance of the Pemaco remedial action. In addition, the ability to easily access operation and sampling data via the project team web site will facilitate treatment system optimization, and enable the project managers and operators to immediately respond to permit excursions.

Compliance monitoring for Pemaco RA includes vapor effluent monitoring in accordance with SCAQMD protocol and water effluent monitoring in accordance with SDLAC permit.

9.1 VAPOR DISCHARGE GUIDANCE

Emission standards and requirements for the vapor treatment system effluent are based on health risk analyses by the SCAQMD as part of the EPA's goal of meeting the substantive requirements of the air permitting process. The FTO system, used for the destruction of VOCs at the Pemaco Site, meets and exceeds the SCAQMD effluent requirements (see [Sections 3.2 and 3.3](#)). Analytical results showing compliance with the vapor guidance documents are presented in [Table 3.14](#).

EPA has a policy that CERCLA response actions are exempted by law from the requirement to obtain Federal, State or local permits related to any activities conducted on the CERCLA site (OSWER Directive 9355.7-03). It also is EPA's policy to assure all activities conducted on sites are protective of human health and the environment. Therefore, the EPA coordinated and consulted with SCAQMD to assure compliance with the Risk Assessment Procedures for Rules 1401 and 212.

For a remediation project involving a FTO in the South Coast Basin, the applicable rules are those that fall under Regulation IV and Rules 1303 and 1304 under Regulation XIII. Rule 1166, which applies to all VOC-contaminated soil handling, is also relevant. Rule 1303 under Regulation XIII pertains to Best Available Control Technology (BACT). These guidelines indicate that FTOs (or "afterburners" as they are referred to in permit documents), which is the BACT for VOCs, are required to operate with a residence time greater than or equal to 0.3 seconds at a temperature greater than or equal to 1,400 degrees Fahrenheit (°F). The FTO far exceeds this requirement. The BACT for NO_x, SO_x, and PM₁₀ is natural gas usage. For this particular project, NO_x, SO_x, carbon monoxide (CO), and PM₁₀ emissions are exempted from offset requirements based on R134(c)(4). Only VOC emissions are subject to this Rule and, therefore, should not exceed the 55 pounds per day or 4 tons/year threshold at the current rate of VOC emission. In 2007, a maximum emission rate of 3.50E-03 pounds of VOCs per day (9/5/07) was calculated for the treatment system. As described in [Section 3.2](#), the dioxin and furan concentrations in 2007 ranged from one (1) to three (3) orders of magnitude below the NESHAP limit of 2.00E-04 µg/dscm.

The SCAQMD is responsible for issuing air permits that typically govern all vapor treatment equipment emissions. The air permits are issued, and required monitoring levels are prescribed based on the overall human health risk posed by the combined emissions of all contaminants in the vapor stream. Vapor guidance information is provided in [Appendix 5](#). The procedures for determining human health risks from air emissions sources are outlined in the SCAQMD Risk Assessment Procedures for Rules 1401 and 212. To comply with Rules 1401 and 212, the human health risk from the emission source must be less than that rate calculated to cause cancer in 1 person out of 100,000; or a cancer risk of 1E-05. Calculated hazard indices must also be less than 1.

A Tier 2 Screening Risk Assessment Model was used to calculate risk from the highest concentrations of dioxin/furan and VOCs measured at the treatment plant stack during the source testing on July 12, 2007. The Tier 2 Risk Assessment is a standard numerical model used to determine exposure and risk from an emission source, in accordance with SCAQMD Rules 1401 and 212. The model calculates health risks according to the probability that a person will contract cancer due to inhalation of TACs in vapor effluents. The following assumptions were used to calculate the risk at 60, 75, and 125 meters from the stack:

- The highest concentrations of dioxins and VOCs measured at the stack during the source testing on 7/12/07;
- The point source is from treatment equipment operating 24 hour per day, 7 days of the week;
- The source is from a stack with a height of greater than 24 feet and less than 49 feet;
- A daily breathing rate of 302 liters/kilogram-day; and
- SCAQMD listed dispersion factors for calculating the annual average 24 hours per day TAC concentrations in air.

An acceptable level of cancer risk is considered to be one in 100,000 according to the SCAQMD however, the EPA has established an acceptable level of cancer risk to be one in a 1,000,000. The results of the risk assessment are shown below:

| VOCs and Dioxins/Furans Exposure Scenarios | Fence Property Line | Nearest Receptor | Park Property Line |
|---|----------------------------|-------------------------|---------------------------|
| Distance from Stack: | 60 meters | 75 meters | 125 meters |
| Total Maximum Individual Cancer Risk | 4.06E-08 | 2.02E-08 | 1.70E-08 |
| Total Chronic Hazard Index | 2.34E-05 | 1.16E-05 | 9.79E-06 |
| Total Acute Hazard Index | 1.20E-09 | 6.48E-10 | 5.46E-10 |

As shown in the table above, the risk associated with potential exposure to TACs at the three distances are less than one-in-a-million. Both acute and chronic hazardous indexes from potential exposure to non-cancer TACs at the three distances are less than 1. The treatment system emissions are 47 to 427 times lower than would be allowable under the NESHAP program. NESHAP's standard for dioxin and furans is 2.00E-04 µg/dscm.

9.2 SEWER DISCHARGE PERMIT

To evaluate compliance with the sewer discharge permit, grab samples are collected and preserved from SP-209 once per three (3) months in accordance with 40 CFR 136 and analyzed by a laboratory that is certified by either the District or the State Department of Health

Services. Samples are analyzed for the following parameters: COD, suspended solids, pH, dissolved sulfide, lead, oil and grease, and VOCs. For unstable parameters such as COD, TSS, and lead 24-hr composite samples are required by the permit. The total wastewater flow rate and peak wastewater flow rate must also be included on the self-monitoring form provided in [Appendix 5](#). The self-monitoring form is a requirement of the sewer discharge permit number 16961) issued by the SDLAC Industrial Waste Section located in Whittier, CA.

The emission limits of VOCs and SVOCs are calculated by adding the concentrations of the organics that are individually present at concentrations greater than 10 ug/L (see [Table 4.6](#)). Analytical results for water effluent samples collected at SP-209 are summarized in [Table 4.6](#).

The current operating scenario indicates that discharge will be kept, on average; two orders of magnitude below the sewer permit discharge limits for VOCs which is 1,000 µg/L. County Sanitation District No. 2 of Los Angeles County, Industrial Waste Section sampling requirements are performed in accordance with the sewer discharge permit.

The Pemaco treatment plant discharges were within the permit requirements. VOC discharges were two (2) to three (3) orders of magnitude less than the discharge limit of 1,000 µg/L in 2007 as discussed in [Section 4.2](#). Quarterly sewer discharge summaries are sent to the EPA for report preparation purposes. Copies of these summaries are included in [Appendix 6](#).

.

10.0 WASTE MANAGEMENT

The operation of the extraction and treatment system generates general solid wastes and potentially hazardous wastes. During operation, TN&A and its subcontractors are responsible for managing California-, CERLA-, and Resource Conservation and Recovery Act- (RCRA)-regulated wastes in accordance with procedures outlined in the WMP. The WMP describes the waste management activities and procedures that are used to handle waste disposal. TN&A conducts a waste management assessment to document that waste activities are in compliance with site procedures and California, CERCLA, and RCRA regulations.

TN&A is responsible for oversight of the waste management activities to ensure compliance with all requirements for regulated wastes. TN&A is also responsible for approving the waste disposal contractor acquisition, costs or waste disposal, and determining of the type of analytical testing needed for disposal of the waste.

The EPA is responsible for receiving ownership of regulated wastes and signing for EPA applicable paperwork and analytical results to facilitate compliance with off-site shipping and disposal. Copies of all manifests and disposal information is provided in [Appendix 6](#).

10.1 EXAMPLES OF WASTE STREAMS

The following types of potentially hazardous waste are generated from the operation and maintenance of the treatment system:

- Spent carbon from vapor and water treatment;
- Bag filters from the liquid process line;
- Partially-filled and empty containers of oil used for maintenance;
- Paint cans and aerosol spray cans; and
- Absorbent pads used for cleaning up small leaks and spills.

The following types of general waste are generated from the operation and maintenance of the treatment system:

- Trash and rubbish generated by site housekeeping;
- Used personal protective equipment (PPE);
- Disposable sampling equipment;
- Metal and plastic pipe, electrical materials (wire, etc.); and
- Miscellaneous wastes (trash, food containers, etc.).

Wastes are segregated into regulated and non-regulated streams to minimize generation and disposal of hazardous waste and material.

10.2 WASTE MANIFESTS AND DISPOSAL

Haz Mat Trans, Inc., the waste disposal subcontractor, is hired to dispose of wastes generally within 30 days of collection. The waste disposal subcontractor provides services including, but not limited to, preparation of manifests, transportation and disposal of wastes. TN&A is responsible for potentially hazardous waste profiling and the EPA is responsible for signing all manifests.

Potentially hazardous solid and liquid wastes generated during O&M activities are managed under Title 40 Code of Federal Regulations 261.31 to 261.33. Non-hazardous and hazardous

wastes generated during O&M activities are disposed of in an EPA-approved Subtitle C landfill. Information on the GAC and filter bag waste disposal sites is provided below:

| GAC | Filter Bags |
|---|---|
| Kettleman Hills Facility Chemical Waste Management, Inc. EPA ID: CAT000646117 35251 Old Skyline Road PO Box 471 Kettleman City, CA 93239 | Siemens Water Technologies Corp. EPA ID: CAD097030993 5375 South Boyle Avenue Vernon, CA 90058 |

In the future, the following EPA-approved waste disposal facilities may be utilized:

| Hazardous and Non-Hazardous Solid Wastes | Liquid Wastes |
|--|--|
| Clean Harbors Buttonwillow Facility EPA ID CAD980675276 2500 West Lokem Road Buttonwillow, CA 93206 | DeMenno-Kerdoon Facility EPA ID: CAT080013352 200 N. Alameda Street Compton, CA |

TN&A has secured approval from the EPA for each of the above-listed waste disposal facilities. TN&A is responsible for coordinating signing of manifests for all wastes with the EPA.

10.3 OFF-SITE WASTE TRANSPORTATION AND DISPOSAL

The EPA pre-approved all off-site disposal facilities during the waste profiling process. Only properly licensed waste haulers can be used for off-site transportation of non-hazardous solid wastes.

Trucks are scheduled to arrive and depart through the District Boulevard gates at off-peak residential traffic times. Morning truck arrivals are scheduled prior to or after the 07:00 – 08:30 peak hours and afternoon departures are scheduled prior to 15:30.

Generally, waste transport trucks are within parking area in front of the office, and are not expected to become contaminated. The trucks pass briefly through the adjacent residential neighborhood, but then travel on Slauson Avenue, a mixed commercial/industrial street before exiting to the 710 Freeway.

10.4 RECORD KEEPING

TN&A maintains all manifests and records of all waste materials removed from the site. Please refer to [Table 10.1](#) for the waste GAC disposal summary and the waste filter bag disposal summary.

The records include the following items:

- Signed wastes manifests and weigh tickets for non-hazardous waste shipments (per federal and state regulations)
- Receipts and/or bills of lading for general solid waste
- Exception reports, in the event that a manifest copy is not received within 35 days of shipment initiation

- Land disposal restriction notification
- Information on labeling, packaging, marking, and placarding of waste shipments

The TN&A Site Manager maintains a binder at the Site field office trailer exclusively for waste transfer activities and provides copies to the EPA. Non-hazardous wastes (soil, liquids) transported, treated, stored, or disposed of must be recorded and reported. At the specified time, TN&A will forward, to the EPA RPM or designee a submittal in the proper form and format to allow the RPM to file a California State Annual or EPA biennial report. The information will contain TN&A's company name, contract number and project location.

11.0 PROJECT DATA COMMUNICATIONS

A communications plan was developed to specify how project issues will be communicated among the project team members and with EPA/USACE. In general, a number of planned conference calls and summary reports are distributed that facilitate coordination of the project team. The project team website supports team communications and allows the team to obtain all pertinent data pertaining to the project. A procedure has also been developed to address unplanned issues and problems.

11.1 PROJECT WEBSITE

The Pemaco project website serves as a work environment where internal and external participants come together as a cohesive team. All data generated through system monitoring as well as environmental data (e.g. groundwater chemical data and vapor data) is accessible to the project team via the website. The website functions as a secure virtual office space with all of the tools and facilities necessary for the project team members to stay up to date on developments and to interact with one another. Some of the useful tools available on the project website include: a bulletin board, a calendar, events and announcements, an online library of relevant historical materials, operational materials, reports, graphics, animations, interactive maps, and interactive schematics.

11.2 SCHEDULED AND UNSCHEDULED COMMUNICATIONS

Scheduled communications consists of those activities that are scheduled on a daily, weekly, or monthly basis to communicate project progress. Communication primarily consists of teleconferences and summary reports. These communications include the following:

- Daily Field Call: The TN&A Site Manager facilitates a daily field call each weekday with each of the Project Engineer (as shown on the Organization Chart, [Figure 1.4](#)). The purpose of the field call is to review recent occurrences, to review work to be performed during the upcoming day, and to review data to be collected. This call is also used to emphasize items of particular concern or issues warranting close attention.
- Daily QC Reports: The TN&A Site Manager prepares a daily report at the end of each weekday that summarizes data collection and field activities for the current day. This daily report is uploaded to the website by 9:00 am on the following weekday (the Friday report will be uploaded by 9:00 am the following Monday). An example daily report is provided as [Table 11.1](#).
- Weekly Team Conference Call: A weekly conference call is held for the extended project team, including all site Operators and Managers. The purpose of this call is to confirm that all aspects of the project are properly communicated among the project team. The agenda of the call addresses: 1) Work completed during the previous week, 2) Work planned for the upcoming week and priorities, 3) Staffing issues, 4) Equipment status, and 5) Changes in system operations and/or schedule.
- Weekly ERH Summary Report: A PDF summary report is uploaded to the project team website each week that provides a quick overview of the previous week's ERH activities, existing problems or issues, and charts and figures that track the progress of the thermal remediation. The report includes an energy balance, energy use, and temperatures profiles. The report is produced by TRS and approved by the TN&A Project Manager prior to distribution and upload to the web site.

- Weekly QC Report: A weekly QC report is provided to EPA and USACE on Monday of each week. The primary purpose of this report is to provide a summary of the week's operations and to forecast for the next week. Items requiring immediate attention are always e-mailed as they are identified, but reminders of the issues are included in the weekly management report.
- Operations Summary: This is a brief report recapping the critical element change of the project such as lead carbon vessel change, equipment replacement, system shutoff resolution, and manifold operations. Operation summary is updated by the TN&A Site Manager on a daily basis and distributed by email to EPA and USACE along with the daily report. Operation summary also records system runtime, filter bag usage, salt usage, and chlorine usage to help the Site Manager and Project Engineer to track the O&M efficiency. An example of the operations summary is provided as [Table 11.2](#).
- 3-Week Project Schedule: A 3-week project schedule is provided to EPA and USACE on the weekly team conference call. The schedule assists Managers in foreseeing the work planned for the upcoming week and priorities. An example of the 3-week schedule is provided as [Table 11.3](#).
- Weekly ERH Summary Report: A PDF summary report is uploaded to the project team website each week that provides a quick overview of the previous week's ERH activities, existing problems or issues, and charts and figures that track the progress of the thermal remediation. The report includes an energy balance, energy use, and temperatures profiles. The report is produced by TRS and approved by the TN&A Project Manager prior to distribution and upload to the web site.

Copies of these reports are provided in [Appendix 7](#).

Time-critical issues and items will be communicated to USACE as they are identified, typically by e-mail since this allows the project team to be copied on important communications. These items will include health and safety issues, updates on equipment repair and/or replacement, early notices on potential problems, and status updates of urgent items in progress.

As-needed teleconferences will be conducted to address specific scope items to confirm that the project team understands the issue. As issues are identified that require modification to equipment or processes in the field, an additional form will be completed to communicate the required modifications. The time-critical issues will be summarized in the weekly management report as a reminder of the status of each item.

12.0 HEALTH AND SAFETY MANAGEMENT

All work performed at the Pemaco Superfund Site is accomplished in a manner that protects the health and safety of the workers and environment, and complies with all applicable federal, state, local, and employer requirements. This section provides an overview of the management system for implementing safety requirement and ensuring a safe work environment. Detail related to specific health and safety requirements and procedures are not included in this plan, but are defined in the TN&A's Accident Prevention Plan/Site Safety and Health Plan (APP/SSHP), and Accident Hazards Analysis (AHAs) provided by TRS (for ERH) and ERM, the builder of the extraction and treatment system.

TN&A is ultimately responsible for ensuring that all work performed for USACE and EPA at the site is performed safely and in accordance with federal, state, and local requirements. As part of this responsibility, TN&A communicated applicable health and safety requirements to all site subcontractors, provided oversight and inspections of site activities, and ensured compliance with such requirements. TN&A will provide direction to all site personnel to correct unsafe or noncompliance acts or conditions. Material Safety Data Sheets pertaining to all the chemicals used in the treatment plant are available on Site.

TN&A is responsible for establishing methods by which work will be performed to ensure a safe work environment that complies with all applicable requirements. TN&A's role is detailed below:

- Inspect and/or provide all required personal protective equipment, exposure monitoring equipment and instruments, area posting and control signs and barriers, and other associated health and safety supplies,
- Plan and perform all work using an Integrated Safety Management System (ISMS) process described in the MOMP (TN&A, 2007) equivalent to the model applied throughout USACE sites,
- Act as a designated and qualified safety professional for the project and work with the operations team in performing activity hazard analysis, determining appropriate safety controls, prescribing personal protective monitoring equipment, performing and documenting personnel exposure monitoring, and assisting with any required investigation and analysis of work related accidents, injuries, or near misses. During routine operation of the remediation process system, an individual with health and safety experience commensurate with the process hazards has been designated as the health and safety competent person,
- Maintain and communicate a policy whereby every individual on site has the authority to stop work if imminently unsafe conditions exist,
- Develop a Site Safety and Health Plan (SSHP),
- Develop an AHA for all major activities associated with fulfilling the scope of work,
- Notify the Project Manager immediately of any work-related accident resulting in personnel injury or illness, environmental spill or release of regulated material, near miss occurrence, or other event that would require report in accordance with USACE requirements, and

- Ensure that any emergency response actions related to their activities or involving their personnel are conducted in accordance with applicable site-specific SSHPs and procedures.

12.1 HEALTH AND SAFETY DOCUMENTS

TN&A maintains a corporate Health and Safety Manual as the primary document that describes TN&A's commitment to worker protection and defines specific policies related to worker health and safety. This manual is structured to provide standards for routine hazards and associated controls related to general industry and construction hazards.

To implement the health and safety standards for the Pemaco site, a site-specific APP/SSHP was written to provide the framework for day-to-day implementation of the health and safety program.

TRS also has SSHPs that address the hazards and controls associated with the ERH work. These SSHPs at a minimum meet the requirements of 29 CFR 1910.120, "Hazardous Waste Operations and Emergency Response". The subcontractors' SSHPs are subordinate to and will not conflict with the TN&A SSHP for activities at Pemaco.

Health and safety activities will be formally documented. Among the types of records included are:

- Record of the tailgate safety meeting,
- AHAs,
- Access control logs,
- Training records,
- Medical records,
- Exposure monitoring data,
- Instrument calibration data,
- Various safety work permits,
- Routine inspection reports,
- Safety inspections, and
- SSHPs and procedures

TN&A ensures that copies of all health and safety documents are readily available at the Site, in the office, and that they are distributed to the USACE and the EPA.

12.2 EMERGENCY RESPONSE ACTIONS

Emergencies within the scope of this document may include accidents or releases of chemicals, fires, or natural events such as a flood, earthquake, or other natural disaster. The site-specific APP/SSHPs and ERP contain personnel responsibilities and actions required by TN&A and subcontractors in the event of such emergency.

13.0 SECURITY AND SITE ACCESS CONTROL

Access to the Site is restricted and controlled to mitigate health and safety, and environmental hazards to the public, workers, and environment; limit access to authorized and/or trained personnel and escorted visitors; and to control the physical assets of EPA, TN&A and their subcontractors.

TN&A is responsible for site controls associated with the exclusion and contaminant reduction zones and the TN&A field office, project work areas, and associated structures. All persons entering the Pemaco work area must sign the TN&A sign-in-log and receive a safety briefing commensurate with the areas they access and the work activities.

Security and site access controls are documented through TN&A's SSHP. TN&A provides oversight, inspection and access-controlled fencing and gates to control the boundaries of the area under remediation.

A control zone is established within the remediation area and thus, personnel are required to have specific training and/or PPE prior to access. Access control and Occupational Safety and Health Administration (OSHA) required warnings and informational signs designate limited access areas. Hazard communication, safety briefings, training, and access sign-in and sign-out logs are documented and reviewed for compliance.



A double-beam security system with interlocks and alarms was installed to prevent entry of unauthorized persons to the ERH area. The ERH system and power supply will automatically shut down if an intrusion occurs for safety and security reasons. An extended fence was also installed along the bike path to discourage unauthorized entry to the Site.

A security guard is present on site after normal work hours and 24 hours a day during weekends and holidays. The security guard is instructed to first call the police for intruders; fire department in case of fire; TN&A in case of equipment malfunction. The presence of the security guard and extensive warning signs has resulted in no break-ins or thefts since ERH since ERH system startup.

14.0 REFERENCES

- J&H, P.C., 2007. *Draft Operation and Maintenance Manual*, Pemaco Superfund Site, Maywood, California, 19 July.
- Thermal Remediation Services, Inc. (TRS), 2006. *Final Work Plan for In Situ Thermal Remediation (Electrical Resistance Heating)*, Pemaco Superfund Site, Maywood, California 90270. 21 September.
- TN&A, 2006. *Final Remedial Design Report*, Pemaco Superfund Site, Maywood, California, August.
- TN&A, 2007. *Accident Prevention Plan*, Pemaco Superfund Site, Maywood, California, August.
- TN&A, 2007. *Construction Completion Report*, Pemaco Superfund Site, Maywood, California, 30 September.
- TN&A, 2007. *Emergency Response Actions*, Pemaco Superfund Site, Maywood, California, October.
- TN&A, 2007. *Environmental Protection Plan*, Pemaco Superfund Site, Maywood, California, October.
- TN&A, 2007. *Monitoring Operations and Maintenance Plan*, Pemaco Superfund Site, Maywood, California, October.
- TN&A, 2007. *Sampling and Analysis Plan*, Pemaco Superfund Site, Maywood, California, October.
- TN&A, 2007. *Waste Management Plan*, Pemaco Superfund Site, Maywood, California, February.
- EPA, 2005. Record of Decision for Pemaco Maywood Superfund Site, Maywood, California. EPA ID: CAD980737092. 13 January.

FIGURES



LEGEND



DATE:
11/5/2000

FILE NAME:
PEMACO-SL

APPROVED BY:

SITE LOCATION MAP

PEMACO, INC.
MAYWOOD, CALIFORNIA

TN & Associates, Inc.
Engineering and Science

FIGURE
1.1







Figure 1.4
Organizational Chart
 Pemaco Superfund Site, Maywood, California





LEGEND:



ABBREVIATIONS:

| | | | |
|-------|--|------|-----------------------------------|
| AL | ALARM | LSHH | LEVEL SWITCH HIGH-HIGH |
| CV | CONTROL VALVE | LSL | LEVEL SWITCH LOW |
| dPIT | DIFFERENTIAL PRESSURE INDICATING TRANSMITTER | LSLL | LEVEL SWITCH LOW-LOW |
| FE | FLOW ELEMENT | PI | PRESSURE INDICATOR |
| FI | FLOW INDICATOR | PT | PRESSURE TRANSMITTER |
| FM | FLOW METER | PS | PRESSURE SWITCH |
| FQI | FLOW TOTALIZER | SP | SAMPLE PORT |
| GALV | GALVANIZED | SS | STAINLESS STEEL |
| HOA | HAND-OFF AUTO | TI | TEMPERATURE INDICATOR |
| LAH | LEVEL ALARM HIGH | TIT | TEMPERATURE INDICATOR TRANSMITTER |
| LACSD | LOS ANGELES COUNTY SANITATION DIVISION | VI | VACUUM INDICATOR |
| LI | LEVEL INDICATOR | VT | VACUUM TRANSMITTER |
| LSH | LEVEL SWITCH HIGH | VFD | VARIABLE FREQUENCY DRIVE |

NOTES:

- A SUMMARY OF PROCESS EQUIPMENT DESCRIPTIONS AND SPECIFICATIONS ARE SHOWN ON THIS DRAWING. REFER TO TABLE 4-11 - EQUIPMENT AND INSTRUMENT SPECIFICATION SUMMARY AND TABLE 4-12 - MAJOR EQUIPMENT SPECIFICATIONS FOR MORE DETAILS ON PUMPS, BLOWERS, PUMPS, VAPOR PHASE CARBON ADSORPTION UNITS, FLAMELESS THERMAL OXIDATION SYSTEM AND FILTRATION SYSTEMS.
- PLEASE SEE SPECIFICATION SECTION 13405 - PROCESS LOGIC CONTROL FOR PLC DESIGN, INTERLOCKS, ALARMS, AND CONTROL REQUIREMENTS AND SPECIFICATIONS.
- INSTALLATION OF PIPING SYSTEM SHALL BE PERFORMED IN ACCORDANCE WITH ATTACHMENT 2 IN THE RFP AND SPECIFICATION SECTION 15400-PROCESS PIPING.
- ALL ELECTRICAL WIRING SHALL CONFORM TO SPECIFICATION DIVISION 16 - ELECTRICAL.
- CONTROL PANELS FOR EACH TREATMENT PROCESS SHALL BE DESIGNED AND POSITIONED ON THE EQUIPMENT IT CONTROLS BY THE MANUFACTURER.
- TREATMENT EQUIPMENT SHALL BE PLACED IN ACCORDANCE WITH THE TREATMENT COMPOUND PROCESS LAYOUT ON DRAWING M-4.
- ALL PIPING AND CONDUITS SHALL BE SUPPORTED, IN ACCORDANCE WITH LOCAL CODES, TO PREVENT SAGGING OR OVER-STRESSING OF THE PIPE AND CONNECTIONS. ALL PIPING SHALL BE SUPPORTED SO THAT NO LOAD OR STRESS IS TRANSFERRED TO ANY EQUIPMENT.
- PROCESS PIPING SHALL BE LABELED WITH FLOW DIRECTION AND CONTENT AT ALL ABOVE GROUND VALVES.
- WHERE PIPING IS ROUTED ABOVE GROUND (INSIDE THE COMPOUND) THE PIPING SHALL BE SUPPORTED BY UNISTRUT AND SHALL BE INSTALLED PER LOCAL CODE AND PIPE MANUFACTURER GUIDELINES.
- UTILITY PIPING MUST BE INSTALLED PER LOCAL CODE.
- ALL PROCESS PIPING BENEATH ROADS SHALL BE A MINIMUM OF SCHEDULE 40.
- SECONDARY CONTAINMENT PIPING AND ELECTRICAL CONDUIT, WHERE REQUIRED, SHALL BE A MINIMUM OF SCHEDULE 40.
- SUMP PUMP P-502 HOSES, ELECTRICAL, AND CONTROLS MUST BE CONFIGURED FOR QUICK REMOVAL FROM SECONDARY CONTAINMENT SUMP.
- CAUSTIC PUMP P-901 WILL BE PROVIDED BY ANGUL AND WILL BE INSTALLED BY CONTRACTOR AS PART OF THIS SCOPE.
- FINAL DESIGN OF VAPOR CONDITIONING PACKAGE SHALL BE DETERMINED BY TREATMENT SYSTEM CONTRACTOR.


GENERAL PIPING AND INSTRUMENTATION DIAGRAM

PEMACO SUPERFUND SITE
5050 EAST SAULSON AVENUE
MAYWOOD, CALIFORNIA

| | |
|--|--|
| PREPARED FOR: U.S. Environmental Protection Agency Region IX San Francisco, California | PREPARED BY: T N & Associates, Inc. & A Engineering and Science |
| SCALE: AS SHOWN | DATE: 05/29/2007 |
| DESIGNED: MB, JW & LL | AS BUILTS |
| DRAWN: DC & JRP | FIGURE |
| CHECKED: JW | 2.1 |

AS-BUILT





LEGEND:

- I-BEAM COLUMN
- C-CHANNEL COLUMN
- UTILITY GAS
- UTILITY WATER/DRAINAGES
- TREATED WATER
- EMERGENCY STOP

DRAFT NOTES:

- THE INTENT OF THIS DRAWING IS TO SHOW EQUIPMENT LAYOUT. REFER TO DRAWING M-1 FOR THE PROCESS AND INSTRUMENTATION DIAGRAM.
- TREATMENT EQUIPMENT SHALL BE PLACED AS SHOWN IN THIS DRAWING. NECESSARY MODIFICATIONS TO LAYOUT DUE TO ACCESS, MAINTENANCE ETC., MUST BE APPROVED BY PROJECT ENGINEER.
- ALL EQUIPMENT AND SKIDS SHALL BE BOLTED ONTO CONCRETE SLAB. ALL SLAB CONNECTIONS SHALL BE SUBJECT TO INSPECTION ACCORDING TO SPECIFICATION SECTION 01452-SPECIAL INSPECTION FOR SEISMIC-RESISTING SYSTEMS. ITEMS WHICH CANNOT BE SKID MOUNTED SHALL BE SIMILARLY MOUNTED OR RESTRAINED BY CABLE OR WALL BRACES AND SUBJECT TO THE SAME SPECIAL INSPECTION FOR SEISMIC-RESISTING SYSTEMS.
- TREATMENT COMPOUND FOUNDATION SHALL BE CONSTRUCTED AS SHOWN IN DRAWINGS C-12 AND C-13. CHANGES TO THE FOUNDATION DESIGN MAY BE REQUIRED BASED ON THE PRE-ENGINEERED METAL BUILDING CONTRACTOR'S DESIGN.
- TREATMENT COMPOUND BUILDING IS A PRE-ENGINEERED METAL STRUCTURE THAT SHALL BE CONSTRUCTED ACCORDING TO DRAWING C-11 AND SPECIFICATION SECTION 13120-PRE-ENGINEERED METAL BUILDINGS.
- REFER TO SPECIFICATION DIVISION 08-DOORS AND WINDOWS, DIVISION 11-TREATMENT COMPONENTS, DIVISION 13-STRUCTURAL COMPONENTS AND PROCESS CONTROL, DIVISION 15-PLUMBING AND DIVISION 16-ELECTRICAL FOR DETAILS ON TREATMENT COMPOUND CONSTRUCTION.
- CONTRACTOR SHALL EXERCISE DUE CARE TO PROTECT EQUIPMENT FROM THEFT OR DAMAGE.
- INTERNAL PIPING AND CONVEYANCE SYSTEMS SHALL BE LOCATED OVERHEAD (8' MINIMUM) OR BENEATH THE CONCRETE SLAB TO ALLOW FORKLIFT ACCESS TO INDIVIDUAL SKIDS.
- INSTALLATION OF ALL PIPING SHALL BE PERFORMED IN ACCORDANCE WITH SPECIFICATION SECTION 15400-PROCESS PIPING. UTILITY PIPING MUST BE INSTALLED PER LOCAL CODE.
- ALL PIPING AND CONDUIT SUPPORTS (NOT SHOWN) SHALL BE INSTALLED IN ACCORDANCE WITH LOCAL CODES TO PREVENT SAGGING OR OVER-STRESSING OF THE PIPE AND CONNECTIONS. ALL PIPING SHALL BE SUPPORTED SO THAT NO LOAD OR STRESS IS TRANSFERRED TO ANY EQUIPMENT.
- PROCESS PIPING AND VALVES SHALL BE LABELED WITH FLOW DIRECTION AND CONTENT AT ALL ABOVE GROUND LOCATIONS.
- FINAL DESIGN OF VAPOR CONDITIONING PACKAGE SHALL BE DETERMINED BY TREATMENT SYSTEM CONTRACTOR.






TREATMENT COMPOUND PROCESS LAYOUT

PEMACO SUPERFUND SITE
5050 EAST SLAUSON AVENUE
MAYWOOD, CALIFORNIA

| | | | |
|--|---------------------|--|------------------|
| PREPARED FOR: U.S. Environmental Protection Agency Region IX San Francisco, California | | PREPARED BY: T N & Associates, Inc. & A Engineering and Science | |
| SCALE: AS SHOWN | DESIGNED: J.W. & DC | APPROVED AS BUILTS | DATE: 05/29/2007 |
| DRAWN: DC & JBP | CHECKED: J.W. | | FIGURE 2.3 |

AS-BUILT





TABLES

Table 2.1
Treatment System Equipment
Pemaco Superfund Site, Maywood, CA

| P&ID | Item Description | Material/Schedule | Operating Specifications | "As-Built" Specified Manufacturer Catalog | Other Specifications |
|---------------|---|--|---|---|---|
| B-101 | Liquid-Ring Vacuum Pump System | TYP | 75 hp/1100 acfm | Oil-Sealed 75 hp Dekker Vacuum Technologies, Inc. System Model #VMX1103KA1-01 | Equipped with oil liquid ring, system interlock/failsafe, alarms, and hour meters. Maximum vacuum 29 in. Hg. 1100 rpm. Max. noise level: 80 dBA. See Table 4-12 - Major Equipment Specifications for more details. |
| B-102 | Liquid-Ring Vacuum Pump System | TYP | 75 hp/1100 acfm | Oil-Sealed 75 hp Dekker Vacuum Technologies, Inc. System Model #VMX1103KA1-01 | Equipped with oil liquid ring, system interlock/failsafe, alarms, and hour meters. Max. vac. 29 in. Hg. 1100 rpm. Max. noise level: 80 dBA. See Table 4-12 - Major Equipment Specifications for more details. |
| B-301 | System Exhaust Blower with Sound Enclosure | TYP | 1,000 cfm, 25 hp | Baldor EM4103T - 25 hp Motor, Roots Rotary Positive Blower - Frame Size 615, SDY 54-106-AA Silencer | 25 hp, 1770 rpm, TEFC, 1036 cfm @ 1750 rpm, 7 psi. See Submittal 11215-16 for sound enclosure details. |
| CT-201 | Cooling Tower, VC Package | TYP | 650 gpm | AQUA-Loop Cooling Tower MB-300 | To be provided as part of the vapor conditioning package. Water evaporation rate: 7.0 gpm. Water blowdown rate: 3.0 gpm. Total water consumption rate is estimated to 10.0 gpm. |
| CV-401, 402 | Bypass Control Valves | CPVC schedule 80 | Rated for 15 psig, 200° F | Hayward Manual Butterfly Valve Engineer Approved Equivalent | Flanged Butterfly valve with Viton elastomer |
| D-601 | Regenerative Desiccant Dryer | TYP | 5 scfm, 90 psig, -90°F Dew Point | KAESER KADW-10 | To provide continuous 5 scfm, 90 psig, and -90°F dew point purge air to FTO, Regenerative desiccant type |
| dPIT-101 | Differential Pressure Indicating Transmitter | Stainless Steel | 0-10in. wc | Dwyer Instrument Model# 605-10 | Electrical accuracy ±0.5%, mechanical accuracy ±2%, 4-20 mA, 2 wire, 10-35 VDC, 0-10 in. wc stainless steel connection tubing |
| F-101 | Inlet Vacuum Particulate Filter | Stainless Steel | 5 microns/2000 acfm | Solberg CSL-485P(2)-1200FS1 485P Polyester Element | 99%+ removal efficiency, Inlet air enters canister above element, SS Housing cartridge filter, Positive sealing O-ring seal system, 0.5 bar pressure for vacuum tightness, Vacuum level: 1x10 ⁻³ mmHg. Two filters installed in parallel with valving as shown in Drawing M-4. Nominal Rating: 4950 scfm, two (2) 485P elements per filter housing. 6" inlet/outlet are custom welded. |
| F-102 | Inlet Vacuum Particulate Filter | Stainless Steel | 5 microns/2000 acfm | Solberg CSL-485P(2)-1200FS1 485P Polyester Element | 99%+ removal efficiency, Inlet air enters canister above element, SS Housing cartridge filter, Positive sealing O-ring seal system, 0.5 bar pressure for vacuum tightness, Vacuum level: 1x10 ⁻³ mmHg. Two filters installed in parallel with valving as shown in Drawing M-4. Nominal Rating: 4950 scfm, two (2) 485P elements per filter housing. 6" inlet/outlet are custom welded. |
| F-103 | Oil Mist Exhaust Filter | Stainless Steel | 0.3 microns/1100 scfm | Solberg HDL-PSG474-2-500 | 0-5 psig operating, 10 psig proof pressure, Minimum 99.97% D.O.P. on 0.3 micron diameter particles, Positive sealing O-ring seal system, SS Housing cartridge filter. Two filters installed in parallel with valving as shown in Drawing M-4. |
| F-104 | Oil Mist Exhaust Filter | Stainless Steel | 0.3 microns/1100 scfm | Solberg HDL-PSG474-2-500 | 0-5 psig operating, 10 psig proof pressure, Minimum 99.97% D.O.P. on 0.3 micron diameter particles, Positive sealing O-ring seal system, SS Housing cartridge filter. Two filters installed in parallel with valving as shown in Drawing M-4. |
| F-401 | Water Filter, four (4) size two bag filter housings in one vessel | 316 Stainless Steel | 400 gpm | Hayward/Eaton Filtration, LLC. Qic-Lock™ Maxiline™ VMBF SE # VMBF-0402-AB10-040A-UT-11SE | Multiple 316 SS bag filter with (4) size two bag filter housings inside one vessel, spring assisted cover, 4" flanged inlet/outlets, low profile for quick filter replacement. Mounted on skid with single bag filter F-402. Inlet/outlet shut-off valves as shown in Drawing M-4. |
| F-402 | Water Filter, one (1), size two bag filter housing | 316 Stainless Steel | 180 gpm | Krystil Klear Filtration L88302FB610, 100 psi | Single 316 SS bag filter with (1) size two bag filter housing, 2" flanged inlet/outlets, low profile for quick filter replacement. Mounted on skid with multiple bag filter housing F-401. Shut-off valves as shown in Drawing M-4. |
| F-403 | Water Filter, size two bag filter housing | 316 Stainless Steel | 180 gpm | Krystil Klear Filtration L88302FB610, 100 psi | Single 316 SS bag filter with size two bag filter housing, 2" flanged inlet/outlets. Skid mounted. Shut-off valves as shown in Drawing M-4. |
| F-404 | Water Filter, size two bag filter housing | 316 Stainless Steel | 180 gpm | Krystil Klear Filtration L88302FB610, 100 psi | Single 316 SS bag filter with size two bag filter housing, 2" flanged inlet/outlets. Skid mounted. Shut-off valves as shown in Drawing M-4. |
| F-501 | Water Filter, size two bag filter housing | 316 Stainless Steel | 180 gpm | Krystil Klear Filtration L88302FB610, 100 psi | Single 316 SS bag filter with size two bag filter housing, 2" flanged inlet/outlets. Skid mounted. Shut-off valves as shown in Drawing M-4. |
| F-502 | Water Filter, size two bag filter housing | 316 Stainless Steel | 180 gpm | Krystil Klear Filtration L88302FB610, 100 psi | Single 316 SS bag filter with size two bag filter housing, 2" flanged inlet/outlets. Skid mounted. Shut-off valves as shown in Drawing M-4. |
| F-601 | Air Filter-compressed air particulate filter with automatic drain | Aluminum | 250 cfm @ 100 psig | Kaeser KPF-250 | Maximum working pressure: 250 psig. Maximum operating temp: 150°F. |
| F-801 | Calcium Filter | TYP | 20 gpm min/<3ppm Calcium | U.S. Filter Duplex KF-2 21"x62" KFZSD021FPZVCX | US Filter KF Series Duplex Alternating Softener w/ brine tank, Feed Temp 45-100°F, Feed pressure 30-100 psig, <3ppm Calcium, 77 gpm, 110V |
| FA-301 | Flame Arrestor | Aluminum outer body with 316 SS internal | Not Specified | GROTH Model 80013075 | Flame arrestor to serve as a backflash prevention device (from vapor phase carbon vessels). Aluminum outer body with 316 SS internal, 12.72" outer diameter, 55 pounds. |
| FE-101 | Vapor Flow Element-Averaging Pitot Tube | Sensor Tube - 304 SS | 0-3040 scfm | Dwyer DS-300-8" | Averaging pitot tube to be used with differential pressure transmitter (dPIT-101), valve is rated at 200 psig and 200°F, 1/4" NPT connection. |
| FI-101 to 108 | Vapor Flow Indicator | Brass | Not Specified | Swagelock Borethrough B-500-1-4BT with Plug (B-500-P) | 1/4" NPT borethrough fitting for insertion of averaging pitot tube. |
| FQI-401 | Flow Totalizer & Indicator | PVDF Rotor, PVC schedule 80 TEE | 22-450 gpm | Signet Series 515 Rotor X, Signet Series 8550 ProcessPro Flow Transmitter, Signet Installation Fitting 3" Tee | Self-powered flow sensor, housing material PVDF, rotor material nat. PVDF, pipe size 1/2" to 4" <Harrington Plastics Part# PS1530-V0>, Field mount with dual input/output <Harrington Plastics Part# 3-8550-3>, 4-20mA, 24 VDC power, <Harrington Plastics Part# PV8T030>, Accuracy: +/- 0.5%. |
| FQI-402 | Flow Totalizer & Indicator | Brass | 2.5-160 gpm | McMaster-Carr 3786k96 | Corrosion-Resistant totalizer with Impeller, NPT male connection. Accuracy: +/- 1.5%. |
| FQI-501 | Flow Totalizer & Indicator | PVDF Rotor, PVC schedule 80 TEE | 20-200 gpm | Signet Series 515 Rotor X, Signet Series 8550 ProcessPro Flow Transmitter, Signet Installation Fitting 2" Tee | Self-powered flow sensor, housing material PVDF, rotor material nat. PVDF, pipe size 1/2" to 4" <Harrington Plastics Part# PS1530-V0>, Field mount with dual input/output <Harrington Plastics Part# 3-8550-3>, 4-20mA, 24 VDC power, <Harrington Plastics Part# PV8T020>, Accuracy: +/- 0.5%. |
| FTO-101 | Flameless Thermal Oxidizer and Scrubber | Not Specified | 1000 scfm Max. | ANGUIL EDGE QR-1000 | To be provided by Anguil and procured by USACE |
| H-201 A/B/C | Air Chiller/Condenser | Stainless Steel/Zinc Plated Steel | 297 gpm | Xchanger Model TV-275 | The VC Package must be capable of interfacing with both the FTO PLC and treatment compound PLC. 297 gpm, Design Temp: -100°F to 225°F. |
| H-202 | Air Warmer | Stainless Sheath and Fins | Not Specified | Vulcan VFT612-10C3 Low Temp Duct Heater | The VC Package must be capable of interfacing with both the FTO PLC and treatment compound PLC. Inlet air temperature shall not exceed 100°F. |
| H-401 | Heat Exchanger | Stainless Steel/Copper coils | 20 gpm | Xchanger, Inc. LC series or equivalent | See Table 4-12 Major Equipment Specifications for more details. Temperature in: 165°F, Temperature out: 130°F. Pressure loss: 2.1 psi. Design temperature: -300 to 200°F. |
| K-601 | Rotary Screw Air Compressor and receiver tank | TYP | 125 PSI, 124 scfm, 30 Hp, 240 gallon receiver | Kaeser Compressor AS-30 | See Table 4-12 - Major Equipment Specifications for more details. |
| LI-101 | Level Indicator | Clear PVC | Not Specified | MK Environmental Stilling Well Level Control Typical | Level indicator for moisture separator to consist of clear pipe with valves and flanges/unions to allow for replacement/cleaning of indicator |
| LI-201 | Level Indicator | Clear PVC | Not Specified | MK Environmental Stilling Well Level Control Typical | Level indicator for moisture separator to consist of clear pipe with valves and flanges/unions to allow for replacement/cleaning of indicator |
| LI-401 | Level Indicator | Clear PVC | Not Specified | MK Environmental Stilling Well Level Control Typical | Level indicator for moisture separator to consist of clear pipe with valves and flanges/unions to allow for replacement/cleaning of indicator |
| LI-402 | Level Indicator | Clear PVC | Not Specified | MK Environmental Stilling Well Level Control Typical | Level indicator for moisture separator to consist of clear pipe with valves and flanges/unions to allow for replacement/cleaning of indicator |
| LI-901 | Level Indicator | Clear PVC | Not Specified | Poly Processing Co. Float Type Sight Gage | Level indicator for caustic tank. Mechanical gauge mounted onto the top of the double contained caustic tank. |
| LSH-101 | Level Switch High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSH-201 | Level Switch High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSH-401 | Level Switch High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSH-501 | Level Switch High | Stainless Steel | Not Specified | GEMS Stainless Steel Multilevel Float Switch - LS800-3-BR-SS-SPST-20-GR2-3 | Plumbing and electrical configured for quick removal for cleaning/replacement, 316 SS, SS ARMCO PH-15-7MO Grip Rings, -40 to 300°F. |
| LSHH-101 | Level Switch High-High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSHH-201 | Level Switch High-High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSHH-401 | Level Switch High-High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSHH-402 | Level Switch High-High | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSHH-501 | Level Switch High-High | Stainless Steel | Not Specified | GEMS Stainless Steel Multilevel Float Switch - LS800-3-BR-SS-SPST-20-GR2-3 | Plumbing and electrical configured for quick removal for cleaning/replacement, 316 SS, SS ARMCO PH-15-7MO Grip Rings, -40 to 300°F. |
| LSL-101 | Level Switch Low | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSL-201 | Level Switch Low | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSL-401 | Level Switch Low | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSL-501 | Level Switch Low | Stainless Steel | Not Specified | GEMS Stainless Steel Multilevel Float Switch - LS800-3-BR-SS-SPST-20-GR2-3 | Plumbing and electrical configured for quick removal for cleaning/replacement, 316 SS, SS ARMCO PH-15-7MO Grip Rings, -40 to 300°F. |
| LSL-901 | Level Switch Low | 316 Stainless Steel | Not Specified | Dwyer/W. E. Anderson Series F7-ST713 Vertical Level Switch | Vertical Level Switch installed from the top of the double contained tank. Float material must be chemically compatible with 25% NaOH solution. |
| LSLL-401 | Level Switch Low-Low | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |
| LSLL-402 | Level Switch Low-Low | Stainless Steel | Not Specified | W.E. Anderson Flotec® Series L6 L6EPBBS3A | Plumbing and electrical configured for quick removal for cleaning/replacement, -4 to 220°F, Explosion proof, SPDT switch type, 1" NPT, 304 SS Cylindrical Float. |

Table 2.1
Treatment System Equipment
Pemaco Superfund Site, Maywood, CA

| P&ID | Item Description | Material/Schedule | Operating Specifications | "As-Built" Specified Manufacturer Catalog | Other Specifications |
|--|---|---|--|--|---|
| P-201 | Cooling Tower Transfer Pump | Stainless Steel | Not Specified | SCOT ARDOX Motorpump - 1750 rpm, 20 hp, 9.38" Impeller, TEFC | To be provided as part of the vapor conditioning package. |
| P-202 | Refrigerated Chiller Pump | Stainless Steel | Not Specified | ITT Goulds Pump - 2ST1H5B4, 3 hp, TEFC Motor | To be provided as part of the vapor conditioning package. |
| P-203 | VC Package Condensate Pump | Polypropylene, ETFE | 52 gpm/45' TDH | Pacer Pumps - Z-40, 1/2 hp | To be provided as part of the vapor conditioning package |
| P-401 | Booster Tank Pump | 316 Stainless Steel | 110 gpm/55' TDH/3 Phase, 460 V | ITT Goulds Pump - 2ST1H2B4, 3 hp, ODP Motor | Centrifugal pump see Major Equipment Specifications for more details. The pump may pass no more than 3/16" particle. |
| P-402 | Holding Tank Pump | 316 Stainless Steel | 100 gpm/75' TDH/3 Phase, 460 V | ITT Goulds Pump - 2ST1JSA4, 5 hp, ODP Motor | Centrifugal pump see Major Equipment Specifications for more details. The pump may pass no more than 3/16" particle. |
| P-501 | Transfer Pump | 316 Stainless Steel | 30 gpm/75' TDH/3 Phase, 460 V | AMT Self-Priming Centrifugal Pump 282B-98 | Self priming centrifugal see Major Equipment Specifications for more details. The pump can handle 3/8" diameter semi-solids. |
| P-502 | Pump for Secondary Containment Sump | 316 Stainless Steel | 30 gpm/35' water/3 Phase, 460 V | Dayton Submersible Sewage Pump DN2110070T | Submersible sump pump, solid handling, self priming. Equipped with LSL, LSH, LSHH, system interlock, and alarms. |
| P-901 | Metering Pump | TYP | 34 gph @ 1725 rpm | MacRoy Pump D7688PE1NIN | Provided by Anguil and installed by the contractor. |
| PI-101 to 103, 201 to 203, 414 | Air Pressure Indicator | 304 SS Case/316 SS Internal | 0-15 PSI | McDaniel Controls K9A-GF (0-15 psi) | 2-1/2" Dial Glycerin-Filled, Grade 1A, 1/4" Bottom NPT male connection |
| PI-401 to 405, 407, 408, 501, 502 | Water Pressure Indicator | 304 SS Case/316 SS Internal | 0-60 PSI | McDaniel Controls K9C-GF (0-60 psi) | 2-1/2" Dial Glycerin-Filled, Grade 1A, 1/4" Bottom NPT male connection |
| PI-406, 409 to 413, 415, 503, 504 | Water Pressure Indicator | 304 SS Case/316 SS Internal | 0-30 PSI | McDaniel Controls K9B-GF (0-30 psi) | 2-1/2" Dial Glycerin-Filled, Grade 1A, 1/4" Bottom NPT male connection |
| PI-601 | Air Pressure Indicator | 316 Stainless Steel | 0-200 | Kodiak Controls Glyrcerine Filled, 2-1/2-in Dial Size, SS316, Model KC301L Pressure Indicating Gauge (0-200 psi) | 2-1/2" Dial Glycerin-Filled, 1.5% Accuracy, 1/4" Bottom NPT male connection |
| PI-602 | Air Pressure Indicator | 304 SS Case/316 SS Internal | 0-160 | McDaniel Controls K9E-GF (0-160 psi) | 2-1/2" Dial Glycerin-Filled, Grade 1A, 1/4" Bottom NPT male connection |
| PRV-401, 402, 403, 404, 901, 902 | Pressure Relief Valve | Not Specified | Not Specified | Poly Processing Co. 2" Mushroom (PPL) Relief Valve with Viton Seals | T-401 has (3) 2" vents. T-402 has (2) 2" vents. T-901 has (3) 2" vents. |
| PRV-405 | Pressure Relief Valve | Not Specified | Not Specified | McMaster-Carr #4780K16, 2", set at 65 psi | PRV-406 is not necessary as PRV-405 will be mounted on the inlet manifold to T-403 and T-404 and will serve both tanks adequate pressure and flow should be maintained down stream of valve. |
| PRV-101, 301, 303 | Pressure Relief Valve | Not Specified | Not Specified | Kunkle Model 337 #0337-H01ANE0005 | 2", set point 6 psig. |
| PRV-602 | Pressure Relief Valve | Not Specified | Not Specified | Control Devices, Inc. SF50 | Set point 140 psi, capacity 257 scfm |
| PS-601 | Pressure Switch | Stainless Steel | 22.5-125 PSI | McMaster# 46995K18, 22.5-125 psi, Nema 4 | Compact cylindrical pressure switch, Nema 4, 1/2" NPT male, 5A @ 125/250 VAC, Buna - N diaphragm - sealed piston, set point range 22.5-125 psi, SPDT |
| PT-101 | Air Pressure Transmitter | Stainless Steel | 0-5 PSI | Dwyer Instrument Model# 673-3C, 0-5 psi | ±0.25% full span accuracy, 17-4 PH SS, 4 to 212°F, 4-20 mA, 2 wire, 0-15 psi |
| PT-401 | Water Pressure Transmitter | 316 Stainless Steel | 0-60 PSI | McMaster# 3196K1, 0-60 psi | Economy transducer, 1/4" NPT male, 316 SS, -40 to 212°F, ≤ 0.5% accuracy, 10-30 VDC, 2 wire, 4-20 mA |
| PT-402 | Water Pressure Transmitter | Stainless Steel | 0-5 PSI | Dwyer Instrument Model# 673-3C, 0-5 psi | ±0.25% full span accuracy, 17-4 PH SS, 4 to 212°F, 4-20 mA, 2 wire, 0-5 psi |
| PT-403 | Water Pressure Transmitter | 316 Stainless Steel | 0-60 PSI | McMaster# 3196K1, 0-60 psi | Economy transducer, 1/4" NPT male, 316 SS, -40 to 212°F, ≤ 0.5% accuracy, 10-30 VDC, 2 wire, 4-20 mA |
| PT-404 | Water Pressure Transmitter | 316 Stainless Steel | 0-60 PSI | McMaster# 3196K1, 0-60 psi | Economy transducer, 1/4" NPT male, 316 SS, -40 to 212°F, ≤ 0.5% accuracy, 10-30 VDC, 2 wire, 4-20 mA |
| PT-501 | Water Pressure Transmitter | 316 Stainless Steel | 0-60 PSI | McMaster# 3196K1, 0-60 psi | Economy transducer, 1/4" NPT male, 316 SS, -40 to 212°F, ≤ 0.5% accuracy, 10-30 VDC, 2 wire, 4-20 mA |
| R-601 | Air Regulator | TYP | 5-125 psi | McMaster# 4959K57 | 1 1/2" NPTF, Maximum scfm @ 100 psi: 440 scfm |
| R-602 | Air Regulator | TYP | 10-250 psi | McMaster# 4959K54 | 3/4" NPTF, Maximum scfm @ 100 psi: 220 scfm |
| R-603 | Air Regulator | TYP | 5-125 psi | McMaster# 4959K55 | 1" NPTF, Maximum scfm @ 100 psi: 480 scfm |
| R-604 | Air Regulator | TYP | 5-125 psi | McMaster# 4959K55 | 1" NPTF, Maximum scfm @ 100 psi: 480 scfm |
| R-605 | Air Regulator | TYP | 5-125 psi | McMaster# 4959K55 | 1" NPTF, Maximum scfm @ 100 psi: 480 scfm |
| R-606 | Air Regulator | TYP | 5-50 psi | McMaster# 4959K55 | 1" NPTF, Maximum scfm @ 100 psi: 480 scfm |
| RC-201 | Refrigerated Chiller, VC Package | Copper Tube/Aluminum Fin | 25 Ton/300,000 Btu/h | Zarsky Water Chillers - Model: ACWC-300-E | The VC Package must be capable of interfacing with both the FTO PLC and treatment compound PLC. Carrier Semi-Hermetic Compressor, 460V, 3 Phase |
| T-101 | Moisture Separator | 1/4" minimum hot rolled steel | Remove 95% of all liquid droplet/30 in. Hg Max. Vacuum | tetraSOLV Filtration, 500 gallon., 316 SS, 30" Hg Vacuum. (Skid: 60"Wx60"Lx4"H) | See Table 4-12 - Major Equipment Specifications for more details. 10 microns droplet size @ 99% removal efficiency. |
| T-201 | Moisture Separator | cross linked HDPE | 60 gallon | Poly Processing - 60 gallon Upright Tank | The VC Package must be capable of interfacing with both the FTO PLC and treatment compound PLC. |
| T-202 | Cooling Water Tank, VC Package | cross linked HDPE | 280 gallon | Poly Processing - 280 gallon Upright Tank | The VC Package must be capable of interfacing with both the FTO PLC and treatment compound PLC. |
| T-301 & 302 | Vapor-Phase Carbon Vessel | Double layered Epoxy Coated Carbon Steel, Vacuum Rated | 4,000 lb, 3000 cfm, 15 psig, 4 in. Hg vacuum. | tetraSOLV Filtration VFV-5000, 5000 pounds | Operating fill: 4,000 lb virgin coconut shell carbon. See Table 4-12 - Major Equipment Specifications for more details. |
| T-401 | Groundwater Booster Tank | cross linked HDPE | 905 gallon | Poly Processing Company Stock Number 41100905 | Vapor tight, bolted, polyethylene man way with viton gaskets with 19" opening. Sight tube/level indicator with unions and isolation valves for quick disassembly/replacement and clean-out. |
| T-402 | Water Holding Tank | cross linked HDPE | 4,900 gallon | Poly Processing Company Stock Number 11004900. | Vapor tight, bolted, polyethylene man way with viton gaskets with 19" opening. Sight tube/level indicator with unions and isolation valves for quick disassembly/replacement and clean-out. |
| T-403 & 404 | Liquid-Phase Carbon Adsorber | Double layered Epoxy Coated Carbon Steel | 3,000 pound/150 gpm/75 psig | tetraSOLV Filtration, hpAF-3000, 3000 lbs | Operating fill: 3,000 pound virgin coconut shell carbon. See Table 4-12 - Major Equipment Specifications for more details. |
| T-601 | Air Receiver Tank | Painted Carbon Steel | 240 gallon | Manchester Tank - Vertical Air Receiver, 240 gallon | Maximum working pressure: 200 psi @ 400°F. Include a pressure gauge, pressure relief valve, automatic drain, manual drain, and galvanized steel plumbing. |
| T-602 | Air Receiver Tank Condensate Drum | Epoxy Coated Steel | 55-gallon Drum/200 pound capacity | SKOLNIK - 55 gallon. TH Drum, 2 Hoops | Not Specified |
| T-701 | Holding Tank Carbon Vessel (vent) | Internal: Polyamide Epoxy Resin/External: Urethane Enamel | 55 gallon | tetraSOLV - VFD-55 | 55-gallon carbon drum filled with virgin coconut shell carbon. |
| T-901 | Caustic Soda Tank | Crosslinked Polyethylene Double-wall | 1,500 gallon | Poly Processing Company SAFE-TANK® Stock Number 42001550 | See Table 4-12 - Major Equipment Specifications for more details. |
| TI-101 to 108, TI-201 to 207 | Temperature Indicator | Stainless Steel | 30-240°F | Taylor Bitherm Dial Thermometer BB3102E083 | 3" Dial Bimetal Stem Thermometer, 30 to 240°F, 316 SS, Back or Bottom NPT male connection with thermowell |
| TIT-101, 102, 201, 202, 301, 401, 402, 501 | Temperature Indicating Transmitter | Stainless Steel | 0-200°F | Siemens SITRANS TF2 7NG3140-3BK00 | Temperature Transmitter with Display and RTD sensor, straight thermowell, 1/2" NPT, 4" bore depth, 316 SS |
| V-101 to 108 | Vapor Diaphragm Valves | 316 SS Trim | 250 psi | NIMCO 250 PSI Gear-Actuated Butterfly Valve, Wafer Style, Memory Stop | Wafer style, Fluoroelastomer seal, 316 SS Trim, Geometric drive, Extended neck, Molded-in seat liner, Gear operator: memory stop. |
| V-407 | Actuated Valve | PVC SCH 80 | 150 psig | OSCAF #5213-09-0400 mounted with ETI 1300 Electric Actuator | Controlled by PLC |
| V-452 | 3-Way True Union Ball Valve with Electric Actuator | CPVC schedule 80 | Rated for 15 psig, 200° F | Spears True Union 2000 Industrial 3 Way Ball Valve with Viton seals and L port Spears Premium Electric TU Ball Valve | Controlled by PLC. |
| V-606 | Compressed air FTO instrumentation solenoid control valve | Brass | 150 psig | N/A | Solenoid valve V-606 is believed to be redundant with <i>Anguil provided</i> SV-604 (shown on Anguil Dwg 12584-101 Rev. C). It was agreed on 1/8/07 between D.C and J.W. that ERM will not install. R.M. copied via email |
| V-607 | Compressed air supply 3-way solenoid valve | Brass | 150 psig | ASCO 1" Air and Water Solenoid Valve 8316G34 | Controlled by PLC, normally closed, 150psi (AC)/125 psi (DC) |
| VI-101 to 111, 201, 301 to 306 | Vacuum Indicator | Stainless Steel | 0 to -30" Hg | McDaniel Controls K9S-GF (30"-0in. Hg) | 2-1/2" Dial Glycerin-Filled, Grade A, Back or Bottom connection, 5" Figure Interval, 0.5" Grad. Mark, 1/2" NPT male, 316 SS |
| VT-101, 201 | Pressure Transmitter | Stainless Steel | 0 to -30" Hg | McMaster# 3200K1, -30 in. Hg-0 psi | High accuracy transducer, 1/2" male NPT, 316 SS, -40 to 212°F, < 0.25% accuracy, 10-30 VDC, 2 wire, 4-20 mA |

Notes:

AC - alternating current
CPVC - chlorinated polyvinyl chloride
DC - direct current
ETFE - ethylene tetrafluoroethylene
FTO - flameless thermal oxidizer
NPT - national pipe thread
NPTF - national pipe thread, female
P&ID - piping and instrumentation diagram
PLC - programmable logic controller

PVC - polyvinyl chloride
PVDF - polyvinylidene fluoride
SPDT - single pole, double throw
SS - stainless steel
TDH - total dynamic head
TEFC - totally enclosed, fan-cooled
TYP - typical
VC - vapor conditioning

acfm - actual cubic feet per minute
Btu/h - British thermal units per hour
cfm - cubic feet per minute
dBA - A-weighted decibels
gph - gallons per hour
gpm - gallons per minute
hp - horsepower
in. Hg - inches of mercury
in. wc - inches of water column

mmHg - millimeters of mercury
°F - degree Fahrenheit
ppm - part per million
psi - pounds per square inch
psig - pounds per square inch gauge
rpm - revolutions per minute
scfm - standard cubic feet per minute
V - volt

Table 2.2
Extraction Well Specifications
Pemaco Superfund Site, Maywood, CA

| Well ID | Associated Hydrogeologic Unit | Casing Diameter (inches) | Screen Material | Well Casing Material | Screen Interval (feet bgs) | Screen Slot Size (inches) | Screen Length (feet) | Filter Pack Sand Size | Total Depth of Well (feet bgs) |
|---------|-------------------------------|--------------------------|---------------------|----------------------|----------------------------|---------------------------|----------------------|-----------------------|--------------------------------|
| PA-1 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 17 - 27 | 0.020 | 10 | 2/12 | 30 |
| PA-2 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 22 - 32 | 0.020 | 10 | 2/12 | 35 |
| PA-3 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 22 - 32 | 0.020 | 10 | 2/12 | 35 |
| PA-4 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 20 - 30 | 0.020 | 10 | 2/12 | 30 |
| PA-5 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 20 - 30 | 0.020 | 10 | 2/12 | 30 |
| PB-1 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 26 - 36 | 0.020 | 10 | 2/12 | 40 |
| PB-2 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 22 - 32 | 0.020 | 10 | 2/12 | 35 |
| PB-3 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 22 - 32 | 0.020 | 10 | 2/12 | 35 |
| PB-4 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 16 - 26 | 0.020 | 10 | 2/12 | 30 |
| PB-5 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 24 - 34 | 0.020 | 10 | 2/12 | 35 |
| PB-6 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 22 - 32 | 0.020 | 10 | 2/12 | 35 |
| PB-7 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 24 - 34 | 0.020 | 10 | 2/12 | 35 |
| PC-1 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 15 - 25 | 0.020 | 10 | 2/12 | 25 |
| PC-2 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 17 - 27 | 0.020 | 10 | 2/12 | 30 |
| PC-5 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 29 - 39 | 0.020 | 10 | 2/12 | 40 |
| PC-6 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 28 - 38 | 0.020 | 10 | 2/12 | 40 |
| PD-1 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 17 - 27 | 0.020 | 10 | 2/12 | 30 |
| PD-4 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 27 - 37 | 0.020 | 10 | 2/12 | 40 |
| PD-5 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 27 - 37 | 0.020 | 10 | 2/12 | 40 |
| PD-6 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 24 - 34 | 0.020 | 10 | 2/12 | 35 |
| PD-7 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 26 - 36 | 0.020 | 10 | 2/12 | 40 |
| PD-8 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 26 - 36 | 0.020 | 10 | 2/12 | 37 |
| PD-9 | Perched Zone | 4 | Schedule 40 PVC | Schedule 40 PVC | 28 - 38 | 0.020 | 10 | 2/12 | 40 |
| DA-1 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 61 - 76 | 0.020 | 15 | 2/12 | 77 |
| DA-2 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 72 - 82 | 0.020 | 10 | 2/12 | 83 |
| DA-3 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 74 - 84 | 0.020 | 10 | 2/12 | 85 |
| DA-4 | A Zone | 6 | 316 Stainless Steel | Low Carbon Steel | 56 - 66 | 0.020 | 10 | 2/12 | 67 |
| DA-5 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 68 - 78 | 0.020 | 10 | 2/12 | 80 |
| DA-6 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 60-70 | 0.020 | 10 | 2/12 | 71 |
| DA-7 | A Zone | 6 | 316 Stainless Steel | Schedule 40 PVC | 61 - 71 | 0.020 | 10 | 2/12 | 72 |
| DA-8 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 65 - 75 | 0.020 | 10 | 2/12 | 76 |
| DA-9 | A Zone | 6 | 316 Stainless Steel | Schedule 80 PVC | 66 - 76 | 0.020 | 10 | 2/12 | 77 |
| DA-10 | A Zone | 6 | 316 Stainless Steel | Low Carbon Steel | 66 - 76 | 0.020 | 10 | 2/12 | 77 |
| DA-11 | A Zone | 6 | 316 Stainless Steel | Low Carbon Steel | 64 - 74 | 0.020 | 10 | 2/12 | 76 |
| DA-12 | A Zone | 6 | Schedule 40 PVC | Schedule 40 PVC | 66 - 76 | 0.020 | 10 | 2/12 | 77 |
| DAB-1 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 70 - 90 | 0.020 | 20 | 2/12 | 91 |
| DAB-2 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 70 - 90 | 0.020 | 20 | 2/12 | 91 |
| DAB-3 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 68.5 - 88.5 | 0.020 | 20 | 2/12 | 89.5 |
| DAB-4 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 66 - 86 | 0.020 | 20 | 2/12 | 87 |
| DAB-5 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 69 - 89 | 0.020 | 20 | 2/12 | 90 |
| DAB-6 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 67 - 87 | 0.020 | 20 | 2/12 | 88 |
| DAB-7 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 68 - 88 | 0.020 | 20 | 2/12 | 89 |
| DAB-8 | A & B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 65 - 85 | 0.020 | 20 | 2/12 | 86 |
| DB-1 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 83 - 93 | 0.020 | 10 | 2/12 | 94 |
| DB-2 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 86 - 96 | 0.020 | 10 | 2/12 | 97 |
| DB-3 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 77 - 87 | 0.020 | 10 | 2/12 | 88 |
| DB-4 | B Zone | 6 | 316 Stainless Steel | Low Carbon Steel | 75 - 85 | 0.020 | 10 | 2/12 | 86 |
| DB-5 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 80 - 90 | 0.020 | 10 | 2/12 | 90 |
| DB-6 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 80 - 90 | 0.020 | 10 | 2/12 | 91 |
| DB-7 | B Zone | 6 | 316 Stainless Steel | Schedule 80 PVC | 81 - 91 | 0.020 | 10 | 2/12 | 92 |
| DB-8 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 81 - 91 | 0.020 | 10 | 2/12 | 92 |
| DB-9 | B Zone | 6 | 316 Stainless Steel | Schedule 80 PVC | 84 - 94 | 0.020 | 10 | 2/12 | 94 |
| DB-10 | B Zone | 6 | 316 Stainless Steel | Low Carbon Steel | 81 - 91 | 0.020 | 10 | 2/12 | 92 |
| DB-11 | B Zone | 6 | 316 Stainless Steel | Low Carbon Steel | 76 - 86 | 0.020 | 10 | 2/12 | 87 |
| DB-12 | B Zone | 6 | Schedule 80 PVC | Schedule 80 PVC | 83.5 - 93.5 | 0.020 | 10 | 2/12 | 94.5 |

Table 2.2
Extraction Well Specifications
Pemaco Superfund Site, Maywood, CA

| Well ID | Associated Hydrogeologic Unit | Casing Diameter (inches) | Screen Material | Well Casing Material | Screen Interval (feet bgs) | Screen Slot Size (inches) | Screen Length (feet) | Filter Pack Sand Size | Total Depth of Well (feet bgs) |
|---------|-------------------------------|--------------------------|------------------|----------------------|----------------------------|---------------------------|----------------------|-----------------------|--------------------------------|
| VR-01LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 37 - 47 | 0.020 | 10 | 2/12 | 47.6 |
| VR-02LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 39 - 49 | 0.020 | 10 | 2/12 | 49.7 |
| VR-02P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 20 | 2/12 | 34.5 |
| VR-03LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.5 |
| VR-04LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 39 - 49 | 0.020 | 10 | 2/12 | 49.9 |
| VR-04P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 23 - 33 | 0.020 | 10 | 2/12 | 33.5 |
| VR-05LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.5 |
| VR-05P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 25 - 35 | 0.020 | 10 | 2/12 | 35.3 |
| VR-06LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 39 - 49 | 0.020 | 10 | 2/12 | 49.8 |
| VR-07LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.6 |
| VR-07P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 10 | 2/12 | 34.6 |
| VR-08LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.5 |
| VR-09LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.4 |
| VR-10LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.0 |
| VR-10P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 10 | 2/12 | 34.6 |
| VR-11LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.5 |
| VR-11P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 10 | 2/12 | 34.9 |
| VR-12LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.0 |
| VR-12P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 10 | 2/12 | 34.7 |
| VR-13LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.5 |
| VR-14LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.0 |
| VR-15LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.2 |
| VR-16LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.5 |
| VR-17LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 39 - 49 | 0.020 | 10 | 2/12 | 49.9 |
| VR-17P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 10 | 2/12 | 34.8 |
| VR-18LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.0 |
| VR-18P | Perched Zone | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 24 - 34 | 0.020 | 10 | 2/12 | 34.8 |
| VR-19LV | Lower Vadose | 2 | Schedule 80 CPVC | Schedule 80 CPVC | 40 - 50 | 0.020 | 10 | 2/12 | 50.0 |

Notes:

CPVC - chlorinated polyvinyl chloride

PVC - polyvinyl chloride

VR - vapor recovery

feet bgs - feet below ground surface

Table 3.1
Field Form Summary
Pemaco Superfund Site, Maywood, CA

| Form Number | Form Title | Description | Collection Frequency |
|-------------|--|--|----------------------|
| 1 | Manifold / LEL Instrument Measurement | Includes daily manifold status (differential pressure, temperature, and vacuum), PID readings, and MultiRAE Plus PGM-50 readings (VOC, LEL, H ₂ S, CO, and oxygen) | Daily and Weekly |
| 2 | Field Input Form for Process Physical Parameters Gauges and Sampling Ports | Contains primary gauge readings collected in the treatment plant, including vacuum, pressure, and temperature | Daily and Weekly |
| 3 | Field Input Form for Process Physical Parameters from PLC and Manual | Includes utility meter readings, flow totalizer readings, and major operating parameters in the SCADA computer, including pressure, vacuum flow, and temperature | Daily |
| 4 | Daily Vapor Sampling | SP-102 daily vapor influent sampling record | Daily |
| 5 | Weekly Vapor Sampling | Weekly vapor sampling record, including sample port SP-102, 104, 106, 108 through 117, 801 through 805, and SP-900 (trip blank) | Weekly |
| 6 | Weekly Process Water Sampling | Weekly process water sampling record, including sample port SP-201, 204, 206, 208, 210, and 212-215 | Weekly |
| 7 | Field Input Form for VR Wells | Contains ERH VR Well field data such as PID readings, temperature, vacuum, and valve status | Weekly during ERH |
| 8 | Field Input Form for Electrode Wells | Contains ERH Electrode Well field data such as PID readings, temperature, vacuum, and valve status | Weekly |
| 9 | Field Input Form for Temperature Thermocouple 10% Validation | ERH Temperature Thermocouple validation readings collected at depth | 2 TMPs once a week |
| 10 | Field Input Form for VMPs | ERH VMP field data record Data includes vacuum, PID/Draeger readings, and sampling method | Monthly during ERH |
| 11 | Groundwater Monitoring within ERH Area | ERH groundwater sampling | Biweekly during ERH |
| 12 | Well Valve Operations - Perched Wells | Contains perched well operation parameters collected in the field, including valve positions, water levels, vacuums, PID readings, temperatures, and air/water flows | Weekly |
| 13A | Well Valve Operations - Exposition Wells - Operation and Maintenance | Shows Exposition Wells valve positions | Weekly |
| 13B | Well Valve Operations - Exposition Wells - Physical Measurements | Includes Exposition Wells physical measurements collected in the field, including water level, water temperature, vacuum, and pump pulse count | Weekly |
| 14 | Field Input Form for Sentry Soil Vapor (SSV) Probes | Includes SSV probe PID readings collected in the field. A subset of SSVs are currently being sampled but all were sampled during the baseline event and are sampled as needed. | Weekly and Monthly |

Notes:

CO - carbon monoxide
ERH - electrical resistance heating
H₂S - hydrogen sulfide
LEL - lower explosive limit
PID - photoionization detector
PLC - programmable logic controller
SCADA - supervisory control and data acquisition
SSV - sentry soil vapor
TMP - temperature monitoring probe
VMP - vapor monitoring probe
VOC - volatile organic compound
VR - vapor recovery

Table 3.2
Vapor Extraction Well Field Sampling Data
Pemaco Superfund Site, Maywood, CA

| Well ID | Total Depth (feet bgs) | Average Vacuum ¹ (in. Hg) | Average PID ¹ (ppm) | Average Temperature ¹ (°F) |
|----------|---------------------------|--|--------------------------------------|---|
| PA-01 | 30 | 14.3 | 0.2 | 76.3 |
| PA-02* | 35 | 13.6 | 2.4 | 70.1 |
| PA-03 | 35 | 13.4 | 480.4 | 78.1 |
| PA-04 | 30 | 12.9 | 56.4 | 73.6 |
| PA-05 | 30 | 12.5 | 976.5 | 78.6 |
| PB-01 | 40 | 7.5 | 104.5 | 75.3 |
| PB-02 | 35 | 7.6 | 0.8 | 79.7 |
| PB-03 | 35 | 11.0 | 0.4 | 74.7 |
| PB-04 | 30 | 6.3 | 2.5 | 73.5 |
| PB-05 | 35 | 4.1 | 0.6 | 74.2 |
| PB-06* | 35 | 5.3 | 0.0 | 73.6 |
| PB-07 | 35 | 7.4 | 0.9 | 77.9 |
| PC-01 | 25 | 10.1 | 0.6 | 71.7 |
| PC-02 | 30 | 13.4 | 0.4 | 77.7 |
| PC-05 | 40 | 6.6 | 0.9 | 74.1 |
| PC-06 | 40 | 7.2 | 0.0 | 72.4 |
| PD-01 | 30 | 11.5 | 19.5 | 76.1 |
| PD-04 | 40 | 5.7 | 35.4 | 68.9 |
| PD-05 | 40 | 5.5 | 8.2 | 75.8 |
| PD-06 | 35 | 7.6 | 1.3 | 76.8 |
| PD-07 | 40 | 9.5 | 1.2 | 71.4 |
| PD-08 | 37 | 4.5 | 4.3 | 76.1 |
| PD-09 | 40 | 9.1 | 0.3 | 73.1 |
| DA-01 | 77 | 0.6 | NC | 77.6 |
| DA-02 | 83 | 0.4 | NC | 82.3 |
| DA-03 | 85 | 0.4 | NC | 81.7 |
| DA-04 ** | 67 | 0.0 | NC | 72.8 |
| DA-05 | 80 | 1.3 | NC | 68.1 |
| DA-06 | 71 | 1.5 | NC | 82.2 |
| DA-07 | 72 | 1.2 | NC | 72.8 |
| DA-08 | 76 | 1.4 | NC | 80.0 |
| DA-09 | 77 | 0.8 | NC | 76.0 |
| DA-10 ** | 77 | 2.0 | NC | 79.6 |
| DA-11 ** | 76 | 2.3 | NC | 72.5 |
| DA-12 | 77 | 2.5 | NC | 83.2 |
| DAB-01 | 91 | 1.2 | NC | 78.1 |
| DAB-02 | 91 | 1.0 | NC | 85.1 |
| DAB-03 | 89.5 | 1.3 | NC | 80.5 |
| DAB-04 | 87 | 1.2 | NC | 82.5 |
| DAB-05 | 90 | 1.2 | NC | 80.7 |
| DAB-06 | 88 | 1.5 | NC | 77.3 |
| DAB-07 | 89 | 1.2 | NC | 78.9 |
| DAB-08 | 86 | 1.6 | NC | 78.5 |
| DB-01 | 94 | 0.5 | NC | 76.3 |
| DB-02 | 97 | 1.4 | NC | 80.0 |

Table 3.2
Vapor Extraction Well Field Sampling Data
Pemaco Superfund Site, Maywood, CA

| Well ID | Total Depth (feet bgs) | Average Vacuum (in. Hg) | Average PID (ppm) | Average Temperature (°F) |
|----------|---------------------------|-------------------------------|-------------------------|--------------------------------|
| DB-03 | 88 | 0.9 | NC | 81.3 |
| DB-04 ** | 86 | 1.8 | NC | 73.0 |
| DB-05 | 90 | 2.0 | NC | 78.3 |
| DB-06 | 91 | 2.4 | NC | 81.1 |
| DB-07 | 92 | 1.2 | NC | 75.4 |
| DB-08 | 92 | 2.2 | NC | 81.2 |
| DB-09 | 94 | 0.9 | NC | 75.8 |
| DB-10 ** | 92 | 1.4 | NC | 86.3 |
| DB-11 ** | 87 | 1.3 | NC | 80.7 |
| DB-12 | 94.5 | 1.4 | NC | 79.6 |
| VR-01LV | 47.6 | 14.1 | 2.6 | 91.1 |
| VR-02LV | 49.7 | 13.6 | 10.8 | 107.1 |
| VR-02P | 34.5 | 13.4 | 3.9 | 102.1 |
| VR-03LV | 50.5 | 13.4 | 13.1 | 109.1 |
| VR-04LV | 49.9 | 12.7 | 406.2 | 105.1 |
| VR-04P | 33.5 | 11.6 | 15.6 | 101.8 |
| VR-05LV | 50.5 | 13.1 | 92.1 | 113.7 |
| VR-05P | 35.3 | 23.8 | 45.9 | 108.4 |
| VR-06LV | 49.8 | 13.5 | 88.1 | 126.3 |
| VR-07LV | 50.6 | 13.4 | 113.1 | 120.3 |
| VR-07P | 34.6 | 13.2 | 3.7 | 108.4 |
| VR-08LV | 50.5 | 12.8 | 227.7 | 95.3 |
| VR-09LV | 50.4 | 13.4 | 312.7 | 115.2 |
| VR-10LV | 50.0 | 13.4 | 72.7 | 111.6 |
| VR-10P | 34.6 | 13.2 | 15.7 | 80.7 |
| VR-11LV | 50.5 | 13.1 | 59.8 | 111.5 |
| VR-11P | 34.9 | 12.5 | 2.1 | 97.8 |
| VR-12LV | 50.0 | 13.6 | 81.3 | 89.5 |
| VR-12P | 34.7 | 13.1 | 3.8 | 162.5 |
| VR-13LV | 50.5 | 14.2 | 171.8 | 99.7 |
| VR-14LV | 50.0 | 14.1 | 12.4 | 87.7 |
| VR-15LV | 50.2 | 14.3 | 31.7 | 91.5 |
| VR-16LV | 50.5 | 13.5 | 10.7 | 116.1 |
| VR-17LV | 49.9 | 13.8 | 4.9 | 83.3 |
| VR-17P | 34.8 | 13.6 | 2.1 | 88.6 |
| VR-18LV | 50.0 | 14.0 | 3.6 | 86.0 |
| VR-18P | 34.8 | 13.8 | 1.6 | 78.5 |
| VR-19LV | 50.0 | 59.0 | 6.1 | 94.3 |

Notes:

1 - Averages were calculated using all field data that was collected in 2007 when well was operational.

Temperature data were collected with an infrared gun and are considered to be biased high for all vaulted wells (all perched and exposition wells).

* - Remote vault

** - Well located in the ERH area

LV - lower vadose; P - perched zone; VR - vapor recovery

°F - degree Fahrenheit; in. Hg - inches of mercury; ppm - part per million by volume

NC - not collected since vapors were not extracted from these wells for most of 2007 with exception of DA-4, DA-5, DA-10, and DA-11

feet bgs - feet below ground surface

Table 3.3
Vapor Extraction Manifold Sampling Data
Pemaco Superfund Site, Maywood, CA

| Manifold ¹ | Average Vacuum (in. Hg) | Average Differential Pressure (in. wc) | Average Concentrations ² | | | | | Average Temperature (°F) | Average Flow Rate ⁴ (scfm) |
|-----------------------|----------------------------|---|-------------------------------------|---------------------------|------------|-----------------------|---------------------------|-----------------------------|--|
| | | | CO (%) | H ₂ S (ppm) | LEL (%) | O ₂ (%) | PID ⁵ (ppm) | | |
| DPE-A | 16.2 | 0.1 | 1.1 | 0.0 | 14.8 | 19.4 | 758.3 | 74.4 | 107.8 |
| DPE-B | 16.4 | 0.1 | 0.8 | 0.0 | 4.5 | 20.1 | 34.8 | 69.6 | 107.5 |
| DPE-C | 16.8 | 0.1 | 1.0 | 0.0 | 3.3 | 20.1 | 16.4 | 72.9 | 105.6 |
| DPE-D | 16.3 | 0.1 | 0.7 | 0.0 | 16.5 | 18.5 | 55.1 | 70.0 | 107.9 |
| VE-1 ³ | NC | NC | NC | NC | NC | NC | NC | NC | NC |
| VE-2 | 16.4 | 0.07 | NC | NC | NC | NC | NC | 69.5 | 90.0 |
| VE-3 | 16.9 | 0.9 | 11.9 | 0.1 | 10.6 | 18.7 | 466.4 | 75.6 | 314.8 |
| VE-4 | 16.0 | 0.07 | 69.0 | 13.0 | 44.0 | 19.0 | 2582.0 | 95.0 | 89.2 |
| TRS Condenser | 16.7 | 1.2 | NC | NC | NC | NC | NC | 77.2 | 365.7 |

Notes:

1 - Vapor Manifold Summary:

DPE-A: 5 wells (PA-1 through PA-5)

DPE-B: 7 wells (PB-1 through PB-7)

DPE-C: 4 wells (PC-1, PC-4 through PC-6)

DPE-D: 7 wells (PD-1, PD-4 through PD-9)

VE-1: 7 wells (DAB-1 through DAB-7)

VE-2: 15 wells (DAB-8, DA/DB-1 through DA/DB-7)

VE-3: 6 Pemaco deep wells (DA/DB-8 through DA/DB-10) and ERH Wells

VE-4: 4 Pemaco deep wells (DA/DB-11 through DA/DB-12) and ERH Wells

2 - Averages were calculated using all field data that was collected in 2007 when the manifold was operational with the exception of the flow rate for VE-2 and VE-4, which includes only data from January 2008.

3 - VE-1 was not operated because: 1) flow capacity needed for perched zone wells and ERH area and 2) would not facilitate mass removal since the wells on VE-1 are farthest downgradient

4 - Average flow rate was calculated using data collected via pitot tube method. Due to varying field and plant operational conditions, accuracy is estimated to be +/- 30%. The flow reported for VE-2 and VE-4 is representative of only 4 wells: DA-4 and DA-5 for VE-2; and DA-10 and DA-11 for VE-4.

5 - PID was calibrated for 100 ppm Isobutylene gas before each measurement.

CO - carbon monoxide

°F - degree Fahrenheit

ERH - electrical resistance heating

in. Hg - inches of mercury

H₂S - hydrogen sulfide

in. wc - inches of water column

LEL - lower explosive limit

ppm - part per million by volume

NC - not collected

scfm - standard cubic feet per minute

O₂ - oxygen

PID - photoionization detector

TRS - Thermal Remediation Systems

Table 3.4
Vapor Sampling Ports
Pemaco Superfund Site, Maywood, CA

| Station ID | Monitoring Location | Analyte or Parameter | Laboratory ² | Frequency | Sample Type | Purpose of Data Collection; Data Use |
|-----------------------|--|---|-------------------------|-----------|------------------|--|
| SP-102 | Pre-FTO | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Daily | Grab | Pre-treatment concentrations to determine VOC mass removal rates |
| | | Light hydrocarbons by TO-3(M) | Calscience | Weekly | Grab | |
| SP-104 | Post FTO, pre-GAC; Post-Chiller | VOCs by TO-15 | EPA Region 9 Lab | Weekly | Grab | To evaluate VOC mass removal rates for analytes not included on TO-15SIM list |
| | | VOCs by TO-15SIM | Air Toxics | Weekly | Grab | To confirm calculated VOC mass removal rates; monitor system efficiency, determine when FTO is no longer needed in treatment chain |
| SP-104a | Post FTO, pre-GAC; Post-Chiller | VOCs by TO-15SIM | Air Toxics | As needed | 1-hour Composite | To confirm calculated VOC mass removal rates; monitor system efficiency, determine when FTO is no longer needed in treatment chain |
| | | Dioxin/Furans by CARB 428 | Vista | As needed | 1-hour Composite | Monitor for possible FTO-related emissions of dioxins, furans |
| SP-106 | Post-Primary GAC Vessel | VOCs by TO-15 | EPA Region 9 Lab | Weekly | Grab | To evaluate GAC efficiency |
| SP-108 | Post-Secondary GAC Vessel | VOCs by TO-15 | EPA Region 9 Lab | Weekly | Grab | |
| SP-109 | FTO/GAC outlet - final effluent | VOCs by TO-15 | EPA Region 9 Lab | Weekly | Grab | To evaluate VOC mass removal rates for analytes not included on TO-15SIM list |
| | | VOCs by TO-15SIM | Air Toxics | Weekly | Grab | To confirm calculated VOC mass removal rates; monitor system efficiency |
| SP-109a | FTO/GAC outlet - final effluent | VOCs by TO-15SIM | Air Toxics | As needed | 1-hour Composite | To confirm calculated VOC mass removal rates; monitor system efficiency |
| | | Dioxin/Furans by CARB 428 | Vista | As needed | 1-hour Composite | Monitor for possible FTO/GAC-related emissions of dioxins, furans |
| SP-110 | West Trench Wells* DAB-8, DA/DB-1 to DA/DB-7 (15 wells) | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-111 | Wells* PA-1 to PA-5 (5 wells) | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-112 | Wells* PB-1 to PB-7 (7 wells) | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-113 | Wells* PD-1, PD-4 to PD-9 (7 wells) | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-114 | Wells* PC-1, PC-4 to PC-6 (4 wells) | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-115 | ERH East Trench Wells*; DA/DB-7 to DA/DB-10 (6 wells); 58 electrodes & 19 VRs | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-116 | ERH East Trench Wells*; DA/DB-11 to DA/DB-12 (4 wells); 58 electrodes & 19 VRs** | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-117 | South Trench Wells* DAB-1 to DAB-7 (7 wells) | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | Evaluate well field performance; monitor system operational efficiency |
| SP-801 through SP-805 | Five (5) sectors of 28 VR wells, 58 electrode wells, and 21 VMPs within ERH area** | TCE, 2 - 6 highest VOCs by TO-15 ¹ | EPA Region 9 Lab | Weekly | Grab | ERH sector performance/efficacy; heating optimization among sectors |

Notes:

1 - 2-6 highest VOC levels to be within the calibration range; reporting will include % of the highest peaks in the sample based on the chromatogram.

2 - Air Toxics - Air Toxics Ltd. is located in Folsom, CA.

Calscience - Calscience Environmental Laboratories, Inc. is located in Garden Grove, CA.

EPA Region 9 Lab - the EPA Region 9 Laboratory is located in Richmond, CA.

Vista - Vista Analytical Laboratory is located in El Dorado Hills, CA.

* See Figure 1.2 for well locations; ** See Figure 1.3 for well locations.

CARB - California Air Resources Board

DPE - dual-phase extraction

EPA - United States Environmental Protection Agency

ERH - electrical resistance heating

FTO - flameless thermal oxidizer

GAC - granular activated carbon

SIM - selective ion mode

SP - sample port

TCE - trichloroethene

VMP - vapor monitoring probe

VOCs - volatile organic compounds

VR - vapor recovery

Table 3.5
VOC Analytical Results for the Vapor Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | m,p-Xylene | n-Hexane | o-Xylene | Propylene | Styrene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Trichlorofluoromethane | | |
|----------------|------------|------------|-------|--------------------|--------------------|-------------|------------|---------|---------|------------------|------------|---------------|------------------------|-------------|--------------|------------|----------|----------|-----------|---------|-------------------|-----------------|----------|--------------------------|-----------------|------------------------|---------|--|
| Description | Station ID | Date | Units | | | | | | | | | | | | | | | | | | | | | | | | | |
| VE-1 Manifold | SP-117 | 5/31/2007 | ppbv | 3 U | 3 U | 3 U | -- | 870 | 3 U | 9 | 8 | 3 U | 6 J | -- | 3 U | 7 U | 14 | 3 U | 6 J | 3 U | 3 U | 16,000 | 8 | 3 U | 230 | 3 U | | |
| VE-2 Manifold | SP-110 | 5/31/2007 | ppbv | 17 U | 17 U | 17 U | -- | 980 | 17 U | 17 U | 17 U | 17 U | 17 U | -- | 17 U | 33 U | 47 | 17 U | 17 U | 17 U | 17 U | 30,000 | 18 J | 17 U | 170 | 17 U | | |
| VE-3 Manifold | SP-115 | 5/31/2007 | ppbv | 16 U | 60 | 16 U | -- | 16 U | 16 U | 16 U | 16 U | 16 U | 310 | -- | 16 U | 33 U | 420 | 16 U | 68 | 16 U | 23 J | 37 | 16 U | 16 U | 4,200 | 16 U | | |
| | | 7/31/2007 | ppbv | 5,400 U | 5,400 U | 5,400 UJ | -- | 5,400 U | 5,400 U | 5,400 U | 5,400 U | 5,400 U | 5,800 J | 5,400 U | 5,400 U | 1,1,000 U | 38,000 | 5,400 U | 5,400 U | 5,400 U | 5,400 U | 5,400 U | 5,400 U | 5,400 U | 33,000 | 5,400 U | | |
| | | 8/7/2007 | ppbv | 1,100 U | 1,100 UJ | 1,100 U | -- | 1,100 U | 1,100 U | 1,100 U | 1,100 U | 1,100 U | 1,100 U | 27,000 | 1,100 U | 2,200 U | 20,000 J | 1,100 U | 1,100 U | 1,100 U | 1,100 U | 1,100 U | 1,100 U | 55,000 J | 1,100 U | 2 | 1,100 U | |
| | | 8/14/2007 | ppbv | 1.3 U | 2.4 J | 3.6 | -- | 24 J | 1.7 J | 1.3 U | 1.3 U | 1.3 U | 6.2 | 31 | 1.5 J | 3.8 J | 440 | 1.9 J | 2 J | 2.2 J | 1.3 U | 230 | 39 | 1.3 U | 20 J | 1.3 U | | |
| | | 9/5/2007 | ppbv | 9.4 U | 34 | 9.4 UJ | 10 J | 25 J | 9.4 U | 37 | 9.4 U | 9.4 U | 45 | 22 | 9.4 U | 19 U | 65 | 9.4 U | 48 | 9.4 U | 31 | 74 | 130 | 9.4 U | 570 | 9.4 U | | |
| | | 9/11/2007 | ppbv | 59 | 520 | 1.6 U | 1.6 U | 1.6 U | 650 | 16 | 71 J | 1.6 U | 2,600 | 14,000 | 84 | 480 | 110,000 | 81 | 38 | 1.6 U | 91 J | 1.6 U | 24,000 | 14 | 3,600 | 1.6 U | | |
| | | 9/18/2007 | ppbv | 68 | 330 | 14 U | 14 UJ | 14 U | 680 | 19 J | 78 | 14 U | 2,100 | 9,500 | 72 | 450 | 110,000 | 91 | 34 | 14 U | 36 | 14 U | 20,000 | 14 U | 2,400 | 14 U | | |
| | | 9/25/2007 | ppbv | 12 U | 12 U | 12 U | 12 UJ | 20 J | 94 | 33 | 12 U | 12 U | 300 | 2,700 | 12 U | 24 U | 30,000 | 12 U | 14 J | 12 U | 12 U | 12 U | 800 | 12 U | 150 | 12 U | | |
| | | 10/1/2007 | ppbv | 270 U | 270 U | 270 U | 270 UJ | 270 U | 560 | 270 U | 270 U | 270 U | 1,300 | 11,000 | 270 U | 540 U | 2 | 270 U | 270 U | 270 U | 270 U | 270 U | 34,000 | 270 U | 1,300 | 270 U | | |
| | | 10/8/2007 | ppbv | 260 U | 260 U | 260 U | 260 UJ | 260 U | 560 | 260 U | 260 U | 260 U | 1,000 | 8,400 | 260 U | 520 U | 110,000 | 260 U | 260 U | 260 U | 260 U | 260 U | 24,000 J | 260 U | 1,100 | 260 U | | |
| | | 10/15/2007 | ppbv | 290 U | 290 U | 290 U | 290 U | 290 U | 530 J | 290 U | 290 U | 290 UJ | 1,200 | 11,000 | 290 U | 580 U | 110,000 | 290 U | 290 U | 290 U | 290 U | 290 U | 19,000 | 290 U | 1,500 J | 290 U | | |
| | | 10/23/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 7.8 J | 28 | 1.6 J | 2.2 J | 1.2 U | 1.2 UJ | 1.2 U | 3.3 | 1.2 U | 2.7 J | 7.5 | 1.2 U | 7.8 | 1.2 U | 1.2 U | 20 | 20 | 1.2 U | 1.6 J | 1.2 U | | |
| | | 10/29/2007 | ppbv | 270 U | 270 U | 270 U | 270 UJ | 270 U | 270 U | 270 U | 270 U | 270 UJ | 690 | 5,000 | 270 U | 550 U | 50,000 | 270 U | 270 U | 270 U | 270 U | 270 U | 7,700 | 270 U | 1,500 | 270 U | | |
| | | 11/7/2007 | ppbv | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 520 J | 5,600 | 270 U | 540 U | 49,000 | 270 U | 270 U | 270 U | 270 U | 270 U | 7,300 | 270 U | 1,600 | 270 U | | |
| | | 11/15/2007 | ppbv | 420 U | 420 U | 420 U | 420 U | 420 U | 420 U | 420 U | 420 U | 420 U | 660 J | 11,000 | 420 U | 850 U | 66,000 | 420 U | 420 U | 420 U | 420 U | 420 U | 6,900 | 420 U | 1,800 | 420 U | | |
| | | 11/20/2007 | ppbv | 200 U | 200 U | 200 U | 200 UJ | 200 U | 200 U | 200 U | 200 U | 200 U | 560 | 7,700 | 200 U | 400 U | 73,000 | 200 U | 200 U | 200 U | 200 U | 200 U | 3,600 | 200 U | 2,800 | 200 U | | |
| | | 11/27/2007 | ppbv | 330 U | 330 U | 330 U | 330 U | 330 U | 330 U | 330 U | 330 U | 330 U | 410 J | 5,900 | 330 U | 660 U | 58,000 | 330 U | 330 U | 330 U | 330 U | 330 U | 2,100 | 330 U | 1,300 | 330 U | | |
| | | 12/4/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 450 J | 5,500 | 250 U | 490 U | 54,000 | 250 U | 250 U | 250 U | 250 U | 250 U | 2,600 | 250 U | 2,100 | 250 U | | |
| 12/11/2007 | ppbv | 2.1 U | 2.1 U | 2.1 UJ | 2.1 UJ | 42 | 2.1 U | 2.1 U | 2.1 U | 2.1 U | 2.1 U | 8.6 | 2.1 U | 6.9 J | 56 | 2.7 J | 4.9 | 2.1 U | 2.1 U | 2.1 U | 93 | 2.1 U | 26 | 2.1 U | | | | |
| 12/20/2007 | ppbv | 220 U | 220 U | 220 UJ | 220 UJ | 430 J | 220 U | 220 U | 220 U | 220 U | 560 | 4,500 | 220 U | 450 U | 44,000 | 220 U | 48,000 | 220 U | 220 U | 220 U | 2,700 | 220 U | 3,200 | 220 U | | | | |
| 12/27/2007 | ppbv | 250 U | 250 U | 250 U | 250 UJ | 250 U | 250 U | 250 U | 250 U | 250 U | 430 J | 3,500 | 250 U | 500 U | 33,000 | 250 U | 250 U | 250 U | 250 U | 250 U | 1,800 | 250 U | 3,400 | 250 U | | | | |
| VE-4 Manifold | SP-116 | 5/31/2007 | ppbv | 14 U | 31 | 14 U | -- | 20 J | 14 U | 110 | 14 U | 14 U | 190 | | 14 U | 29 U | 82 | 14 U | 450 | 14 U | 17 J | 520 | 14 U | 31 | 18,000 | 14 U | | |
| | | 9/5/2007 | ppbv | 2.8 U | 2.8 U | 2.8 U | | 210 | 310 | 2.8 U | 2.8 U | 2.8 U | 4.1 J | 2.8 U | 2.8 U | 5.7 U | 20 | 2.8 U | 2.8 U | 2.8 U | 2.8 U | 640 | 32 | 2.8 U | 7.1 | 2.8 U | | |
| | | 9/18/2007 | ppbv | 0.8 U | 0.8 U | 0.8 U | 14 J | 14 | 5.5 | 1.4 J | 0.8 U | 0.8 U | 23 | 31 | 1.8 | 13 | 290 | 3 | 1.5 J | 0.8 U | 0.8 U | 73 | 350 | 0.8 U | 30 | 0.8 U | | |
| | | 10/23/2007 | ppbv | 2.3 U | 2.3 U | 2.3 U | 2.3 UJ | 36 | 2.3 U | 3.4 J | 2.3 U | 2.3 UJ | 2.3 U | 6.7 | 2.3 U | 5.7 J | 46 | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 15 | 31 | 2.3 U | 3.5 J | 2.3 U | | |
| | | 10/29/2007 | ppbv | 270 U | 270 U | 270 U | 270 UJ | 270 U | 280 J | 270 U | 270 U | 270 UJ | 690 | 6,800 | 270 U | 540 U | 82,000 | 270 U | 270 U | 270 U | 270 U | 270 U | 10,000 | 270 U | 2,000 | 270 U | | |
| DPE-A Manifold | SP-111 | 5/31/2007 | ppbv | 34 U | 34 U | 34 U | -- | 34 U | 34 U | 99 | 34 U | 34 U | 34 U | -- | 34 U | 68 U | 220 | 34 U | 34 U | 34 U | 34 U | 790 | 300 | 34 U | 190 | 34 U | | |
| | | 6/5/2007 | ppbv | 3,200 U | 3,200 U | 3,200 U | -- | 3,200 U | 3,200 U | 3,200 U | 3,200 U | 3,200 U | 5100 J | -- | 3,200 U | 6,500 U | 300,000 | 3,200 U | 3,200 U | 3,200 U | 3,200 U | -- | 3,200 U | 3,200 U | 29,000 | 3,200 U | | |
| | | 6/14/2007 | ppbv | 3.6 U | 3.6 U | 3.6 U | -- | 3.6 U | 23 | 20 | 3.6 U | 3.6 U | 3,300 | 24,000 | 8 | 23 | 140,000 | 3.6 U | 200 | 3.6 U | 33 | -- | 3,300 | 110 | 20,000 | 3.6 U | | |
| | | 6/19/2007 | ppbv | 4,000 UJ | 4,000 U | 4,000 UJ | -- | 4,000 U | 4,000 U | 4,000 U | 4,000 U | 4,000 U | 22,000 | 4,000 U | 7,900 U | 160,000 | 4,000 U | 5,400 J | 4,000 U | 4,000 U | -- | 4,500 J | 4,000 U | 14,000 | 4,000 U | | | |
| | | 7/11/2007 | ppbv | 2,700 U | 2,700 U | 2,700 U | -- | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 14,000 | 2,700 U | 5,400 U | 110,000 | 2,700 U | 2,700 U | 2,700 U | 2,700 U | -- | 11,000 | 2,700 U | 11,000 | 2,700 U | | | |
| | | 7/17/2007 | ppbv | 2,700 U | 2,700 U | 2,700 UJ | -- | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 12,000 | 2,700 U | 5,400 U | 94,000 | 2,700 U | 2,700 U | 2,700 U | 2,700 U | -- | 11,000 | 2,700 U | 6,600 | 2,700 U | | | |
| | | 7/25/2007 | ppbv | 1,200 U | 1,200 U | 1,200 UJ | -- | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 5,600 | 1,200 U | 2,300 U | 37,000 | 1,200 U | 1,200 U | 1,200 U | 1,200 U | -- | 2 | 1,200 U | 4,200 | 1,200 U | | | |
| | | 7/31/2007 | ppbv | 1,300 U | 1,300 U | 1,300 UJ | -- | 1,300 U | | | | | | | | | | | | | | | | | | | | |

Table 3.5
VOC Analytical Results for the Vapor Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | m,p-Xylene | n-Hexane | o-Xylene | Propylene | Styrene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Trichlorofluoromethane | |
|-------------------|------------|------------|-------|--------------------|--------------------|-------------|------------|---------|---------|------------------|------------|---------------|------------------------|-------------|--------------|------------|----------|----------|-----------|---------|-------------------|-----------------|---------|--------------------------|-----------------|------------------------|--|
| Description | Station ID | Date | Units | | | | | | | | | | | | | | | | | | | | | | | | |
| DPE-B Manifold | SP-112 | 5/31/2007 | ppbv | 7.6 U | 7.6 U | 7.6 U | -- | 7.6 U | 9.8 J | 43 | 7.6 U | 7.6 U | 7.6 U | -- | 7.6 U | 15 U | 97 | 7.6 U | 8.6 J | 7.6 U | 7.6 U | 13 J | 250 | 7.6 U | 120 | 7.6 U | |
| | | 6/5/2007 | ppbv | 2.9 J | 1.6 U | 1.6 U | -- | 4 | 62 | 12 | 1.6 U | 1.6 U | 41 | 1.6 U | 1.6 U | 3.3 U | 2,000 | 1.6 U | 1.7 | 1.6 U | 15 | -- | 14 | 1.6 U | 240 | 1.6 U | |
| | | 6/14/2007 | ppbv | 7.3 J | 21 | 6.7 U | -- | 93 | 22 | 10 J | 6.7 U | 6.7 U | 69 | 200 | 6.7 U | 13 U | 1,100 J | 6.7 U | 2,000 | 6.7 U | 31 | -- | 8.3 J | 6.7 U | 41 | 6.7 U | |
| | | 6/19/2007 | ppbv | 320 U | 320 U | 320 U | -- | 730 | 320 U | 320 U | 320 U | 320 UJ | 320 U | 320 U | 320 U | 650 U | 880 | 320 U | 880 | 320 U | 320 U | -- | 320 U | 320 U | 320 U | 320 U | |
| | | 7/11/2007 | ppbv | 13 U | 23 J | 13 U | -- | 340 | 15 J | 13 U | 13 U | 13 U | 130 | 210 | 13 U | 33 J | 840 | 17 J | 2,900 | 13 U | 23 J | -- | 290 | 13 U | 62 | 13 U | |
| | | 7/17/2007 | ppbv | 13 | 33 | 5.7 UJ | -- | 380 | 64 | 7.6 J | 5.7 U | 5.7 U | 190 | 310 | 13 | 40 | 780 | 21 | 3,000 | 5.7 U | 31 | -- | 37 | 5.7 U | 62 | 5.7 U | |
| | | 7/25/2007 | ppbv | 7.4 U | 14 J | 7.4 UJ | -- | 170 | 44 | 17 | 7.4 U | 7.4 U | 82 | 120 | 7.4 U | 17 J | 350 J | 9.5 J | 400 | 7.4 U | 13 J | -- | 32 | 7.4 U | 31 | 7.4 U | |
| | | 7/31/2007 | ppbv | 12 U | 73 | 12 U | -- | 160 | 31 | 13 J | 12 U | 12 U | 190 | 250 UJ | 12 U | 25 U | 970 UJ | 12 U | 390 | 12 U | 26 | 950 J | 49 UJ | 12 U | 490 | 12 U | |
| | | 8/7/2007 | ppbv | 9.3 | 37 | 1.6 U | -- | 120 J | 24 J | 22 | 1.7 J | 1.6 U | 170 J | 150 J | 7.1 | 23 | 4,300 J | 11 | 68 J | 1.8 J | 29 | 1,000 J | 1,200 | 3.3 | 100 J | 1.6 U | |
| | | 8/14/2007 | ppbv | 1.3 U | 1.3 U | 8 | -- | 36 J | 1.3 U | 12 | 1.3 U | 1.3 U | 2.2 J | 15 | 1.3 U | 2.7 U | 51 J | 1.3 U | 15 | 1.3 U | 1.3 U | 72 | 10 UJ | 11 | 4.9 | 1.3 U | |
| | | 9/5/2007 | ppbv | 14 U | 16 J | 14 UJ | 14 U | 30 J | 37 | 21 J | 14 U | 14 U | 90 | 120 | 14 U | 27 U | 340 | 14 U | 16 J | 14 U | 20 J | 21 J | 2,200 | 14 U | 42 J | 14 U | |
| | | 9/11/2007 | ppbv | 15 U | 15 U | 15 U | 15 U | 15 U | 22 J | 15 U | 15 U | 15 U | 32 | 84 | 16 J | 36 J | 310 | 15 U | 15 U | 15 U | 34 | 15 U | 3,600 J | 15 U | 31 | 15 U | |
| | | 9/18/2007 | ppbv | 3.8 | 5.5 | 1.3 U | 1.3 UJ | 7.9 J | 27 | 5.5 | 1.3 U | 1.3 U | 41 | 79 | 13 | 30 | 250 | 9.6 | 14 | 1.3 U | 29 | 1.3 U | 3,100 | 1.6 J | 29 | 1.3 U | |
| | | 9/25/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 4.5 J | 16 | 1.3 U | 7 | 1.3 U | 1.3 UJ | 1.3 U | 2.4 J | 1.3 U | 2.7 U | 13 | 1.3 U | 3.7 J | 1.3 U | 1.3 U | 19 | 23 | 1.3 U | 1.3 U | 1.3 U | |
| | | 10/23/2007 | ppbv | 1.1 U | 1.1 U | 1.1 U | 6.4 J | 33 | 2.3 | 2.1 J | 1.1 U | 1.1 UJ | 1.1 U | 5.4 | 1.4 J | 4.9 | 10 | 1.7 J | 7.6 | 1.1 U | 1.1 U | 25 | 40 | 1.1 U | 3.4 | 1.1 U | |
| | | 10/29/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 6.1 J | 5.4 | 31 | 4.3 | 1.3 UJ | 1.3 UJ | 32 | 100 | 1.4 J | 6.9 | 280 | 2 J | 2.2 J | 1.3 U | 14 | 29 | 450 J | 2.9 | 17 | 1.3 U | |
| | | 11/7/2007 | ppbv | 4 U | 4 U | 4 U | 4 UJ | 4 U | 15 | 7.7 J | 4 U | 4 U | 26 | 72 UJ | 5.2 J | 10 UJ | 200 UJ | 4.2 J | 310 | 4 U | 8.5 | 4 U | 2,700 | 4 U | 26 UJ | 4 U | |
| | | 11/15/2007 | ppbv | 7.2 U | 7.2 U | 7.2 U | 7.2 U | 7.2 U | 14 J | 7.9 J | 7.2 U | 7.2 U | 31 | 160 | 7.2 U | 14 U | 1,400 | 7.2 U | 390 | 7.2 U | 11 J | 7.2 U | 400 | 7.2 U | 29 | 7.2 U | |
| | | 11/20/2007 | ppbv | 6.8 U | 6.8 U | 6.8 U | 6.8 UJ | 6.8 U | 21 | 6.8 U | 6.8 U | 66 | 27 | 99 | 16 | 25 J | 370 J | 9.3 J | 1,800 | 6.8 U | 17 | 6.8 U | 5,700 | 6.8 U | 21 | 6.8 U | |
| | | 11/27/2007 | ppbv | 14 U | 14 U | 14 U | 38 | 31 | 17 J | 15 J | 14 U | 14 U | 34 | 110 | 14 U | 27 U | 470 | 14 U | 1,200 | 14 U | 14 J | 140 | 5,700 | 14 U | 92 | 14 U | |
| | | 12/4/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 3.9 UJ | 3.8 | 1.4 U | 1.4 U | 1.4 U | 4.5 | 8.6 | 1.6 J | 2.9 J | 19 | 1.4 U | 450 | 1.4 U | 2.4 J | 1.4 U | 2,300 | 1.4 U | 3.3 | 1.4 U | |
| | | 12/11/2007 | ppbv | 1.2 U | 1.2 U | 1.2 UJ | 1.2 UJ | 15 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.3 J | 1.2 U | 2.4 U | 7.7 | 1.2 U | 2.9 | 1.2 U | 1.2 U | 6.3 | 15 | 1.2 U | 2.7 | 1.2 U | |
| | | 12/20/2007 | ppbv | 12 U | 12 U | 12 UJ | 12 U | 12 U | 16 J | 12 U | 12 U | 12 U | 29 | 60 | 12 U | 24 U | 190 | 12 U | 42 | 12 U | 17 J | 12 U | 3,100 | 12 U | 29 | 12 U | |
| | | 12/27/2007 | ppbv | 1.8 J | 1.3 U | 1.3 U | 1.3 UJ | 1.3 U | 7.6 | 1.3 U | 1.3 U | 1.3 U | 21 | 43 | 1.4 J | 4.4 J | 160 | 1.5 J | 5.3 | 1.3 U | 19 | 1.3 U | 560 J | 1.3 U | 19 | 1.3 U | |
| DPE-C Manifold | SP-114 | 5/31/2007 | ppbv | 14 U | 14 U | 14 U | -- | 14 U | 14 U | 14 U | 14 U | 14 U | 14 U | 140 | 14 U | 28 U | 190 | 14 U | 100 | 14 U | 15 J | -- | 14 U | 14 U | 100 | 14 U | |
| | | 6/5/2007 | ppbv | 19 U | 19 U | 19 U | -- | 11 | 19 U | 18 | 4 | 19 U | 18 | 19 U | 19 U | 3 U | 340 | 19 U | 280 | 19 U | 16 | -- | 2 J | 19 U | 300 | 19 U | |
| | | 6/14/2007 | ppbv | 6.7 U | 19 | 6.7 U | -- | 7.4 J | 6.7 U | 24 | 7.2 J | 6.7 U | 34 | 190 | 6.7 U | 13 U | 360 | 6.7 U | 16 | 6.7 U | 24 | -- | 6.7 U | 6.7 U | 160 | 6.7 U | |
| | | 6/19/2007 | ppbv | 30 UJ | 30 J | 30 UJ | -- | 30 U | 30 U | 59 J | 30 U | 30 U | 44 J | 200 | 30 U | 60 U | 940 | 30 U | 56 J | 30 U | 33 J | -- | 30 U | 30 U | 400 | 30 U | |
| | | 7/11/2007 | ppbv | 14 U | 18 J | 14 U | -- | 21 J | 14 U | 14 U | 14 U | 14 U | 26 J | 91 | 14 U | 28 U | 230 | 14 U | 14 U | 14 U | 26 J | -- | 540 | 14 U | 270 | 14 U | |
| | | 7/17/2007 | ppbv | 13 U | 13 U | 13 UJ | -- | 13 U | 13 U | 13 U | 13 U | 13 U | 13 U | 54 | 13 U | 26 U | 330 | 13 U | 21 J | 13 U | 13 U | -- | 47 | 13 U | 81 | 13 U | |
| | | 7/25/2007 | ppbv | 6.4 U | 9.1 J | 6.4 UJ | -- | 17 | 6.4 U | 25 | 6.4 J | 6.4 U | 10 J | 28 | 6.4 U | 13 U | 110 | 6.4 U | 6.4 U | 6.4 U | 7.2 J | -- | 58 | 6.4 U | 130 | 6.4 U | |
| | | 7/31/2007 | ppbv | 5.3 | 23 | 4.6 | -- | 9.8 UJ | 1.4 UJ | 11 | 11 | 1.4 J | 25 UJ | 24 UJ | 1.4 U | 2.7 U | 73 UJ | 1.4 U | 3.6 | 1.4 U | 15 | 67 | 38 UJ | 2.6 J | 160 | 1.4 U | |
| | | 8/7/2007 | ppbv | 14 U | 16 J | 14 U | -- | 30 | 14 U | 21 J | 14 U | 14 U | 14 U | 34 | 14 U | 27 U | 140 | 14 U | 14 U | 14 U | 18 J | 730 J | 210 J | 14 U | 72 | 14 U | |
| | | 8/14/2007 | ppbv | 0.7 U | 0.7 U | 1 J | -- | 13 J | 0.7 U | 0.7 U | 0.7 U | 0.7 U | 1 J | 3.1 | 0.7 U | 1.7 J | 42 | 0.9 J | 1.1 J | 1 J | 0.7 U | 120 | 5.5 UJ | 0.7 U | 3.6 J | 0.7 U | |
| | | 9/5/2007 | ppbv | 14 U | 61 | 14 U | 14 U | 18 J | 14 U | 28 | 14 U | 14 U | 30 | 24 J | 14 U | 27 U | 270 | 14 U | 14 U | 14 U | 22 J | 47 | 160 | 14 U | 100 | 14 U | |
| | | 11/7/2007 | ppbv | 5.4 | 26 | 5.9 | 3 J | 5 | 1.4 UJ | 4.1 | 2.3 J | 1.2 U | 12 UJ | 12 UJ | 1.2 U | 2.4 U | 76 UJ | 1.2 U | 22 | 1.2 U | 16 | 7.2 | 70 UJ | 1.2 U | 32 UJ | 1.2 U | |
| | | 11/15/2007 | ppbv | 6.8 | 35 | 1.3 UJ | 1.3 UJ | 3.1 | 2.2 J | 23 | 3.1 | 1.3 U | 11 | 32 | 1.3 U | 2.5 U | 330 | 1.3 U | 1.3 U | 1.3 U | 9.3 | 16 | 120 | 1.3 U | 30 | 1.3 U | |
| | | 11/20/2007 | ppbv | 11 | 46 | 2.4 | 1.2 UJ | 4.3 | 2.6 | 2 J | 3.6 | 1.2 U | 11 | 11 | 2.4 | 5.9 | 60 | 1.7 J | 3.5 | 1.2 U | 22 | 9.2 | 290 | 1.2 U | 25 | | |

Table 3.5
VOC Analytical Results for the Vapor Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | m,p-Xylene | n-Hexane | o-Xylene | Propylene | Styrene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Trichlorofluoromethane | |
|-----------------|------------|------------|-------|--------------------|--------------------|-------------|------------|---------|---------|------------------|------------|---------------|------------------------|-------------|--------------|------------|-----------|----------|-----------|---------|-------------------|-----------------|---------|--------------------------|-----------------|------------------------|---------|
| Description | Station ID | Date | Units | | | | | | | | | | | | | | | | | | | | | | | | |
| ERH Zone 801 | SP-801 | 9/27/2007 | ppbv | 14 U | 150 | 14 U | 14 UJ | 14 U | 14 U | 18 J | 14 U | 14 U | 300 | 14 U | 14 UJ | 27 UJ | 29 | 14 UJ | 30 | 14 UJ | 14 UJ | 14 U | 14 UJ | 14 U | 320 | 14 U | |
| | | 10/1/2007 | ppbv | 16 J | 200 | 13 U | 13 UJ | 13 U | 13 U | 43 | 13 U | 13 U | 390 | 110 | 13 UJ | 27 UJ | 1,800 | 13 UJ | 45 | 13 UJ | 13 UJ | 13 U | 230 J | 13 U | 310 | 13 U | |
| | | 10/8/2007 | ppbv | 19 J | 180 | 14 U | 14 U | 22 J | 14 U | 62 | 14 U | 14 U | 330 | 33 | 14 U | 28 U | 84 | 14 U | 74 | 14 U | 14 U | 14 U | 22 J | 14 U | 450 | 14 U | |
| | | 10/15/2007 | ppbv | 8.1 | 100 | 1.3 U | 39 UJ | 24 | 3.2 | 52 | 1.4 J | 1.3 UJ | 130 | 22 | 1.3 U | 3.8 J | 33 | 2 J | 58 J | 1.3 U | 5.8 | 110 UJ | 6.8 | 3.7 | 390 | 1.3 U | |
| | | 10/23/2007 | ppbv | 12 U | 60 | 12 U | 12 UJ | 12 U | 12 U | 69 | 12 U | 12 UJ | 84 | 75 | 12 U | 24 U | 54 | 12 U | 96 | 12 U | 12 U | 230 | 58 | 12 U | 550 | 12 U | |
| | | 10/30/2007 | ppbv | 13 U | 36 | 13 U | 13 UJ | 86 | 13 U | 67 | 13 U | 13 UJ | 87 | 47 | 13 U | 26 U | 94 | 13 U | 95 | 13 U | 33 | 120 | 84 | 13 U | 610 | 13 U | |
| | | 11/8/2007 | ppbv | 11 U | 23 | 11 U | 11 U | 28 | 11 U | 19 J | 11 U | 11 U | 35 | 39 | 11 U | 22 U | 67 | 11 U | 750 J | 11 U | 11 U | 11 U | 510 J | 11 U | 720 | 11 U | |
| | | 11/15/2007 | ppbv | 14 U | 96 | 14 UJ | 14 UJ | 96 | 14 U | 40 | 14 U | 14 U | 110 | 35 | 14 U | 27 U | 120 | 14 U | 61 | 14 U | 14 U | 61 | 150 | 14 U | 850 | 14 U | |
| | | 11/20/2007 | ppbv | 13 U | 68 | 13 U | 21 J | 140 | 13 U | 39 | 13 U | 13 U | 84 | 75 | 13 U | 26 U | 140 | 13 U | 58 | 13 U | 13 U | 31 | 130 | 13 U | 1,200 | 13 U | |
| | | 11/27/2007 | ppbv | 13 U | 88 | 13 U | 13 U | 160 | 13 U | 32 | 13 U | 13 U | 130 | 46 | 13 U | 26 U | 120 | 13 U | 120 | 13 U | 13 U | 35 | 110 | 13 U | 930 | 13 U | |
| | | 12/4/2007 | ppbv | 12 U | 88 | 12 U | 23 J | 230 | 12 U | 30 | 12 U | 12 U | 140 | 62 | 12 U | 24 U | 100 | 12 U | 88 | 12 U | 12 U | 27 | 72 | 12 U | 1,900 | 12 U | |
| | | 12/11/2007 | ppbv | 9.5 U | 58 | 9.5 U | 39 | 310 | 9.5 U | 24 | 9.5 U | 9.5 UJ | 95 | 49 | 9.5 U | 19 U | 97 | 9.5 U | 48 | 9.5 U | 9.5 U | 44 | 67 | 9.5 U | 1,800 | 9.5 U | |
| 12/20/2007 | ppbv | 12 U | 17 J | 12 UJ | 68 | 630 J | 12 U | 25 | 12 U | 12 U | 63 | 54 | 12 U | 24 U | 59 UJ | 12 U | 250 | 12 U | 12 U | 28 | 62 | 12 U | 2,000 | 12 U | | | |
| 12/27/2007 | ppbv | 13 U | 19 J | 13 U | 13 UJ | 440 | 13 U | 13 U | 13 U | 13 U | 33 | 30 | 13 U | 25 U | 50 | 13 U | 37 | 13 U | 13 U | 13 U | 72 | 13 U | 790 J | 13 U | | | |
| ERH Zone 802 | SP-802 | 9/27/2007 | ppbv | 290 U | 290 U | 290 U | 290 UJ | 290 U | 660 | 290 U | 290 U | 290 UJ | 1,100 | 6,400 | 290 UJ | 570 U | 52,000 | 290 U | 290 U | 290 U | 290 U | 290 U | 30,000 | 290 U | 3,000 | 290 U | |
| | | 10/1/2007 | ppbv | 260 U | 260 U | 260 U | 260 UJ | 260 U | 400 J | 260 U | 260 U | 260 U | 810 | 3,600 | 260 U | 510 U | 29,000 | 260 U | 260 U | 260 U | 260 U | 260 U | 19,000 | 260 U | 2,300 | 260 U | |
| | | 10/8/2007 | ppbv | 270 U | 270 U | 270 U | 270 UJ | 270 U | 270 U | 270 U | 270 U | 270 U | 490 J | 960 | 270 U | 530 U | 6,200 | 270 U | 270 U | 270 U | 270 U | 270 U | 4,100 | 270 U | 1,800 | 270 U | |
| | | 10/15/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 UJ | 350 J | 1.7 | 250 U | 500 U | 16,000 | 250 U | 250 U | 250 U | 250 U | 250 U | 1,900 | 250 U | 2,000 J | 250 U | |
| | | 10/23/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 460 J | 260 U | 530 U | 2,800 | 260 U | 260 U | 260 U | 260 U | 260 U | 940 | 260 U | 2,000 | 260 U | |
| | | 10/30/2007 | ppbv | 260 U | 260 U | 260 U | 260 UJ | 260 U | 480 J | 260 U | 260 U | 260 UJ | 860 | 8,600 | 260 U | 520 U | 88,000 | 260 U | 260 U | 260 U | 260 U | 260 U | 290 J | 16,000 J | 260 U | 1,600 | 260 U |
| | | 11/8/2007 | ppbv | 260 U | 260 U | 260 U | 260 UJ | 260 U | 260 U | 260 U | 260 U | 260 U | 320 J | 280 J | 260 U | 510 U | 1,200 | 260 U | 260 U | 260 U | 260 U | 260 U | 910 | 260 U | 5,000 | 260 U | |
| | | 11/15/2007 | ppbv | 250 U | 250 U | 250 UJ | 250 UJ | 250 U | 250 U | 250 U | 250 U | 250 U | 270 J | 2,800 | 250 U | 490 U | 34,000 | 250 U | 250 U | 250 U | 250 U | 250 U | 950 | 250 U | 2,600 | 250 U | |
| | | 11/20/2007 | ppbv | 220 U | 220 U | 220 U | 220 UJ | 220 U | 220 U | 220 U | 220 U | 220 U | 370 J | 8,200 | 220 U | 450 U | 69,000 | 220 U | 220 U | 220 U | 220 U | 220 U | 3,300 | 220 U | 5,200 | 220 U | |
| | | 11/27/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 4,000 | 250 U | 500 U | 28,000 | 250 U | 250 U | 250 U | 250 U | 250 U | 1.7 | 250 U | 3,100 | 250 U | |
| | | 12/4/2007 | ppbv | 240 U | 240 U | 240 U | 240 U | 350 J | 240 U | 240 U | 240 U | 240 U | 280 J | 5,200 | 240 U | 480 U | 43,000 | 240 U | 240 U | 240 U | 240 U | 240 U | 2,300 | 240 U | 4,400 | 240 U | |
| | | 12/11/2007 | ppbv | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 UJ | 2,400 U | 5,400 | 2,400 U | 4900 U | 56,000 | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 2,400 U | 5,200 | 2,400 U |
| 12/11/2007 | ppbv | 250 U | 250 U | 250 UJ | 250 UJ | 490 J | 250 U | 250 U | 250 U | 250 U | 520 | 1,700 | 250 U | 500 U | 13,000 | 250 U | 250 U | 250 U | 250 U | 250 U | 810 | 250 U | 5,500 | 250 U | | | |
| 12/11/2007 | ppbv | 240 U | 240 U | 240 U | 240 UJ | 240 U | 240 U | 240 U | 240 U | 240 U | 400 J | 2,200 | 240 U | 490 U | 17,000 | 240 U | 240 U | 240 U | 240 U | 240 U | 720 | 240 U | 3,800 | 240 U | | | |
| ERH Zone 803 | SP-803 | 9/27/2007 | ppbv | 270 U | 920 | 270 U | 270 UJ | 270 U | 3,300 | 270 U | 270 U | 270 UJ | 7,400 | 62,000 | 280 J | 1,900 | 600,000 | 360 J | 270 U | 270 U | 270 U | 270 U | 66,000 | 270 U | 3,400 | 270 U | |
| | | 10/1/2007 | ppbv | 160 | 630 | 60 U | 60 UJ | 60 U | 2,400 | 60 U | 60 U | 60 U | 5,400 J | 1,600 | 210 | 1,300 | 38,000 | 260 | 79 J | 60 U | 63 J | 850 | 3,400 | 60 U | 2,300 | 60 U | |
| | | 10/8/2007 | ppbv | 35 | 610 | 2.5 U | 2.5 UJ | 2.5 U | 2,900 | 24 | 2.5 U | 2.6 J | 4,700 J | 40,000 | 240 | 2,000 | 460,000 J | 370 | 39 | 2.5 U | 42 J | 2.5 U | 95,000 | 2.5 U | 2,200 | 2.7 J | |
| | | 10/15/2007 | ppbv | 250 U | 680 | 250 U | 250 U | 250 U | 2,500 | 250 U | 250 U | 250 UJ | 4,700 | 47,000 | 250 U | 2,100 | 46000 | 440 J | 250 U | 250 U | 250 U | 250 U | 98,000 | 250 U | 2,200 | 250 U | |
| | | 10/23/2007 | ppbv | 570 U | 1,100 J | 570 U | 570 UJ | 570 U | 3,800 | 570 U | 570 U | 570 UJ | 6,200 | 37,000 | 570 U | 2,800 | 400,000 | 680 J | 570 U | 570 U | 570 U | 570 U | 73,000 | 570 U | 5,500 | 570 U | |
| | | 10/30/2007 | ppbv | 260 U | 500 J | 260 U | 260 UJ | 260 U | 1.7 | 260 U | 260 U | 260 UJ | 3,200 | 31,000 | 260 U | 1.7 | 360,000 | 410 J | 260 U | 260 U | 300 J | 260 U | 59,000 | 260 U | 3,800 | 260 U | |
| | | 11/8/2007 | ppbv | 280 U | 370 J | 280 U | 280 UJ | 280 U | 1,400 | 280 U | 280 U | 280 U | 2,300 | 28,000 | 280 U | 1,400 | 350,000 | 330 J | 280 U | 280 U | 280 U | 280 U | 52,000 | 280 U | 3,700 | 280 U | |
| | | 11/15/2007 | ppbv | 270 U | 320 J | 270 UJ | 270 UJ | 270 U | 390 J | 270 U | 270 U | 270 U | 1,900 | 12,000 | 270 U | 540 U | 150,000 | 270 U | 270 U | 270 U | 270 U | 270 U | 2 | 270 U | 2,200 | 270 U | |
| | | 11/20/2007 | ppbv | 240 U | 330 J | 240 U | 240 UJ | 260 J | UJ | 240 U | 240 U | 240 U | 1,900 | 13,000 | 240 U | 480 U | 160,000 | 240 U | 240 U | 240 U | | | | | | | |

Table 3.5
VOC Analytical Results for the Vapor Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| | | | | Analyte: | | | | | | | | | | | | | | | | | | | | | | | | |
|-----------------|------------|------------|-------|---------------------|---------------------|--------------|------------|---------|---------|------------------|------------|---------------|--------------------------|-------------|--------------|--------------|-----------|-----------|-----------|---------|-------------------|-----------------|---------|----------------------------|-----------------|------------------------|---------|---------|
| | | | | 1, 1-Dichloroethane | 1, 1-Dichloroethene | 1, 4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroform | Chloromethane | cis -1, 2-Dichloroethene | Cyclohexane | Ethylbenzene | m, p -Xylene | n -Hexane | o -Xylene | Propylene | Styrene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans -1, 2-Dichloroethene | Trichloroethene | Trichlorofluoromethane | | |
| Description | Station ID | Date | Units | | | | | | | | | | | | | | | | | | | | | | | | | |
| ERH Zone 805 | SP-805 | 9/27/2007 | ppbv | 280 U | 280 U | 280 U | 280 UJ | 280 U | 280 U | 280 U | 280 U | 280 U | 320 J | 290 J | 280 U | 560 U | 2,800 | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 1,200 | 280 U | 1.7 | 280 U | |
| | | 10/1/2007 | ppbv | 2,700 U | 4,300 J | 2,700 U | 2,700 UJ | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 7500 | 2,700 U | 2,700 U | 5,400 U | 11,000 | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 1,200 | 2,700 U | 8,600 | 2,700 U |
| | | 10/8/2007 | ppbv | 1.7 J | 1.3 U | 1.3 U | 12 J | 36 | 12 | 16 | 160 | 1.3 U | 300 | 51 | 1.3 U | 4.3 J | 170 | 1.4 J | 25 | 1.3 U | 13 | 10 | 330 | 6.7 | 1,200 | 1.3 U | | |
| | | 10/15/2007 | ppbv | 7.3 U | 7.3 U | 7.3 U | 7.3 U | 22 | 7.3 U | 7.3 U | 7.3 U | 7.3 UJ | 16 | 88 | 7.3 U | 15 U | 1,200 | 7.3 U | 9.5 J | 7.3 U | 7.3 U | 31 UJ | 120 | 7.3 U | 56 | 7.3 U | | |
| | | 10/23/2007 | ppbv | 5.4 U | 16 | 5.4 U | 120 J | 94 | 12 | 32 | 150 | 5.4 UJ | 440 | 110 | 5.4 U | 11 U | 200 | 5.4 U | 56 | 5.4 U | 25 | 590 | 310 | 12 | 1,300 | 5.4 U | | |
| | | 10/30/2007 | ppbv | 28 U | 28 U | 28 U | 28 UJ | 110 | 28 U | 29 J | 250 | 28 UJ | 350 | 130 | 28 U | 56 U | 350 | 28 U | 90 | 28 U | 33 J | 170 | 400 | 28 U | 1,200 | 28 U | | |
| | | 11/8/2007 | ppbv | 8.5 U | 12 J | 8.5 U | 8.5 UJ | 64 | 8.5 U | 17 J | 180 | 8.5 U | 290 | 91 | 8.5 U | 17 U | 58 | 8.5 U | 86 | 8.5 U | 22 | 29 | 130 | 9 J | 1,800 | 8.5 U | | |
| | | 11/15/2007 | ppbv | 270 U | 270 U | 270 UJ | 270 UJ | 270 U | 270 U | 270 U | 270 U | 270 U | UJ | 14,000 J | 270 U | 550 U | 150,000 | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 3,300 | 270 U | 1,200 | 270 U | |
| | | 11/20/2007 | ppbv | 4,100 U | 4,100 U | 4,100 U | 4,100 UJ | 4,100 U | 4,100 U | 4,100 U | 4,100 U | 4,100 U | 4,100 U | 11,000 | 4,100 U | 8,200 U | 130,000 | 4,100 U | 4,100 U | 4,100 U | 4,100 U | 4,100 U | 4,100 U | 4,200 J | 4,100 U | 19,000 | 4,100 U | |
| | | 11/27/2007 | ppbv | 740 U | 740 U | 740 U | 740 U | 740 U | 740 U | 740 U | 740 U | 740 U | 740 U | 13,000 | 740 U | 1,500 U | 130,000 | 740 U | 430 U | 740 U | 740 U | 740 U | 740 U | 4,000 | 740 U | 1,600 | 740 U | |
| | | 12/4/2007 | ppbv | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 270 J | 5,400 | 230 U | 470 U | 50,000 | 230 U | 230 U | 230 U | 230 U | 230 U | 3,700 | 230 U | 1,800 | 230 U | |
| | | 12/11/2007 | ppbv | 500 U | 500 U | 500 U | 500 UJ | 500 U | 500 U | 500 U | 500 U | 500 U | 500 U | 500 U | 5,200 | 500 U | 1,000 U | 53,000 | 500 U | 500 U | 500 U | 500 U | 500 U | 2,600 | 500 U | 2,000 | 500 U | |
| | | 12/20/2007 | ppbv | 240 U | 240 U | 240 UJ | 240 UJ | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 290 J | 9,200 | 240 U | 480 U | 71,000 | 240 U | 240 U | 240 U | 240 U | 240 U | 4,400 | 240 U | 2,100 | 240 U |
| 12/27/2007 | ppbv | 260 U | 260 U | 260 U | 260 UJ | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 3,600 | 260 U | 520 U | 25,000 | 260 U | 260 U | 260 U | 260 U | 260 U | 3,000 | 260 U | 2,300 | 260 U | | | |

Notes:
Bolded results indicate positive detections.
Analyses were performed by EPA Region 9 laboratory using EPA Method TO-15 .
Only commonly detected in 2007 are listed in this table. For more detailed results, see [Table A2.1](#) and the lab reports in [Appendix 2](#).
ERH - electrical resistance heating
U - not detected above the stated reporting limit; UJ - not detected at estimated reporting limit; J - quantitative estimate
"--" - not available
ppbv - part per billion by volume

Table 3.6
VOC Analytical Results for the Influent to the Vapor Treatment System
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,2,4-Trichlorobenzene | 1,2,4-Trimethylbenzene | 1,3,5-Trimethylbenzene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroethane | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | Freon 113* | Hexachlorobutadiene | Isopropanol | m,p-Xylene | Methylene chloride | n-Hexane | o-Xylene | Propylene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Vinyl chloride |
|----------|-----------|------|--------------------|--------------------|------------------------|------------------------|------------------------|-------------|------------|---------|---------|------------------|--------------|------------|---------------|------------------------|-------------|--------------|------------|---------------------|-------------|------------|--------------------|----------|----------|-----------|-------------------|-----------------|---------|--------------------------|-----------------|----------------|
| | | | 54 J | 130 J | 15 UJ | 15 UJ | 15 UJ | 15 UJ | -- | 40 J | 72 J | 15 UJ | 39 J | 15 UJ | 15 UJ | 580 J | -- | 48 J | 15 UJ | 15 UJ | 15 UJ | 110 J | 15 UJ | 200,000 | 18 J | 110 J | 38 J | -- | 14,000 | 15 UJ | 10,000 | 750 J |
| SP-102 | 5/14/2007 | ppbv | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| SP-102 | 5/15/2007 | ppbv | 46 J | 13 UJ | 13 UJ | 13 UJ | 13 UJ | 13 UJ | -- | 13 UJ | 110 J | 13 UJ | 32 J | 13 UJ | 13 UJ | 720 J | -- | 95 J | 13 UJ | 13 UJ | 13 UJ | 210 J | 13 UJ | 200,000 | 36 J | 63 J | 48 J | -- | 33,000 | 13 UJ | 13,000 | 540 J |
| SP-102 | 5/17/2007 | ppbv | 120 U | 160 J | 120 U | 120 U | 120 U | 120 U | -- | 120 U | 130 J | 120 U | 120 U | 120 U | 120 U | 720 | -- | 120 U | 120 U | 120 UJ | 120 U | 240 U | 370 | 440,000 | 120 U | 610 | 120 U | -- | 20,000 | 370 | 7,800 | 480 |
| SP-102 | 5/18/2007 | ppbv | 130 U | 130 U | 130 U | 130 U | 130 U | 130 U | -- | 130 U | 160 J | 130 U | 130 U | 130 U | 130 U | 19,000 | 130 U | 130 U | 130 UJ | 130 U | 260 U | 130 U | 120,000 | 130 U | 1,700 | 130 U | -- | 46,000 J | 130 U | 9,700 | 550 | |
| SP-102 | 5/21/2007 | ppbv | 140 U | 140 U | 140 U | 140 U | 140 U | 140 U | -- | 140 U | 140 U | 140 U | 140 U | 140 U | 140 U | 810 | 13,000 | 140 U | 140 U | 140 UJ | 140 U | 290 U | 140 U | 120,000 | 140 U | 690 | 140 U | -- | 22,000 | 140 U | 8,900 | 480 |
| SP-102 | 5/22/2007 | ppbv | 3.6 U | 3.6 U | 3.6 U | 27 | 3.6 U | 3.6 U | -- | 30 | 22 | 5.7 J | 9.8 | 3.6 U | 3.6 U | 600 | 4,700 | 5.1 J | 3.6 U | 3.6 UJ | 3.6 U | 10 J | 3.6 U | 17,000 | 3.6 U | 2,700 | 170 J | -- | 35 | 3.6 U | 6,600 | 170 |
| SP-102 | 5/29/2007 | ppbv | 6.7 U | 6.7 U | 6.7 UJ | 6.7 U | 6.7 U | 6.7 U | -- | 6.7 UJ | 6.7 U | 6.7 U | 6.7 U | 6.7 U | 6.7 U | 180 J | 2,500 | 6.7 U | 6.7 U | 6.7 UJ | 6.7 U | 13 U | 6.7 U | 7,400 | 6.7 U | 3,500 | 49 | -- | 11 J | 6.7 U | 3,500 J | 64 J |
| SP-102 | 5/30/2007 | ppbv | 17 U | 17 U | 17 U | 17 U | 17 U | 17 J | -- | 21 J | 17 U | 17 U | 17 U | 17 U | 17 U | 370 | 4,300 | 17 U | 17 U | 17 U | 17 U | 33 U | 17 U | 17,000 | 17 U | 8,200 | 130 | -- | 17 U | 17 U | 3,900 | 17 U |
| SP-102 | 5/31/2007 | ppbv | 15 U | 15 U | 15 UJ | 15 U | 15 U | 15 U | -- | 15 U | 15 U | 15 U | 15 U | 15 U | 15 U | 350 | 5,600 | 15 U | 15 U | 15 UJ | 15 U | 30 U | 15 U | 21,000 | 15 U | 4,300 | 51 | -- | 19 J | 15 U | 4,800 | 110 |
| SP-102 | 6/1/2007 | ppbv | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | -- | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | -- | 1,700 U | 1,700 U | 1,700 UJ | 1,700 U | 3,300 U | 1,700 U | 48,000 | 1,700 U | 4,900 | 1,700 U | -- | 1,700 U | 1,700 U | 6,500 | 1,700 U |
| SP-102 | 6/4/2007 | ppbv | 2,900 U | 2,900 U | 2,900 U | 2,900 U | 2,900 U | 2,900 U | -- | 2,900 U | 2,900 U | 2,900 U | 2,900 U | 2,900 U | 2,900 U | 2,900 U | -- | 2,900 U | 2,900 U | 2,900 UJ | 2,900 U | 5,800 U | 2,900 U | 44,000 | 2,900 U | 3,200 J | 2,900 U | -- | 2,900 U | 2,900 U | 5,400 J | 2,900 U |
| SP-102 | 6/5/2007 | ppbv | 2,800 U | 2,800 U | 2,800 U | 2,800 U | 2,800 U | 2,800 U | -- | 2,800 U | 2,800 U | 2,800 U | 2,800 U | 2,800 U | 2,800 U | 2,800 U | -- | 2,800 U | 2,800 U | 2,800 UJ | 2,800 U | 5,600 U | 2,800 U | 58,000 | 2,800 U | 3,300 J | 2,800 U | -- | 2,800 U | 2,800 U | 5,900 | 2,800 U |
| SP-102 | 6/6/2007 | ppbv | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | -- | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | -- | 1,600 U | 1,600 U | 1,600 UJ | 1,600 U | 3,300 U | 1,600 U | 71,000 | 1,600 U | 9,900 | 1,600 U | -- | 1,600 U | 1,600 U | 5,700 | 1,600 U |
| SP-102 | 6/7/2007 | ppbv | 540 U | 540 U | 540 U | 540 U | 540 U | 540 U | -- | 540 U | 540 U | 540 U | 540 U | 540 U | 540 U | 1,400 | -- | 540 U | 540 U | 540 UJ | 540 U | 1,100 U | 540 U | 54,000 | 540 U | 11,000 | 540 U | -- | 1,100 | 540 U | 6,500 | 540 U |
| SP-102 | 6/8/2007 | ppbv | 510 U | 510 U | 510 U | 510 U | 510 U | 510 U | -- | 510 U | 510 U | 510 U | 510 U | 510 U | 510 U | 1,400 | -- | 510 U | 510 U | 510 UJ | 510 U | 1,000 U | 510 U | 52,000 | 510 U | 8,800 | 510 U | -- | 1,500 | 510 U | 5,700 | 510 U |
| SP-102 | 6/11/2007 | ppbv | 600 U | 600 U | 600 U | 600 U | 600 U | 600 U | -- | 600 U | 600 U | 600 U | 600 U | 600 U | 600 U | 1,200 | -- | 600 U | 600 U | 600 UJ | 600 U | 1,200 U | 600 U | 40,000 | 600 U | 5,700 | 600 U | -- | 600 U | 600 U | 5,100 | 600 U |
| SP-102 | 6/12/2007 | ppbv | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | -- | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 740 | -- | 280 U | 280 U | 280 UJ | 280 U | 550 U | 280 U | 1,700 | 280 U | 2,000 | 280 U | -- | 280 U | 280 U | 4,300 | 280 U |
| SP-102 | 6/13/2007 | ppbv | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | -- | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | -- | 1,200 U | 1,200 U | 1,200 UJ | 1,200 U | 2,300 U | 1,200 U | 38,000 | 1,200 U | 2,400 | 1,200 U | -- | 1,200 U | 1,200 U | 3,100 | 1,200 U |
| SP-102 | 6/14/2007 | ppbv | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | -- | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 9,600 | 1,600 U | 1,600 U | 1,600 UJ | 1,600 U | 3,200 U | 1,600 U | 70,000 | 1,600 U | 8,100 | 1,600 U | -- | 1,600 U | 1,600 U | 7,400 | 1,600 U |
| SP-102 | 6/15/2007 | ppbv | 1,500 U | 1,500 U | 1,500 UJ | 1,500 U | 1,500 U | 1,500 U | -- | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 8,400 | 1,500 U | 1,500 U | 1,500 UJ | 1,500 U | 2,900 U | 1,500 U | 62,000 J | 1,500 U | 5,000 J | 1,500 U | -- | 2,400 J | 1,500 U | 6,200 | 1,500 U |
| SP-102 | 6/18/2007 | ppbv | 1,000 U | 1,000 U | 1,000 UJ | 1,000 U | 1,000 U | 1,000 U | -- | 1,000 U | 1,000 U | 1,000 U | 1,000 U | 1,000 U | 1,000 U | 1,400 J | 7,500 | 1,000 U | 1,000 U | 1,000 UJ | 1,000 U | 2,100 U | 1,000 U | 51,000 | 1,000 U | 11,000 | 1,000 U | -- | 1,400 J | 1,000 U | 6,200 | 1,000 U |
| SP-102 | 6/19/2007 | ppbv | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | 1,700 U | -- | 2,900 J | 1,700 U | 1,700 U | 1,700 U | 1,700 UJ | 1,700 J | 9,300 | 1,700 U | 1,700 U | 1,700 UJ | 1,700 U | 3,300 U | 1,700 U | 72,000 J | 1,700 U | 3,700 | 1,700 U | -- | 2,500 J | 1,700 U | 7,600 | 1,700 U | |
| SP-102 | 6/20/2007 | ppbv | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | -- | 2,600 J | 1,500 U | 1,500 U | 1,500 U | 1,500 UJ | 1,500 J | 7,300 | 1,500 U | 1,500 U | 1,500 UJ | 1,500 U | 3,000 U | 1,500 U | 60,000 | 1,500 U | 3,200 | 1,500 U | -- | 3,200 | 1,500 U | 6,100 | 1,500 U | |
| SP-102 | 6/21/2007 | ppbv | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | -- | 2,400 J | 1,400 U | 1,400 U | 1,400 U | 1,400 UJ | 1,500 J | 8,200 | 1,400 U | 1,400 U | 1,400 UJ | 1,400 U | 2,900 U | 1,400 U | 64,000 J | 1,400 U | 3,200 | 1,400 U | -- | 2,200 J | 1,400 U | 6,700 | 1,400 U | |
| SP-102 | 7/9/2007 | ppbv | 1,600 U | 1,600 U | 1,600 UJ | 1,600 U | 1,600 U | 1,600 U | -- | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 1,600 U | 7,200 | 1,600 U | 1,600 U | 1,600 UJ | 1,600 UJ | 3,200 U | 1,600 U | 51,000 | 1,600 U | 1,600 U | 1,600 U | -- | 2,500 J | 1,600 U | 5,500 | 1,600 U |
| SP-102 | 7/10/2007 | ppbv | 1,500 U | 1,500 U | 1,500 UJ | 1,500 U | 1,500 U | 1,500 U | -- | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 7,600 | 1,500 U | 1,500 U | 1,500 UJ | 1,500 UJ | 3,000 U | 1,500 U | 57,000 | 1,500 U | 2,500 J | 1,500 U | -- | 3,400 | 1,500 U | 5,400 | 1,500 U |
| SP-102 | 7/11/2007 | ppbv | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | -- | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 J | 7,800 | 1,500 U | 1,500 U | 1,500 UJ | 1,500 UJ | 3,100 U | 1,500 U | 59,000 | 1,500 U | 2,900 J | 1,500 U | -- | 5,000 | 1,500 U | 5,700 | 1,500 U |
| SP-102 | 7/12/2007 | ppbv | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | -- | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 1,500 U | 6,400 | 1,500 U | 1,500 U | 1,500 UJ | 1,500 UJ | 3,100 U | 1,500 U | 48,000 | 1,500 U | 3,100 | 1,500 U | -- | 5,100 | 1,500 U | 4,900 | 1,500 U |
| SP-102 | 7/16/2007 | ppbv | 1,400 U | 1,400 U | 1,400 UJ | 1,400 U | 1,400 U | 1,400 UJ | -- | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 6,100 | 1,400 U | 1,400 U | 1,400 UJ | 1,400 U | 2,800 U | 1,400 U | 47,000 | 1,400 U | 1,500 J | 1,400 U | -- | 4,000 | 1,400 U | 3,300 | 1,400 U |
| SP-102 | 7/17/2007 | ppbv | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 UJ | -- | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 6,300 | 1,400 U | 1,400 U | 1,400 UJ | 1,400 U | 2,700 U | 1,400 U | 51,000 | 1,400 U | 3,300 | 1,400 U | -- | 5,700 | 1,400 U | 3,900 | 1,400 U |
| SP-102 | 7/18/2007 | ppbv | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 UJ | -- | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 6,000 | 1,300 U | 1,300 U | 1,300 UJ | 1,300 U | 2,600 U | 1,300 U | 49,000 | 1,300 U | 3,100 | 1,300 U | -- | 5,700 | 1,300 U | 3,200 | 1,300 U |
| SP-102 | 7/19/2007 | ppbv | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 UJ | -- | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 1,400 U | 6,600 | 1,400 U | 1,400 U | 1,400 UJ | 1,400 U | 2,900 U | 1,400 U | 55,000 | 1,400 U | 3,800 | 1,400 U | -- | 6,900 | 1,400 U | 3,400 | 1,400 U |
| SP-102 | 7/20/2007 | ppbv | 1,300 U | 1,300 U | 1,300 UJ | 1,300 U | 1,300 U | 1,300 UJ | -- | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 8,000 | 1,300 U | 1,300 U | 1,300 UJ | 1,300 U | 2,600 U | 1,300 U | 55,000 J | 1,300 U | 5,100 | 1,300 U | -- | 9,100 | 1,300 U | 4,000 | 1,300 U |
| SP-102 | 7/24/2007 | ppbv | 1,300 U | 1,300 U | 1,300 UJ | 1,300 U | 1,300 U | 1,300 UJ | -- | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 1,300 U | 6,500 | 1,300 U | 1,300 U | 1,300 UJ | 1,300 U | 2,700 U | 1,300 U | 50,000 J | 1,300 U | 1,500 J | 1,300 U | -- | 8,100 | 1,300 U | 3,600 | 1,300 U |
| SP-102 | 7/25/2007 | ppbv | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 UJ | -- | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 1,200 U | 8,700 | 1,200 U | 1,200 U | 1,200 UJ | 1,200 U | 2,400 U | 1,200 U | 57,000 J | 1,200 U | 2,800 | 1,200 U | -- | 12,000 | 1,200 U | 4,300 | 1,200 U |
| SP-102 | 7/26/2007 | ppbv | 250 U | 280 J | 250 U | 250 U | 250 U | 250 UJ | -- | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 1,100 | 7,600 | 250 U | 250 U | 250 UJ | 250 U | 490 U | 250 U | 57,000 J | 250 U | 2,200 | 250 U | -- | 9,100 | | | |

Table 3.6
VOC Analytical Results for the Influent to the Vapor Treatment System
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,2,4-Trichlorobenzene | 1,2,4-Trimethylbenzene | 1,3,5-Trimethylbenzene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroethane | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | Freon 113* | Hexachlorobutadiene | Isopropanol | m,p-Xylene | Methylene chloride | n-Hexane | o-Xylene | Propylene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Vinyl chloride |
|------------|------------|-------|--------------------|--------------------|------------------------|------------------------|------------------------|-------------|------------|---------|---------|------------------|--------------|------------|---------------|------------------------|-------------|--------------|------------|---------------------|-------------|------------|--------------------|-----------|----------|-----------|-------------------|-----------------|---------|--------------------------|-----------------|----------------|
| Station ID | Date | Units | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 UJ | 280 U | 280 U | 280 U | 280 U | 280 UJ | 440 J | 4,000 | 280 U | 280 U | 280 U | 280 U | 280 U | 560 U | 280 U | 46,000 | 280 U | 280 U | 280 U | 280 U | 10,000 | 280 U | 500 | 280 U |
| SP-102 | 9/26/2007 | ppbv | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 UJ | 280 U | 280 U | 280 U | 280 U | 280 UJ | 440 J | 4,000 | 280 U | 280 U | 280 U | 280 U | 280 U | 560 U | 280 U | 46,000 | 280 U | 280 U | 280 U | 280 U | 10,000 | 280 U | 500 | 280 U |
| SP-102 | 9/27/2007 | ppbv | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 UJ | 270 U | 680 | 270 U | 270 U | 270 U | 270 UJ | 1,300 | 10,000 | 270 U | 270 U | 270 U | 270 U | 540 U | 270 U | 180,000 | 270 U | 270 UJ | 270 U | 270 U | 35,000 | 270 U | 1,400 | 270 U |
| SP-102 | 9/28/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 UJ | 250 U | 600 | 250 U | 250 U | 250 U | 250 UJ | 1,100 | 9,900 | 250 U | 250 U | 250 U | 250 U | 490 U | 250 U | 120,000 | 250 U | 250 U | 250 U | 250 U | 27,000 | 250 U | 1,100 | 250 U |
| SP-102 | 10/1/2007 | ppbv | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 UJ | 1,200 | 10,000 | 280 U | 280 U | 280 U | 280 U | 280 U | 550 U | 280 U | 130,000 | 280 U | 280 U | 280 U | 280 U | 35,000 | 280 U | 1,200 | 280 U |
| SP-102 | 10/2/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 UJ | 260 U | 650 | 260 U | 260 U | 260 U | 260 UJ | 1,300 | 12,000 | 260 UJ | 260 U | 260 U | 260 U | 510 U | 260 U | 140,000 | 260 U | 260 U | 260 U | 260 U | 38,000 | 260 U | 1,300 | 260 U |
| SP-102 | 10/3/2007 | ppbv | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 UJ | 270 U | 710 | 270 U | 270 U | 270 U | 270 UJ | 1,300 | 12,000 | 270 UJ | 270 U | 270 U | 270 U | 550 U | 270 U | 140,000 | 270 U | 270 U | 270 U | 270 U | 39,000 | 270 U | 1,400 | 270 U |
| SP-102 | 10/4/2007 | ppbv | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 UJ | 270 U | 680 | 270 U | 270 U | 270 U | 270 UJ | 1,200 | 10,000 | 270 UJ | 270 U | 270 U | 270 U | 540 U | 270 U | 13,0000 J | 270 U | 270 U | 270 U | 270 U | 35,000 | 270 U | 1,200 | 270 U |
| SP-102 | 10/5/2007 | ppbv | 2,700 U | 4,200 J | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 UJ | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 7,700 | 11,000 | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 5,300 U | 2,700 U | 13,0000 J | 2,700 U | 2,700 U | 2,700 U | 2,700 U | 40,000 | 2,700 U | 8,100 | 2,700 U |
| SP-102 | 10/8/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 UJ | 260 U | 620 | 260 U | 260 U | 260 U | 260 U | 1,000 | 8,300 | 260 U | 260 U | 260 U | 260 U | 530 U | 260 U | 110,000 J | 260 U | 260 U | 260 U | 260 U | 40,000 | 260 U | 1,200 | 260 U |
| SP-102 | 10/9/2007 | ppbv | 280 U | 280 U | 280 U | 280 U | 280 U | 280 U | 280 UJ | 280 U | 530 J | 280 U | 280 U | 280 U | 280 U | 870 | 8,300 | 280 U | 280 U | 280 U | 280 U | 570 U | 280 U | 86,000 | 280 U | 280 U | 280 U | 280 U | 16,000 | 280 U | 1,000 | 280 U |
| SP-102 | 10/10/2007 | ppbv | 260 U | 260 U | 260 UJ | 260 U | 260 U | 260 U | 260 UJ | 260 U | 360 J | 260 U | 260 U | 260 U | 260 U | 620 | 5,900 | 260 U | 260 U | 260 U | 260 U | 530 U | 260 U | 62,000 | 260 U | 260 U | 260 U | 260 U | 11,000 | 260 U | 720 | 260 U |
| SP-102 | 10/11/2007 | ppbv | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 UJ | 270 U | 430 J | 270 U | 270 U | 270 U | 270 U | 770 | 7,700 | 270 U | 270 U | 270 U | 270 U | 540 U | 270 U | 86,000 | 270 U | 270 U | 270 U | 270 U | 15,000 | 270 U | 920 | 270 U |
| SP-102 | 10/12/2007 | ppbv | 280 U | 280 U | 280 U | 280 UJ | 280 UJ | 280 UJ | 280 UJ | 280 U | 420 J | 280 U | 280 U | 280 U | 280 U | 880 | 7,600 | 280 U | 280 U | 280 U | 280 U | 550 U | 280 U | 74,000 | 280 U | 280 U | 280 U | 280 U | 13,000 | 280 U | 910 | 280 U |
| SP-102 | 10/15/2007 | ppbv | 260 U | 260 U | 260 U | 260 UJ | 260 UJ | 260 UJ | 260 UJ | 260 U | 350 J | 260 U | 260 U | 260 U | 260 U | 810 | 7,200 | 260 U | 260 U | 260 U | 260 U | 510 U | 260 U | 72,000 | 260 U | 260 U | 260 U | 260 U | 12,000 | 260 U | 1,000 | 260 U |
| SP-102 | 10/16/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 450 J | 260 U | 260 U | 260 U | 260 UJ | 1,100 | 8,300 | 260 U | 260 U | 260 U | 260 U | 530 U | 260 U | 87,000 | 260 U | 260 U | 260 U | 260 U | 14,000 | 260 U | 1,100 J | 260 U |
| SP-102 | 10/17/2007 | ppbv | 290 U | 290 U | 290 U | 290 U | 290 U | 290 U | 290 UJ | 290 U | 1,700 | 290 U | 290 U | 290 U | 290 UJ | 950 | 8,100 | 290 U | 290 U | 290 U | 290 U | 580 U | 290 U | 79,000 | 290 U | 290 U | 290 U | 290 U | 14,000 | 290 U | 1,200 J | 290 U |
| SP-102 | 10/18/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 UJ | 250 U | 430 J | 250 U | 250 U | 250 U | 250 UJ | 940 | 7,900 | 250 U | 250 U | 250 U | 250 U | 500 U | 250 U | 85,000 | 250 U | 250 U | 250 U | 250 U | 19,000 | 250 U | 1,300 | 250 U |
| SP-102 | 10/19/2007 | ppbv | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 U | 410 UJ | 800 J | 6,200 | 410 U | 410 U | 410 U | 410 U | 830 U | 410 U | 86,000 J | 410 U | 410 U | 410 U | 410 U | 12,000 | 410 U | 910 | 410 U |
| SP-102 | 10/22/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 390 J | 260 U | 260 U | 260 U | 260 UJ | 850 | 6,800 | 260 U | 260 U | 260 U | 260 U | 520 U | 260 U | 71,000 | 260 U | 260 U | 260 U | 260 U | 15,000 | 260 U | 1,200 | 260 U |
| SP-102 | 10/23/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 350 J | 260 U | 260 U | 260 U | 260 UJ | 810 | 6,700 | 260 U | 260 U | 260 U | 260 U | 520 U | 260 U | 68,000 | 260 U | 260 U | 260 U | 260 U | 15,000 | 260 U | 2,100 | 260 U |
| SP-102 | 10/24/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 340 J | 260 U | 260 U | 260 U | 260 UJ | 800 | 6,500 | 260 U | 260 U | 260 U | 260 U | 520 U | 260 U | 67,000 | 260 U | 260 U | 260 U | 260 U | 13,000 | 260 U | 1,500 | 260 U |
| SP-102 | 10/25/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 UJ | 250 U | 310 J | 250 U | 250 U | 250 U | 250 UJ | 680 | 5,700 | 250 U | 250 U | 250 U | 250 U | 510 U | 250 U | 62,000 | 250 U | 250 U | 250 U | 250 U | 12,000 | 250 U | 1,400 | 250 U |
| SP-102 | 10/26/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 UJ | 260 U | 270 J | 260 U | 260 U | 260 U | 260 UJ | 550 | 5,500 | 260 U | 260 U | 260 U | 260 U | 530 U | 260 U | 57,000 | 260 U | 260 U | 260 U | 260 U | 10,000 | 260 U | 1,100 | 260 U |
| SP-102 | 10/29/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 UJ | 260 U | 270 J | 260 U | 260 U | 260 U | 260 UJ | 540 | 5,200 | 260 U | 260 U | 260 U | 260 U | 530 U | 260 U | 55,000 | 260 U | 260 U | 260 U | 260 U | 10,000 | 260 U | 1,100 | 260 U |
| SP-102 | 10/30/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 UJ | 260 U | 280 J | 260 U | 260 U | 260 U | 260 UJ | 530 | 5,600 | 260 U | 260 U | 260 U | 260 U | 520 U | 260 U | 54,000 | 260 U | 260 U | 260 U | 260 U | 9,000 | 260 U | 1,400 | 260 U |
| SP-102 | 10/31/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 UJ | 250 U | 250 UJ | 250 U | 250 U | 250 U | 250 UJ | 400 J | 5,300 | 250 U | 250 U | 250 U | 250 U | 500 U | 250 U | 58,000 | 250 U | 250 U | 250 U | 250 U | 9,400 | 250 U | 1,400 | 250 U |
| SP-102 | 11/1/2007 | ppbv | 250 U | 250 U | 250 U | 250 U | 250 U | 250 U | 250 UJ | 250 U | 250 UJ | 250 U | 250 U | 250 U | 250 UJ | 490 J | 5,100 | 250 U | 250 U | 250 U | 250 U | 500 U | 250 U | 50,000 | 250 U | 250 U | 250 U | 250 U | 9,100 | 250 U | 1,400 | 250 U |
| SP-102 | 11/2/2007 | ppbv | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 270 U | 440 J | 4,400 | 270 U | 270 U | 270 U | 270 U | 540 U | 270 U | 41,000 | 270 U | 270 U | 270 U | 270 U | 8,600 | 270 U | 1,300 | 270 U |
| SP-102 | 11/5/2007 | ppbv | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 300 U | 430 J | 4,100 | 300 U | 300 U | 300 U | 300 U | 600 U | 300 U | 39,000 | 300 U | 300 U | 300 U | 300 U | 8,600 | 300 U | 1,400 | 300 U |
| SP-102 | 11/6/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 490 J | 3,100 | 260 U | 260 U | 260 U | 260 U | 520 U | 260 U | 24,000 | 260 U | 260 U | 260 U | 260 U | 6,700 | 260 U | 3,800 | 260 U |
| SP-102 | 11/7/2007 | ppbv | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 UJ | 420 J | 4,300 | 260 U | 260 U | 260 U | 260 U | 260 U | 530 U | 260 U | 43,000 | 260 U | 260 U | 260 U | 260 U | 8,000 | 260 U | 1,500 | 260 U |
| SP-102 | 11/8/2007 | ppbv | 260 U | 260 U | 260 UJ | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 260 U | 400 J | 4,100 | 260 U | 260 U | 260 U | 260 U | 510 U | 260 U | 42,000 | 260 U | 260 U | 260 U | 260 U | 9,200 | 260 U | 1,900 | 260 U |
| SP-102 | 11/14/2007 | ppbv | 250 U | 250 U | 250 UJ | 250 U | 250 U | 250 U | 250 UJ | 250 U | 250 U | 250 U | 250 U | 250 UJ | 340 J | 3,900 | 250 U | 250 U | 250 U | 250 U | 490 U | 250 U | 51,000 | 250 U | 250 U | 250 U | 250 U | 4,700 | 250 U | 1,400 | 250 UJ | |
| SP-102 | 11/15/2007 | ppbv | 240 U | 240 U | 240 UJ | 240 U | 240 U | 240 UJ | 240 UJ | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 290 J | 4,700 | 240 U | 240 U | 240 U | 240 U | 490 U | 240 U | 44,000 | 240 U | 240 U | 240 U | 240 U | 4,700 | 240 U | 1,100 | 240 U |
| SP-102 | 11/16/2007 | ppbv | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 240 U | 390 J | 2,000 | 240 U | 240 U | 240 U | 240 U | 480 U | 240 U | 22,000 | 240 U | 240 U | 240 U | 240 U | 2,300 | 240 U | 3,000 | 240 U |
| SP-102 | 11/19/2007 | ppbv | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 220 U | 370 J | 4,400 | 220 U | 220 U | 220 U | 220 U | 430 U | 220 U | 47,000 | 220 U | 220 U | 220 U | 220 U | 4,400 | 220 U | 1,800 | 220 U |
| SP-102 | 11/20/2007 | ppbv | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 230 UJ | 230 U | 230 U | 230 U | 230 U | 230 U | 230 U | 320 J | 5,100 | 230 U | 230 U | 230 U | 230 U | 460 U | 230 U | 51,000 | 230 U | 230 U | 230 U | 230 U | 4,700 | 230 U | 1,600 | 230 U |
| SP-102 | 11/21 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Table 3.7
TIC Analytical Results in Vapor Samples
Pemaco Superfund Site, Maywood, CA

| Station ID | Description | TIC Detected | Minimum | | Maximum | | Average |
|------------|--------------------|------------------------|----------------------|--------------------------|----------------------|--------------------------|----------------------|
| | | | Concentration (ppbv) | Date | Concentration (ppbv) | Date | Concentration (ppbv) |
| SP-102 | Influent to FTO | Butane | 4,300 J | 5/30/2007 | 6,300 J | 6/18/2007 | 5,300 J |
| | | Dimethylcyclohexane | 360 J | 8/15/2007 | 3,100 J | 5/15/2007 | 985 J |
| | | Dimethylhexane isomers | 2,100 J | 12/7/2007 | 9,100 J | 9/12/2007 | 4,400 J |
| | | Dimethylbutanes | 1,260 J | 5/22/2007 | 167,000 J | 5/17/2007 | 38,301 J |
| | | Dimethylpentane | 680 J | 9/4/2007 | 38,000 J | 5/17/2007 | 7,369 J |
| | | Isobutane | 1,300 J | 11/29/2007 | 8,100 J | 6/18/2007 | 5,200 J |
| | | Methylheptane isomers | 1,500 J | 8/20/2007 | 2,000 J | 10/26/2007 | 1,800 J |
| | | Methylbutanes | 910 J | 8/10/2007 | 6,400 J | 6/7/2007 | 3,776 J |
| | | Methylcyclopentane | 430 J | 5/22/2007 | 70,000 J | 8/6/2007 | 23,626 J |
| | | Methylhexane | 150 J | 5/22/2007 | 15,300 J | 9/10/2007 | 4,264 J |
| | | Methylpentane | 460 J | 5/22/2007 | 520,000 J | 8/6/2007 | 164,236 J |
| | | n-Octane | 760 J | 9/7/2007 | 1,600 J | 9/11/2007 | 1,180 J |
| | | n-Pentane | 1,000 J | 11/19/2007 11/30/2007 | 3,700 J | 8/7/2007 | 1,825 J |
| | | Tetrahydromethylfuran | 26,000 J | 5/29/2007 | 53,000 J | 5/30/2007 | 42,333 J |
| | | Trimethylbutane | 1,800 J | 9/11/2007 11/14/2007 | 2,000 J | 8/14/2007 11/20/2007 | 1,900 J |
| | | Unknown hydrocarbons | 1,300 J | 12/13/2007 | 1,110,000 J | 5/14/2007 | 371,367 J |
| SP-104 | Pre-GAC | Acetophenone | 9 J | 11/20/2007 | 15 J | 9/25/2007 | 12 J |
| | | Dimethylbutanes | 16 J | 10/8/2007 | 80 J | 10/1/2007 | 46 J |
| | | Dimethyldecane | 13 J | 9/25/2007 | 24 J | 9/5/2007 | 18 J |
| | | Dimethyloctane | 8 J | 12/4/2007 | 33 J | 12/27/2007 | 20 J |
| | | Methylcyclopentane | 6 J | 11/20/2007 | 55 J | 8/14/2007 | 35 J |
| | | Methylpentane | 16 J | 12/20/2007 | 410 J | 8/14/2007 | 166 J |
| | | Total hydrocarbons | 97 J | 11/15/2007 | 280 J | 10/23/2007 | 187 J |
| | | Unknown hydrocarbons | 5 J | 9/25/2007 | 25 J | 10/15/2007 | 14 J |
| SP-106 | Post-Primary GAC | 1-Nonanal | 8 J | 7/31/2007 | 16 J | 8/7/2007 | 12 J |
| | | 1-Pentene | 22 J | 7/11/2007 9/18/2007 | 160 J | 7/17/2007 | 68 J |
| | | Acetaldehyde | 10 J | 10/29/2008 | 15 J | 11/15/2007 | 12 J |
| | | Acetophenone | 7 J | 12/4/2007 | 15 J | 9/25/2007 | 10.6 J |
| | | Dimethylbutanes | 114 J | 12/27/2007 | 840 J | 12/11/2007 | 379 J |
| | | Isobutane | 5 J | 7/11/2007 | 28 J | 7/17/2007 | 17 J |
| | | Methylbutanes | 6 J | 7/25/2007 | 40 J | 7/31/2007 | 23.6 J |
| | | Methylcyclopentane | 76 J | 10/29/2007 | 260 J | 12/11/2007 12/27/2007 | 160 J |
| | | Methylethylbenzene | 7 J | 11/20/2007 | 12 J | 7/25/2007 7/27/2007 | 10 J |
| | | Methylpentane | 17 J | 7/17/2007 | 6,000 J | 12/11/2007 12/27/2007 | 852 J |
| | | n-Pentane | 10 J | 10/29/2007 | 24 J | 11/27/2007 | 18.4 J |
| | | Total hydrocarbons | 54 J | 7/25/2007 | 640 J | 10/1/2007 | 194 J |
| | | Unknown hydrocarbons | 10 J | 10/23/2007 | 290 J | 10/1/2007 | 58 J |
| SP-108 | Post-Secondary GAC | Acetophenone | 6 J | 12/4/2007 | 16 J | 9/25/2007 | 10 J |
| | | Cyclopentane | 6 J | 10/23/2007 | 89 J | 12/4/2007 | 33 J |
| | | Dimethylundecane | 33 J | 10/8/2007 | 39 J | 7/11/2007 | 36 J |
| | | Dimethylbutanes | 22 J | 12/11/2007 | 467 J | 12/20/2007 | 155 J |
| | | Isobutane | 4 J | 7/25/2007 | 16 J | 5/31/2007 | 9.7 J |
| | | Methylbutanes | 8 J | 11/7/2007 | 110 J | 12/11/2007 | 51 J |
| | | Methylcyclopentane | 10 J | 9/18/2007 | 190 J | 12/20/2007 | 20.5 J |
| | | Methylethylbenzene | 7 J | 11/27/2007 | 25 J | 7/31/2007 | 14.5 J |
| | | Methylpentane | 6 UJ | 10/23/2007 | 257 J | 5/31/2007 | 95 J |
| | | n-Pentane | 12 J | 11/7/2007 | 31 J | 12/20/2007 | 15 J |
| | | Total hydrocarbons | 64 J | 7/25/2007 | 590 J | 10/1/2007 | 192 J |
| | | Unknown hydrocarbons | 7 J | 11/27/2007 | 229 J | 10/1/2007 | 34 J |
| SP-109 | Final Effluent | 1-Pentene | 9 J | 10/29/2007 | 34 J | 11/7/2007 | 22 J |
| | | Acetophenone | 6 J | 10/29/2007 | 17 J | 7/25/2007 | 10 J |
| | | Butane | 6 J | 9/18/2007 | 7 J | 7/25/2007 | 6 J |
| | | Cyclohexanone | 26 J | 10/15/2007 | 29 J | 8/7/2007 | 28 J |

Table 3.7
TIC Analytical Results in Vapor Samples
Pemaco Superfund Site, Maywood, CA

| Station ID | Description | TIC Detected | Minimum | | Maximum | | Average |
|---------------------|-------------------|------------------------|----------------------|----------------------|----------------------|--------------------|----------------------|
| | | | Concentration (ppbv) | Date | Concentration (ppbv) | Date | Concentration (ppbv) |
| SP-109 Continued | Final Effluent | Cyclopentane | 22 J | 11/15/07 12/20/07 | 48 J | 11/27/2007 | 31 J |
| | | Dimethyloctane | 35 J | 12/27/2007 | 43 J | 7/12/2007 | 39 J |
| | | Dimethylpentane | 53 J | 10/1/2007 | 430 J | 11/20/2007 | 242 J |
| | | Dimethylbutanes | 9 J | 11/27/2007 | 940 J | 11/20/2007 | 201 J |
| | | Isobutane | 8 J | 7/12/2007 | 14 J | 7/25/2007 | 11 J |
| | | Methylbutanes | 50 J | 12/20/2007 | 200 J | 12/11/2007 | 109 J |
| | | Methylethylbenzene | 8 J | 10/29/2007 | 32 J | 7/25/2007 | 22 J |
| | | Methylcyclopentane | 11 J | 11/27/2007 | 760 J | 11/20/2007 | 163 J |
| | | Methylhexane | 6 J | 10/8/2007 | 270 J | 11/20/2007 | 80 J |
| | | Methylpentane | 7 J | 9/18/2007 | 5,900 J | 11/20/2007 | 799 J |
| | | n-Pentane | 16 J | 12/27/2007 | 97 J | 11/20/2007 | 46 J |
| | | Total hydrocarbons | 66 J | 10/8/2007 | 430 J | 10/23/2007 | 182 J |
| SP-111 | DPE-A Manifold | Unknown hydrocarbons | 8 J | 9/25/2007 | 66 J | 10/8/2007 | 34 J |
| | | Dimethylcyclohexane | 300 J | 10/1/2007 | 2,400 J | 8/7/2007 | 1,068 J |
| | | Dimethylbutanes | 1,930 J | 10/1/2007 | 125,000 J | 7/31/2007 | 27,177 J |
| | | Dimethylpentane | 710 J | 10/8/2007 | 22,400 J | 7/31/2007 | 5,101 J |
| | | Methylheptane isomers | 640 J | 9/5/2007 | 1,500 J | 8/7/2007 | 1,070 J |
| | | Methylbutanes | 10 J | 10/23/2007 | 7,800 J | 7/31/2007 | 3,905 J |
| | | Methylcyclopentane | 9 J | 9/25/2007 | 100,000 J | 7/31/2007 | 17,992 J |
| | | Methylhexane | 350 J | 10/8/2007 | 16,000 J | 7/31/2007 | 3,346 J |
| | | Methylpentane | 5 J | 12/11/2007 | 790,000 J | 7/31/2007 | 165,492 J |
| | | n-Octane | 60 J | 10/8/2007 | 640 J | 11/20/2007 | 350 J |
| SP-112 | DPE-B Manifold | n-Pentane | 130 J | 10/8/2007 | 2,300 J | 10/15/2007 | 853 J |
| | | Unknown hydrocarbons | 8 J | 10/23/2007 | 47 J | 9/25/2007 | 27 J |
| | | Butane | 8 J | 9/25/2007 | 1,100 J | 11/20/2007 | 529 J |
| | | Dimethylbutanes | 4 J | 10/23/2007 | 2,240 J | 7/31/2007 | 528 J |
| | | Isobutane | 120 J | 12/4/2007 | 4,600 J | 7/17/2007 | 1,518 J |
| | | Methylbutanes | 18 J | 10/23/2007 | 2,100 J | 7/17/2007 | 488 J |
| | | Methylcyclohexane | 89 J | 12/27/2007 | 260 J | 7/25/2007 | 172 J |
| | | Methylcyclopentane | 7 J | 10/23/2007 | 1,100 J | 7/11/2007 | 344 J |
| | | Methylhexane | 6 J | 10/23/2007 | 180 J | 7/17/2007 | 87 J |
| | | Methylpentane | 8 J | 9/25/2007 | 10,500 J | 7/11/2007 | 2,080 J |
| SP-113 | DPE-D Manifold | n-Pentane | 6 J | 10/23/2007 | 280 J | 7/31/2007 | 134 J |
| | | Unknown hydrocarbons | 8J | 10/23/2007 | 47 J | 9/25/2007 | 27 J |
| | | Butane | 300 J | 8/7/2007 | 20,000 J | 6/19/2007 | 6,091 J |
| | | Dimethylbutanes | 37 J | 9/25/2007 | 6,400 J | 7/17/2007 | 1,913 J |
| | | Isobutane | 400 J | 8/7/2007 | 27,000 J | 7/11/2007 | 11,592 J |
| | | Methylbutanes | 11 J | 10/23/2007 | 16,000 J | 7/17/2007 | 5,174 J |
| | | Methylcyclohexane | 150 J | 11/7/2007 | 630 J | 12/27/2007 | 427 J |
| | | Methylcyclopentane | 7 J | 10/23/2007 | 5,700 J | 7/17/2007 | 1,203 J |
| | | Methylhexane | 35 J | 9/25/2007 | 1,000 J | 7/17/2007 | 411 J |
| | | Methylpentane | 35 J | 10/23/2007 | 55,000 J | 7/17/2007 | 11,195 J |
| SP-114 | DPE-C Manifold | n-Pentane | 340 J | 8/7/2007 | 7,800 J | 11/27/2007 | 2,050 J |
| | | Trimethylcyclohexanone | 340 J | 9/18/2007 | 2,400 J | 8/7/2007 | 952 J |
| | | Dimethylbutanes | 22 J | 11/15/2007 | 3,900 J | 5/31/2007 | 977 J |
| | | Dimethylpentane | 8 J | 11/15/2007 | 1,000 J | 5/31/2007 | 504 J |
| | | Methylbutanes | 13 J | 11/7/2007 | 340 J | 11/27/2007 | 184 J |
| | | Methylcyclopentane | 4 J | 8/14/2007 | 430 J | 5/31/07 6/19/07 | 160 J |
| | | Methylhexane | 12 UJ | 11/20/2007 | 21 J | 11/15/2007 | 17 J |
| | | Methylpentane | 26 J | 8/14/2007 | 7,700 J | 5/31/2007 | 1,644 J |
| | | n-Pentane | 10 J | 11/7/2007 | 160 J | 11/27/2007 | 85 J |
| | | Trimethylcyclohexanone | 6 J | 12/11/07 12/27/07 | 69 J | 11/27/2007 | 44 J |
| SP-114 | DPE-C Manifold | Unknown hydrocarbons | 8 J | 11/7/2007 | 21 J | 11/27/2007 | 14 J |

Table 3.7
TIC Analytical Results in Vapor Samples
Pemaco Superfund Site, Maywood, CA

| Station ID | Description | TIC Detected | Minimum | | Maximum | | Average |
|------------|---------------|-----------------------|----------------------|-------------------------|----------------------|------------|----------------------|
| | | | Concentration (ppbv) | Date | Concentration (ppbv) | Date | Concentration (ppbv) |
| SP-115 | VE-3 Manifold | Butane | 5 J | 10/23/2007 | 140 J | 9/5/2007 | 73 J |
| | | Dimethylbutanes | 34 J | 8/14/2007 | 88,000 J | 8/7/2007 | 19,077 J |
| | | Dimethylpentane | 1,100 J | 12/27/2007 | 18,900 J | 9/18/2007 | 8,164 J |
| | | Methylbutanes | 14 J | 10/23/2007 | 8,100 J | 8/7/2007 | 2,453 J |
| | | Methylcyclopentane | 17 J | 12/11/2007 | 97,000 J | 8/7/2007 | 24,227 J |
| | | Methylhexane | 2,300 J | 12/27/2007 | 13,000 J | 8/7/2007 | 5,669 J |
| | | Methylpentane | 53 J | 12/11/2007 | 750,000 J | 8/7/2007 | 161,302 J |
| | | n-Pentane | 520 J | 9/25/2007 | 7,200 J | 8/7/2007 | 2,365 J |
| SP-116 | VE-4 Manifold | Unknown hydrocarbons | 6.2 J | 10/23/2007 | 3,900 J | 10/8/2007 | 1,803 J |
| | | Methylcyclopentane | 13 J | 10/23/2007 | 1,6000 J | 10/29/2007 | 5,365 J |
| | | Methylpentane | 75 J | 10/23/2007 | 280 J | 9/18/2007 | 178 J |
| SP-801 | ERH Zone 801 | Acetaldehyde | 73 J | 12/27/2007 | 120 J | 12/20/2007 | 97 J |
| | | Butane | 77 J | 12/20/2007 | 340 J | 11/8/2007 | 176 J |
| | | Dimethylbutanes | 66 J | 12/11/2007 | 440 J | 10/1/2007 | 166 J |
| | | Ethylcyclopropane | 30 J | 10/15/2007 | 60 J | 9/27/2007 | 45 J |
| | | Isobutane | 27 J | 10/15/2007 | 500 J | 11/8/2007 | 177 J |
| | | Methylbutanes | 31 J | 10/15/2007 | 190 J | 11/8/2007 | 97 J |
| | | Methylcyclopentane | 29 J | 10/15/2007 | 360 J | 10/1/2007 | 114 J |
| | | Methylpentane | 260 J | 10/1/2007 | 2,900 J | 12/27/2007 | 843 J |
| | | n-Pentane | 37 J | 10/15/2007 | 99 J | 11/8/2007 | 62 J |
| SP-802 | ERH Zone 802 | Unknown hydrocarbons | 54 J | 12/4/2007 | 62 J | 12/11/2007 | 58 J |
| | | Dimethylbutanes | 1700 J | 12/20/2007 | 23,000 J | 9/27/2007 | 8,544 J |
| | | Dimethylpentane | 2,400 J | 11/27/2007 | 9,000 J | 9/27/2007 | 5,340 J |
| | | Methylcyclopentane | 2,800 J | 10/8/2007 | 24,000 J | 9/27/2007 | 11,173 J |
| | | Methylhexane | 1,100 J | 10/8/2007 10/15/2007 | 5,100 J | 9/27/2007 | 2,538 J |
| SP-803 | ERH Zone 803 | Methylpentane | 4,200 J | 11/8/2007 | 157,000 J | 9/27/2007 | 52,854 J |
| | | Dimethylcyclohexane | 2,090 J | 10/8/2007 | 4,400 J | 10/15/2007 | 3,348 J |
| | | Dimethylbutanes | 11,000 J | 12/20/2007 | 168,000 J | 9/27/2007 | 52,075 J |
| | | Dimethylpentane | 7,000 J | 12/20/2007 | 78,000 J | 9/27/2007 | 26,833 J |
| | | Methylheptane isomers | 600 J | 10/8/2007 | 5,300 J | 11/15/2007 | 2,950 J |
| | | Methylcyclopentane | 21,000 J | 12/20/2007 | 200,000 J | 9/27/2007 | 76,000 J |
| | | Methylpentane | 490 J | 10/8/2007 | 1,130,000 J | 9/27/2007 | 408,345 J |
| | | n-Octane | 1,100 J | 10/8/2007 | 6,300 J | 10/23/2007 | 4,125 J |
| | | n-Pentane | 1,900 J | 11/15/2007 | 11,000 J | 9/27/2007 | 5,088 J |
| SP-804 | ERH Zone 804 | Unknown hydrocarbons | 1,900 J | 10/23/2007 | 78,000 J | 10/1/2007 | 28,966 J |
| | | Acetaldehyde | 90 J | 11/20/2007 | 190 J | 12/20/2007 | 135 J |
| | | Butane | 60 J | 10/1/2007 | 86 J | 11/8/2007 | 71 J |
| | | Cyclohexanone | 47 J | 10/8/2007 | 590 J | 12/20/2007 | 243 J |
| | | Dimethylbutanes | 68 J | 11/20/2007 | 16,900 J | 9/27/2007 | 3,096 J |
| | | Dimethylpentane | 240 J | 10/8/2007 | 6,600 J | 9/27/2007 | 3,420 J |
| | | Methylcyclopentane | 63 J | 11/8/2007 | 20,000 J | 9/27/2007 | 2,297 J |
| | | Methylhexane | 72 J | 12/11/2007 | 3,700 J | 9/27/2007 | 1,401 J |
| | | Methylpentane | 220 J | 11/27/2007 | 131,000 J | 9/27/2007 | 12,977 J |
| | | n-Pentane | 120 J | 10/8/2007 | 1,200 J | 9/27/2007 | 660 J |
| SP-805 | ERH Zone 805 | Unknown hydrocarbons | 58 J | 11/8/2007 | 250 J | 10/30/2007 | 125 J |
| | | Dimethylbutanes | 110 J | 10/8/2007 | 23,800 J | 11/15/2007 | 8322 J |
| | | Dimethylpentane | 5,400 J | 12/4/2007 | 14,200 J | 11/15/2007 | 10,275 J |
| | | Methylcyclopentane | 110 J | 10/8/2007 | 34,000 J | 11/15/2007 | 13,842 J |
| | | Methylhexane | 1,900 J | 12/27/2007 | 9,100 J | 11/15/2007 | 5,267 J |
| | | Methylpentane | 760 J | 10/8/2007 | 202,000 J | 11/15/2007 | 66,576 J |
| | | n-Pentane | 48 J | 11/8/2007 | 79 J | 10/23/2007 | 67 J |
| | | Unknown hydrocarbons | 68 J | 10/23/2007 | 2,500 J | 11/15/2007 | 924 J |

Notes:

Analyses were performed by EPA Region 9 laboratory using EPA Method TO-15 .

Averages were calculated for positive detections of TICs that were detected at least 2 times in samples collected during 2007.

For a complete list of TIC detections, see [Table A2.2](#) in [Appendix 2](#).

ERH - electrical resistance heating; FTO - flameless thermal oxidizer; GAC - granular activated carbon; TICs - tentatively identified compounds

J - estimated detection

ppbv - part per billion by volume

Table 3.8
Light Hydrocarbon Analytical Results for the Influent to the Vapor Treatment System
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | PID ¹ | Butane | Ethane | Ethene | Methane | n-Hexane | n-Pentane | Propane |
|------------|------------|-------|------------------|------------|------------|--------|--------------|------------|------------|------------|
| Station ID | Date | Units | | | | | | | | |
| SP-102 | 6/20/2007 | ppmv | 88.6 | 9.5 | 100 | 1 U | 5,200 | 320 | 9.7 | 22 |
| SP-102 | 7/11/2007 | ppmv | 44.3 | 4.6 | 51 | 1 U | 2,600 | 350 | 9.8 | 11 |
| SP-102 | 7/17/2007 | ppmv | 61.4 | 7.3 | 78 | 1 U | 3,800 | 280 | 10 | 17 |
| SP-102 | 7/25/2007 | ppmv | -- | 3.7 | 37 | 1 U | 2,000 | 250 | 11 | 8.6 |
| SP-102 | 7/31/2007 | ppmv | 156 | 1 U | 5.9 | 1 U | 420 | 130 | 1.8 | 1.3 |
| SP-102 | 8/7/2007 | ppmv | 194 | 1.5 | 14 | 1 U | 860 | 820 | 19 | 3.7 |
| SP-102 | 9/5/2007 | ppmv | 262 | 2 | 23 | 1 U | 1,100 | 260 | 5.3 | 5.7 |
| SP-102 | 9/11/2007 | ppmv | 1,281 | 1.2 | 12 | 1 U | 670 | 730 | 13 | 3.1 |
| SP-102 | 9/18/2007 | ppmv | 970 | 1.4 | 15 | 1 U | 890 | 570 | 9.5 | 3.7 |
| SP-102 | 9/25/2007 | ppmv | 340 | 1.3 | 14 | 1 U | 900 | 450 | 7.3 | 3.3 |
| SP-102 | 10/1/2007 | ppmv | 85 | 1 U | 1 U | 1 U | 120 | 170 | 2.5 | 1 U |
| SP-102 | 10/8/2007 | ppmv | 183.6 | 1 U | 1 U | 1 U | 290 | 370 | 5.5 | 1 U |
| SP-102 | 10/15/2007 | ppmv | 160 | 1 U | 1 U | 1 U | 240 | 370 | 5.4 | 1 U |
| SP-102 | 10/23/2007 | ppmv | 232 | 2.1 | 19 | 1 U | 1,200 | 730 | 17 | 4.8 |
| SP-102 | 10/29/2007 | ppmv | 446 | 1 U | 6.3 | 1 U | 440 | 130 | 2 | 1.4 |
| SP-102 | 11/7/2007 | ppmv | 375 | 1.9 | 21 | 1 U | 1,200 | 190 | 3.2 | 5.1 |
| SP-102 | 11/15/2007 | ppmv | 168 | 1 U | 1 U | 1 U | 150 | 220 | 3.2 | 1 U |
| SP-102 | 11/20/2007 | ppmv | 386 | 1 U | 3.7 | 1 U | 290 | 220 | 3.5 | 1 U |
| SP-102 | 11/27/2007 | ppmv | 308 | 1.7 | 19 | 1 U | 1,000 | 170 | 3 | 4.7 |
| SP-102 | 12/4/2007 | ppmv | 274 | 3.7 | 41 | 1 U | 2,200 | 170 | 3.7 | 9.9 |
| SP-102 | 12/11/2007 | ppmv | 280 | 1.2 | 11 | 1 U | 620 | 150 | 2.7 | 3 |
| SP-102 | 12/20/2007 | ppmv | 487 | 1.6 | 12 | 1 U | 700 | 180 | 3.6 | 3.5 |
| SP-102 | 12/27/2007 | ppmv | 33.1 | 1.7 | 15 | 1 U | 760 | 100 | 2.4 | 4.2 |

Notes:

1 - PID was calibrated for 100 ppm Isobutylene gas before each measurement.

Analyses were performed by Calscience Environmental Laboratories, Inc. using EPA Method TO-3(M) .

Bolded results indicate positive detections.

PID - photoionization detector

U - not detected above the stated reporting limit

--" - not available

ppmv - part per million by volume

Table 3.9
VOC Analytical Results for the Vapor Treatment System Samples
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,2,4-Trichlorobenzene | 1,2,4-Trimethylbenzene | 1,3,5-Trimethylbenzene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroethane | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | Freon 113* | Hexachlorobutadiene | Isopropanol | m,p-Xylene | Methylene chloride | n-Hexane | o-Xylene | Propylene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Vinyl chloride | | | |
|--------------------------------|--------------------|-----------|-------|--------------------|--------------------|------------------------|------------------------|------------------------|-------------|------------|---------|---------|------------------|--------------|------------|---------------|------------------------|-------------|--------------|------------|---------------------|-------------|------------|--------------------|----------|----------|-----------|-------------------|-----------------|---------|--------------------------|-----------------|----------------|-------|--|--|
| Maximum Emission Limit (ppbv): | | | | 74 | 133,700 | - | NL | - | 8.4 | - | NL | 19 | 116,100 | - | - | - | NL | - | 124,800 | - | NL | - | 124,800 | - | - | 124,800 | - | 24 | - | 143,900 | NL | 110 | 31 | | | |
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| SP-106 | Post-Primary GAC | 5/31/2007 | ppbv | 1.3 U | 1.3 U | 1.3 UJ | 1.3 U | 1.3 U | 1.3 U | - | 39 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 UJ | 1.3 U | 2.6 U | 1.3 U | 3.8 | 1.3 U | 4.6 | 1.3 U | - | 5.8 | 1.3 U | 3.5 | 1.3 U | | |
| SP-108 | Post-Secondary GAC | 5/31/2007 | ppbv | 1.6 U | 1.6 U | 1.6 UJ | 1.6 U | 1.6 U | 1.6 U | - | 7.4 | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 UJ | 1.6 U | 3.2 U | 1.6 U | 54 | 1.6 U | 37 | 1.6 U | - | 15 | 1.6 U | 8.3 | 1.6 U | | |
| SP-106 | Post-Primary GAC | 6/14/2007 | ppbv | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | - | 34 | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 3.2 U | 1.6 U | 1.6 U | 1.6 U | 4.5 UJ | 1.6 U | - | 5.2 | 1.6 U | 1.6 U | 1.6 U | | |
| SP-108 | Post-Secondary GAC | 6/14/2007 | ppbv | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | - | 10 | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 1.6 U | 3.3 U | 1.6 U | 91 | 1.6 U | 16 | 1.6 U | - | 2.8 J | 1.6 U | 12 | 1.6 U | | |
| SP-106 | Post-Primary GAC | 7/11/2007 | ppbv | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | - | 21 J | 0.5 U | 0.5 J | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 0.5 U | 1 U | 0.5 U | 0.5 U | 0.5 U | 1.5 | 0.5 U | - | 1.1 | 0.5 U | 0.5 U | 0.5 U | | | |
| SP-108 | Post-Secondary GAC | 7/11/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | - | 8 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.7 U | 1.4 U | 1.4 U | 1.4 U | 5.4 | 1.4 U | - | 1.4 U | 1.4 U | 1.4 U | 1.4 U | | | |
| SP-109 | Final Effluent | 7/12/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | - | 15 | 1.3 U | 1.9 J | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 1.3 U | 2.5 J | 1.3 U | - | 1.3 U | 1.3 U | 1.3 U | 1.3 U | | | | |
| SP-106 | Post-Primary GAC | 7/17/2007 | ppbv | 2 U | 2.2 J | 2 U | 2 U | 2 U | 2 UJ | - | 37 | 2 U | 2 U | 2 U | 2 U | 2 U | 2 J | 2 U | 2 U | 2 U | 2 U | 2 U | 4 U | 2 U | 5 | 2 U | 10 | 2 U | - | 6.7 | 2 U | 2.7 J | 2 U | | | |
| SP-108 | Post-Secondary GAC | 7/17/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 UJ | - | 14 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 1.4 U | 1.4 U | 3.5 | 1.4 U | - | 1.8 J | 1.4 U | 1.4 U | 1.4 U | | | |
| SP-109 | Final Effluent | 7/17/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 UJ | - | 7.6 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 1.4 U | 1.4 U | 4.4 | 1.4 U | - | 1.4 U | 1.4 U | 1.4 U | 1.4 U | | | |
| SP-106 | Post-Primary GAC | 7/25/2007 | ppbv | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 UJ | - | 27 J | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.7 J | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 1.3 U | 0.6 U | 0.6 U | 0.6 U | 1 J | 0.6 U | - | 1.6 | 0.6 U | 0.6 U | 0.6 U | | | |
| SP-108 | Post-Secondary GAC | 7/25/2007 | ppbv | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 UJ | - | 11 | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 0.6 U | 1.3 U | 0.6 U | 0.6 U | 0.6 U | 2.2 | 0.6 U | - | 0.6 J | 0.6 U | 0.6 U | 0.6 U | | | |
| SP-109 | Final Effluent | 7/25/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 UJ | - | 2.6 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 1.3 U | 1.3 U | 6.9 | 1.3 U | - | 1.3 U | 1.3 U | 1.3 U | 1.3 U | | | |
| SP-106 | Post-Primary GAC | 7/31/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | - | 26 J | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 3.8 UJ | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 3.4 UJ | 1.3 U | 1.5 J | 1.3 U | 4.2 | 4.8 UJ | 1.3 U | 2.2 UJ | 1.3 U | | | |
| SP-108 | Post-Secondary GAC | 7/31/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | - | 20 J | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 3 UJ | 1.4 U | 1.4 U | 1.4 U | 2.4 J | 3.2 UJ | 1.4 U | 2.3 UJ | 1.4 U | | | |
| SP-109 | Final Effluent | 7/31/2007 | ppbv | 1.4 U | 3.3 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | - | 4.3 UJ | 1.4 UJ | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 40 | 160 UJ | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 1,800 UJ | 1.4 U | 18 | 1.4 U | 2.6 J | 130 UJ | 1.7 J | 360 | 2.9 UJ | | | |
| SP-106 | Post-Primary GAC | 8/7/2007 | ppbv | 1.3 U | 1.3 U | 1.3 UJ | 1.3 U | 1.3 U | 1.3 U | - | 31 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 5.1 | 9.7 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 1.8 J | 1.3 U | 2.1 J | 1.3 U | 1,300 J | 2.2 J | 1.3 U | 12 | 1.3 U | | | |
| SP-108 | Post-Secondary GAC | 8/7/2007 | ppbv | 1.3 U | 1.3 U | 1.3 UJ | 1.3 U | 1.3 U | 1.3 U | - | 100 J | 1.3 U | 1.3 U | 1.3 U | 12 | 4.8 | 4.5 | 70 J | 1.3 U | 1.3 U | 1.3 U | 3.5 | 2.6 U | 1.3 U | 34 | 1.3 U | 5.1 | 1.3 U | 11,000 J | 4.6 | 1.3 U | 81 | 2.6 | | | |
| SP-109 | Final Effluent | 8/7/2007 | ppbv | 1.4 U | 1.4 U | 1.4 UJ | 1.4 U | 1.4 U | 1.4 U | - | 15 | 1.4 U | 1.4 U | 1.4 U | 1.9 J | 1.4 U | 1.4 U | 13 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.7 U | 1.4 U | 5 | 1.4 U | 1.5 J | 1.4 U | 4,100 | 1.4 U | 1.4 U | 27 | 1.4 U | | | |
| SP-104 | Post-FTO | 8/14/2007 | ppbv | 4 U | 4 U | 4 U | 4 U | 4 U | 4 U | - | 17 UJ | 4 U | 4 U | 4 U | 4 U | 4 U | 4 U | 14 | 4 U | 4 U | 4 U | 4 U | 8 U | 4 U | 180 | 4 U | 4 U | 4 U | 44 | 14 UJ | 4 U | 8.3 J | 4 U | | | |
| SP-106 | Post-Primary GAC | 8/14/2007 | ppbv | 3.7 U | 3.7 U | 3.7 U | 3.7 U | 3.7 U | 3.7 U | - | 16 UJ | 3.7 U | 3.7 U | 3.7 U | 3.7 U | 3.7 U | 10 | 3.7 U | 3.7 U | 3.7 U | 3.7 U | 3.7 U | 7.5 U | 3.7 U | 3.7 U | 3.7 U | 59 | 3.7 U | 3.7 U | 5.4 J | 3.7 U | 5.4 J | 3.7 U | | | |
| SP-108 | Post-Secondary GAC | 8/14/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | - | 18 UJ | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.9 U | 1.4 U | 1.4 U | 1.4 U | 2 J | 1.4 U | 47 | 2.3 UJ | 1.4 U | 1.4 U | 1.4 U | | | |
| SP-109 | Final Effluent | 8/14/2007 | ppbv | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | - | 11 UJ | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 9.2 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 4.6 U | 130 | 4.6 U | 4.6 U | 4.6 U | 4.6 U | | | |
| SP-104 | Post-FTO | 9/5/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 5.5 | 7.3 | 1.4 U | 2.2 J | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 6.1 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | | | |
| SP-106 | Post-Primary GAC | 9/5/2007 | ppbv | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 7.3 J | 18 | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 3.8 U | 7.5 U | 3.8 U | 3.8 U | 3.8 U | 9 | 3.8 U | 8.3 | 3.8 U | 3.8 U | 3.8 U | 3.8 U | | | |
| SP-108 | Post-Secondary GAC | 9/5/2007 | ppbv | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 4.3 J | 5.6 J | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | 3.9 U | | | | | | | | | | | | | | | |

Table 3.9
VOC Analytical Results for the Vapor Treatment System Samples
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-Dichloroethane | 1,1-Dichloroethene | 1,2,4-Trichlorobenzene | 1,2,4-Trimethylbenzene | 1,3,5-Trimethylbenzene | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Carbon disulfide | Chloroethane | Chloroform | Chloromethane | cis-1,2-Dichloroethene | Cyclohexane | Ethylbenzene | Freon 113* | Hexachlorobutadiene | Isopropanol | m,p-Xylene | Methylene chloride | n-Hexane | o-Xylene | Propylene | Tetrachloroethene | Tetrahydrofuran | Toluene | trans-1,2-Dichloroethene | Trichloroethene | Vinyl chloride | | | | |
|--------------------------------|--------------------|------------|-------|--------------------|--------------------|------------------------|------------------------|------------------------|-------------|------------|---------|---------|------------------|--------------|------------|---------------|------------------------|-------------|--------------|------------|---------------------|-------------|------------|--------------------|----------|----------|-----------|-------------------|-----------------|---------|--------------------------|-----------------|----------------|-------|--|--|--|
| Maximum Emission Limit (ppbv): | | | | 74 | 133,700 | - | NL | - | 8.4 | - | NL | 19 | 116,100 | - | - | - | NL | - | 124,800 | - | NL | - | 124,800 | - | - | 124,800 | - | 24 | - | 143,900 | NL | 110 | 31 | | | | |
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| SP-104 | Post-FTO | 10/15/2007 | ppbv | 1.7 U | 1.7 U | 1.7 U | 1.7 U | 1.7 U | 1.7 U | 170 | 42 | 1.7 U | 1.7 U | 1.7 U | 1.7 U | 1.9 J | 5.1 | 21 | 1.7 U | 1.7 U | 1.7 U | 1.7 U | 1.7 U | 3.4 U | 1.7 U | 210 | 1.7 U | 3.5 | 1.7 U | 580 | 40 | 1.7 U | 17 | 1.7 U | | | |
| SP-106 | Post-Primary GAC | 10/15/2007 | ppbv | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 36 UJ | 49 | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 2.3 UJ | 2.6 J | 25 | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 2.3 U | 4.6 U | 2.3 U | 2.3 U | 2.3 U | 4.6 J | 2.3 U | 18 UJ | 2.3 U | 40 | 2.3 U | 2.3 U | | | |
| SP-108 | Post-Secondary GAC | 10/15/2007 | ppbv | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 11 UJ | 16 | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 1.5 UJ | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 1.5 U | 2.9 U | 1.5 U | 2.5 J | 1.5 U | 2 J | 1.5 U | 12 UJ | 1.5 U | 1.5 U | 1.5 U | 1.5 U | | | | |
| SP-109 | Final Effluent | 10/15/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 29 UJ | 3.8 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 UJ | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.9 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 180 UJ | 1.4 U | 1.4 U | 1.4 U | 1.4 U | | | |
| SP-104 | Post-FTO | 10/23/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 8.6 | 1.2 U | 1.2 U | 1.2 U | 1.8 J | 1.2 U | 1.2 U | 1.4 J | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.4 U | 1.2 U | 17 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 3.5 | 1.2 U | 1.2 U | 1.2 U | | | |
| SP-106 | Post-Primary GAC | 10/23/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 33 | 28 | 1.3 U | 1.7 J | 1.3 U | 1.6 J | 1.3 U | 2.7 | 28 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 2 J | 1.3 U | 2.4 J | 1.3 U | 7.9 | 3.4 | 1.3 U | 1.3 U | 1.3 U | | | | |
| SP-108 | Post-Secondary GAC | 10/23/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 6.7 | 14 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.7 U | 1.3 U | 6.3 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 3.1 | 1.3 U | 1.3 U | 1.3 U | | | | |
| SP-109 | Final Effluent | 10/23/2007 | ppbv | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 5.2 | 1.1 U | 3 | 1.1 U | 1.1 U | 1.7 J | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 2.2 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.1 U | 1.9 J | 1.1 U | 1.1 U | 1.1 U | | | | |
| SP-104 | Post-FTO | 10/29/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 UJ | 16 | 1.3 U | 1.3 U | 1.3 U | 2 J | 1.3 UJ | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.7 U | 1.3 U | 3.1 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | | | | |
| SP-106 | Post-Primary GAC | 10/29/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 22 J | 24 | 1.2 U | 1.2 U | 1.2 U | 1.4 J | 1.2 UJ | 2.1 J | 24 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.5 U | 1.2 U | 1.2 U | 1.2 U | 4.5 | 1.2 U | 7.3 | 2.2 J | 1.2 U | 1.2 U | 1.2 U | | | | |
| SP-108 | Post-Secondary GAC | 10/29/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 7 J | 12 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 UJ | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.3 U | 1.2 U | 1.2 U | 1.2 U | 1.3 J | 1.2 U | 1.2 U | 3.1 | 1.2 U | 1.2 U | 1.2 U | | | | |
| SP-109 | Final Effluent | 10/29/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 UJ | 2.8 | 1.2 U | 2.2 J | 1.2 U | 1.2 U | 1.9 J | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.5 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | | | | |
| SP-104 | Post-FTO | 11/7/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.8 | 13 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 4.3 UJ | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 38 UJ | 1.3 U | 1.8 UJ | 1.3 U | 1.3 U | 11 UJ | 1.3 U | 1.9 UJ | 1.3 U | | | | |
| SP-106 | Post-Primary GAC | 11/7/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 5.9 | 11 | 1.2 U | 1.2 U | 1.2 U | 3.1 | 1.2 U | 3.4 UJ | 50 UJ | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.4 U | 1.2 U | 23 UJ | 1.2 U | 1.4 UJ | 1.2 U | 12 | 10 UJ | 1.2 U | 2.6 UJ | 1.2 U | | | | |
| SP-108 | Post-Secondary GAC | 11/7/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 5.7 | 9.3 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.7 U | 1.4 U | 8.1 UJ | 1.4 U | 2.1 UJ | 1.4 U | 2.9 UJ | 3.3 UJ | 1.4 U | 1.4 U | 1.4 U | | | | |
| SP-109 | Final Effluent | 11/7/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 3.4 | 1.4 U | 1.5 J | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 3.5 UJ | 1.4 U | 1.6 UJ | 1.4 U | 2.5 UJ | 2.5 UJ | 1.4 U | 1.4 U | 1.4 U | | | | |
| SP-104 | Post-FTO | 11/15/2007 | ppbv | 1.3 U | 1.3 U | 1.3 UJ | 1.3 U | 1.3 U | 1.3 UJ | 1.3 UJ | 6.7 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 6.1 | 1.3 U | 1.3 U | 1.3 U | | | | |
| SP-106 | Post-Primary GAC | 11/15/2007 | ppbv | 1.2 U | 1.2 U | 1.2 UJ | 1.2 U | 1.2 U | 1.2 UJ | 1.2 UJ | 33 | 1.2 U | 1.2 U | 1.2 U | 1.9 J | 1.2 U | 1.5 J | 27 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.4 U | 1.2 U | 6.8 | 1.2 U | 3 | 1.2 U | 5.5 | 4.5 | 1.2 U | 1.2 U | 1.2 U | | | | |
| SP-108 | Post-Secondary GAC | 11/15/2007 | ppbv | 1.4 U | 1.4 U | 1.4 UJ | 1.4 U | 1.4 U | 1.4 UJ | 1.4 UJ | 16 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.9 U | 1.4 U | 2.3 J | 1.4 U | 1.6 J | 1.4 U | 1.4 U | 3 | 1.4 U | 1.4 U | 1.4 U | | | | |
| SP-109 | Final Effluent | 11/15/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.9 | 1.4 U | 1.8 J | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | | | | |
| SP-104 | Post-FTO | 11/20/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 UJ | 15 | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.4 UJ | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.7 U | 1.3 U | 23 UJ | 1.3 U | 3 | 1.3 U | 1.3 U | 4.8 | 1.3 U | 3.1 UJ | 1.3 U | | | | |
| SP-106 | Post-Primary GAC | 11/20/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 20 J | 25 | 1.2 U | 1.2 U | 1.2 U | 2.4 J | 1.2 U | 1.5 J | 39 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.4 U | 1.2 U | 8.9 UJ | 1.2 U | 2.1 J | 1.2 U | 6.9 | 4.7 | 1.2 U | 1.4 UJ | 1.2 U | | | | |
| SP-108 | Post-Secondary GAC | 11/20/2007 | ppbv | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 6.9 J | 13 | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 1.8 UJ | 1.2 U | 1.2 U | 1.2 U | 1.2 U | 2.4 U | 1.2 U | 18 UJ | 1.2 U | 1.8 J | 1.2 U | 1.2 U | 7.5 | 1.2 U | 1.2 U | 1.2 U | | | | |
| SP-109 | Final Effluent | 11/20/2007 | ppbv | 12 U | 12 U | 12 U | 12 U | 12 U | 12 UJ | 12 U | 22 J | 12 U | 12 U | 12 U | 12 U | 12 U | 12 U | 300 | 12 U | 12 U | 12 U | 12 U | 25 U | 12 U | 3,100 | 12 U | 12 U | 12 U | 12 U | 1,400 | 12 U | 12 U | 12 U | | | | |
| SP-104 | Post-FTO | 11/27/2007 | ppbv | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 15 | 1.3 U | 1.3 U | 1.3 U | 1.6 J | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 2.6 U | 1.3 U | 1.4 J | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.6 J | 1.3 U | 1.3 U | 1.3 U | | | | |
| SP-106 | Post-Primary GAC | 11/27/2007 | ppbv | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 6 | 6.3 | 1.4 U | 1.4 U | 1.4 U | 3.4 | 1.4 U | 1.4 U | 57 | 1.4 U | 1.4 U | 1.4 U | 1.4 U | 2.8 U | 1.4 U | 1.4 U | 1.4 U | | | | | | | | | | | |

Table 3.10
VOC Analytical Method Comparison for Vapor Samples from SP-104 and SP-109
Pemaco Superfund Site, Maywood, CA

| Station ID: | | SP-104 | | | | | | | | | | | | | | | | | | | | | | | |
|---------------------------------|-----------|-----------|-----------|-----------|-----------|----------|-----------|----------|-----------|-----------|-----------|-----------|-----------|------------|------------|------------|-----------|------------|------------|------------|------------|-----------|------------|------------|------------|
| Description: | | Post-FTO | | | | | | | | | | | | | | | | | | | | | | | |
| Date: | | 5/31/2007 | 6/18/2007 | 7/12/2007 | 7/25/2007 | 8/7/2007 | 8/14/2007 | 9/5/2007 | 9/11/2007 | 9/18/2007 | 9/25/2007 | 10/1/2007 | 10/8/2007 | 10/15/2007 | 10/23/2007 | 10/29/2007 | 11/7/2007 | 11/15/2007 | 11/20/2007 | 11/27/2007 | 11/30/2007 | 12/4/2007 | 12/11/2007 | 12/20/2007 | 12/27/2007 |
| Units: | | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv |
| Analyte | Method | | | | | | | | | | | | | | | | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15 SIM | 0.03 | 0.023 U | 0.064 | 0.024 U | 0.024 U | 0.057 | 0.028 U | 0.043 U | 0.027 U | 0.024 U | 0.03 U | 0.032 U | 0.024 U | 0.03 U | 0.03 U | 0.034 U | 0.029 U | 0.031 U | -- | 0.11 | 0.025 U | 0.079 | 0.027 U | 0.026 U |
| 1,1-Dichloroethane | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.03 U | 0.023 U | 0.028 U | 0.024 U | 0.024 U | 0.028 U | 0.028 U | 0.043 U | 0.027 U | 0.024 U | 0.03 U | 0.032 U | 0.024 U | 0.03 U | 0.03 U | 0.034 U | 0.029 U | 0.031 U | -- | 0.029 U | 0.025 U | 0.03 U | 0.027 U | 0.026 U |
| 1,1-Dichloroethene | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 26 | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.01 U | 0.012 U | 0.014 U | 0.012 U | 0.012 U | 0.014 U | 0.014 U | 0.021 U | 0.013 U | 0.012 U | 0.015 U | 0.016 U | 0.012 U | 0.015 U | 0.015 U | 0.017 U | 0.014 U | 0.016 U | -- | 0.014 U | 0.012 U | 0.015 U | 0.014 U | 0.013 U |
| 1,2,4-Trichlorobenzene | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 UJ | 1.3 UJ | 3 U | 2.4 UJ | 1.7 U | 1.2 U | 1.3 U | 1.3 UJ | 1.3 UJ | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 UJ | 1.3 UJ | 1.1 UJ |
| | TO-15SIM | 0.27 | 0.12 U | 0.14 U | 0.12 U | 0.12 U | 0.14 U | 0.14 U | 0.21 U | 0.13 U | 0.12 U | 0.15 U | 0.16 U | 0.12 U | 0.15 U | 0.15 U | 0.17 U | 0.14 U | 0.16 U | -- | 0.14 U | 0.12 U | 0.15 U | 0.14 U | 0.13 U |
| 1,2,4-Trimethylbenzene | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| 1,2-Dichlorotetrafluoroethane | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 UJ | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U | |
| 1,3,5-Trimethylbenzene | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.03 U | 0.023 U | 0.028 U | 0.024 U | 0.024 U | 0.028 U | 0.028 U | 0.043 U | 0.027 U | 0.024 U | 0.03 U | 0.032 U | 0.024 U | 0.03 U | 0.03 U | 0.034 U | 0.029 U | 0.031 U | -- | 0.029 U | 0.025 | 0.03 U | 0.031 | 0.027 |
| 1,4-Dioxane | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 UJ | 1.1 U |
| | TO-15 | -- | -- | -- | -- | -- | -- | 5.5 | 2 J | 5 J | 1.3 UJ | 4.9 J | 2.4 UJ | 170 | 1.2 U | 1.3 UJ | 2.8 | 1.3 UJ | 1.3 UJ | 1.3 U | -- | 3.4 | 0.9 U | 1.3 U | 1.1 UJ |
| 2-Butanone | TO-15SIM | 9 | 6 | 3.2 | 3.1 | 3.7 | 2.9 | 3 | 3.3 | 2 | 2 | 1.4 | 1.4 | 1.8 | 5.6 | 2.7 | 1.9 | 2.4 | 1.8 | -- | 2.4 | 1.9 | 2.3 | 1.8 | 1.4 |
| | TO-15 | -- | -- | -- | -- | -- | 17 UJ | 7.3 | 5.7 | 7.6 J | 5.4 | 19 | 7.7 | 42 | 8.6 | 16 | 13 | 6.7 | 15 | 15 | -- | 15 UJ | 0.9 U | 9.3 | 14 |
| Acetone | TO-15SIM | 5.46 | 4.1 | 8.3 | 6.3 | 6.3 | 6.7 J | 6 | 12 | 7.9 | 2.8 | 3.7 | 3.1 | 2 | 19 | 6.8 | 4.7 | 5.5 | 4 | -- | 3.9 | 4.3 | 5.8 | 4.3 | 4.6 |
| | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| Benzene | TO-15SIM | 0.1 | 0.12 | 0.1 | 0.084 | 0.12 | 0.22 | 0.071 U | 0.11 U | 0.067 U | 0.074 | 0.073 J | 0.081 U | 0.1 | 0.17 | 0.076 U | 0.2 | 0.14 | 0.15 | -- | 0.083 | 0.13 | 0.091 | 0.084 | 0.1 |
| | TO-15 | -- | -- | -- | -- | -- | 4 U | 2.2 J | 1.5 U | 1.4 U | 1.3 U | 7.2 | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 UJ |
| Carbon disulfide | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.19 | 0.049 | 0.036 | 0.03 | 0.15 | 0.039 | 0.028 U | 0.073 | 0.032 | 0.024 U | 0.03 U | 0.032 | 0.024 U | 0.047 | 0.038 | 0.034 U | 0.029 U | 0.031 U | -- | 0.029 U | 0.026 | 0.03 U | 0.041 | 0.042 |
| Carbon tetrachloride | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.07 U | 0.058 U | 0.07 U | 0.059 U | 0.06 U | 0.071 U | 0.071 U | 0.11 U | 0.067 U | 0.059 U | 0.074 U | 0.081 U | 0.059 U | 0.074 U | 0.076 U | 0.085 U | 0.072 U | 0.078 U | -- | 0.072 U | 0.062 U | 0.076 U | 0.068 U | 0.066 U |
| Chloroethane | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.8 J | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.6 J | -- | 1.4 J | 0.9 U | 1.6 J | 2.9 |
| | TO-15SIM | 1.21 | 1 | 1.1 | 1 | 1.8 | 1.3 | 0.44 | 2.1 | 0.34 | 0.21 | 0.42 | 1.4 | 1.3 | 2.1 | 1.6 | 1.4 | 0.63 | 0.8 | -- | 1.3 | 1.7 | 1.4 | 1.8 | 3.1 |
| Chloroform | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.9 J | 1.2 U | 1.3 UJ | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.14 | 0.23 | 0.19 | 0.13 | 0.18 | 0.34 | 0.17 | 0.16 | 0.28 | 0.1 | 0.14 | 0.12 | 0.1 | 0.43 | 0.18 | 0.2 | 0.18 | 0.19 | -- | 0.41 | 0.11 | 0.1 | 0.18 | 0.24 |
| Chloromethane | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 54 | 2.4 U | 5.1 | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15SIM | 0.03 U | 0.023 U | 0.028 U | 0.024 U | 0.024 U | 0.028 U | 0.028 U | 0.043 U | 0.027 U | 0.024 U | 0.03 U | 0.032 U | 0.024 U | 0.03 U | 0.03 U | 0.034 U | 0.029 U | 0.031 U | -- | 0.029 U | 0.025 U | 0.03 U | 0.027 U | 0.026U |
| <i>cis</i> -1,2-Dichloroethene | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 15 | 2.4 U | 21 | 1.4 J | 1.3 U | 4.3 UJ | 1.3 U | 2.4 UJ | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 6.7 UJ |
| | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 UJ | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| <i>cis</i> -1,3-Dichloropropene | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 UJ | 1.3 UJ | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| Cyclohexane | TO-15 | -- | -- | -- | -- | -- | 14 | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 15 | 9.2 | 21 | 1.4 J | 1.3 U | 4.3 UJ | 1.3 U | 2.4 UJ | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 6.7 UJ |
| | TO-15 | -- | -- | -- | -- | -- | 4 U | 1.4 U | 1.5 U | 1.4 U | 1.3 U | 3 U | 2.4 U | 1.7 U | 1.2 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | 1.3 U | -- | 1.3 U | 0.9 U | 1.3 U | 1.1 U |
| Dichlorodifluoromethane | TO-15SIM | 0.03 U | 0.023 U | 0.028 U | 0.024 U | 0.025 | 0.098 | 0.042 | 0.056 | 0.05 | | | | | | | | | | | | | | | |

Table 3.10
VOC Analytical Method Comparison for Vapor Samples from SP-104 and SP-109
Pemaco Superfund Site, Maywood, CA

| Station ID: | | SP-109 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-------------------------------|-----------|-------------|-----------|-----------|-----------|-----------|-----------|----------|-----------|----------|-----------|-----------|-----------|-----------|-----------|------------|------------|------------|-----------|------------|------------|------------|------------|-----------|------------|------------|------------|---------|--------|
| Description: | | Post-Carbon | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Date: | | 5/31/2007 | 6/18/2007 | 7/12/2007 | 7/17/2007 | 7/25/2007 | 7/31/2007 | 8/7/2007 | 8/14/2007 | 9/5/2007 | 9/11/2007 | 9/18/2007 | 9/25/2007 | 10/1/2007 | 10/8/2007 | 10/15/2007 | 10/23/2007 | 10/29/2007 | 11/7/2007 | 11/15/2007 | 11/20/2007 | 11/27/2007 | 11/30/2007 | 12/4/2007 | 12/11/2007 | 12/20/2007 | 12/27/2007 | | |
| Units: | | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | ppbv | | |
| Analyte | Method | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15 SIM | 0.03 U | 0.024 U | 0.15 | 0.023 U | 0.028 U | 0.03 U | 0.028 U | 0.023 U | 0.03 U | 0.029 U | 0.03 U | 0.025 U | 0.023 U | 0.023 U | 0.023 U | 0.028 U | 0.028 U | 0.032 U | 0.023 U | 0.023 U | 0.023 U | -- | 0.077 | 0.03 U | 0.048 | 0.028 U | 0.028 U | |
| 1,1-Dichloroethane | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15SIM | 0.03 U | 0.024 U | 0.03 U | 0.023 U | 0.028 U | 0.03 U | 0.028 U | 0.023 U | 0.03 U | 0.029 U | 0.03 U | 0.025 U | 0.023 U | 0.023 U | 0.023 U | 0.028 U | 0.028 U | 0.032 U | 0.024 | 0.031 | -- | 0.097 | 0.17 | 0.44 | 0.3 | 0.084 | | |
| 1,1-Dichloroethene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 3.3 | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15SIM | 0.01 U | 0.012 U | 0.015 U | 0.011 U | 0.014 U | 0.015 U | 0.014 U | 0.011 U | 0.015 U | 0.032 | 0.071 | 0.19 | 0.19 | 0.26 | 0.35 | 0.38 | 0.3 | 0.32 | 0.29 | 0.25 | -- | 0.27 | 0.33 | 0.44 | 0.29 | 0.1 | | |
| 1,2,4-Trichlorobenzene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 UJ | 4.6 U | 14 U | 14 U | 1.3 UJ | 3 | 1.3 U | 1.4 UJ | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 UJ | 1.3 UJ | | |
| | TO-15SIM | 0.13 U | 0.12 U | 0.15 U | 0.11 U | 0.14 U | 0.15 U | 0.14 U | 0.11 U | 0.15 U | 0.14 U | 0.15 U | 0.13 U | 0.12 U | 0.12 U | 0.11 U | 0.14 U | 0.14 U | 0.16 U | 0.12 U | 0.11 U | -- | 0.15 U | 0.15 U | 0.11 U | 0.14 U | 0.14 U | | |
| 1,2,4-Trimethylbenzene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| 1,2-Dichlorotetrafluoroethane | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| 1,3,5-Trimethylbenzene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| 1,4-Dichlorobenzene | TO-15SIM | 0.03 U | 0.024 U | 0.03 U | 0.023 U | 0.028 U | 0.03 U | 0.028 U | 0.023 U | 0.03 U | 0.029 U | 0.03 U | 0.025 U | 0.023 U | 0.023 U | 0.023 U | 0.028 U | 0.028 U | 0.032 U | 0.023 U | 0.023 U | -- | 0.03 U | 0.03 U | 0.023 U | 0.028 U | 0.028 U | | |
| | TO-15 | -- | -- | 1.3 U | 1.4 UJ | 1.3 UJ | 1.4 U | 1.4 U | 4.6 U | 14 UJ | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 UJ | 1.3 U | | |
| 2-Butanone | TO-15 | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | 14 U | 14 U | 1.3 UJ | 1.3 UJ | 1.3 UJ | 1.4 UJ | 29 UJ | 1.1 U | 1.2 UJ | 1.4 U | 1.4 U | 12 UJ | 1.3 UJ | -- | 2.8 | 2.4 U | 1.3 U | 1.3 UJ |
| | TO-15SIM | 1.2 | 0.78 | 0.38 | 0.26 | 0.17 | 0.57 | 0.41 | 0.36 | 0.36 | 0.21 | 0.18 | 0.88 | 0.27 | 0.22 | 0.15 | 0.6 | 0.36 | 3.8 | 1.2 | 0.26 | -- | 0.28 | 0.62 | 0.4 | 0.74 | 1.2 | | |
| Acetone | TO-15 | -- | -- | 15 | 7.6 | 2.6 | 4.3 UJ | 15 | 11 UJ | 18 J | 14 U | 4.5 J | 4.6 | 15 | 6.4 | 3.8 | 5.2 | 2.8 | 3.4 | 2.9 | 12 U | 3.2 | -- | 4 UJ | 8.3 J | 10 | 12 | | |
| | TO-15SIM | 4.62 | 1.6 | 2.8 | 0.66 | 0.9 | 2.2 | 2 | 0.87 | 1.4 | 0.81 | 0.91 | 2 | 2.1 | 0.58 U | 0.57 U | 1.5 | 1.4 | 9.1 | 6.4 | 1 | -- | 2.1 | 2.2 | 1.5 | 2.2 | 5.4 | | |
| Benzene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 UJ | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 3.7 | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 22 J | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15SIM | 0.08 | 0.1 | 0.099 | 0.057 U | 0.07 U | 0.084 | 0.13 | 0.066 | 0.074 U | 0.072 U | 0.074 U | 0.76 | 0.058 U | 0.058 U | 0.057 U | 0.07 U | 0.18 | 0.08 U | 0.058 U | 0.057 U | -- | 0.076 U | 0.076 U | 0.06 | 0.1 | 0.071 U | | |
| Carbon disulfide | TO-15 | -- | -- | 1.9 J | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 3 | 2.2 J | 1.5 J | 1.8 J | 12 U | 1.4 J | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 UJ | | |
| Carbon tetrachloride | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15SIM | 0.03 UJ | 0.024 U | 0.03 U | 0.023 U | 0.028 U | 0.03 U | 0.028 U | 0.023 U | 0.03 U | 0.029 U | 0.03 U | 0.025 U | 0.023 U | 0.023 U | 0.023 U | 0.028 U | 0.028 U | 0.032 U | 0.023 U | 0.023 U | -- | 0.03 U | 0.03 U | 0.023 U | 0.22 | 0.1 | | |
| Chloroethane | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |
| | TO-15SIM | 0.53 | 0.06 U | 0.076 U | 0.057 U | 0.07 U | 0.074 U | 0.07 U | 0.057 U | 0.074 U | 0.072 U | 0.074 U | 0.063 U | 0.058 U | 0.058 U | 0.057 U | 0.07 U | 0.071 U | 0.08 U | 0.058 U | 0.057 U | -- | 0.076 U | 0.076 U | 0.057 U | 0.07 U | 0.071 U | | |
| Chloroform | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.9 J | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 3.8 J | 4.2 | 2.9 | | |
| | TO-15SIM | 0.03 U | 0.024 U | 0.03 U | 0.023 U | 0.028 U | 0.03 U | 0.028 U | 0.023 U | 0.03 U | 0.029 U | 0.03 U | 0.025 U | 0.023 U | 0.023 U | 0.023 U | 0.028 U | 0.028 U | 0.032 U | 0.023 U | 0.023 U | -- | 0.056 | 0.28 | 3.5 | 7.9 | 3.1 | | |
| Chloromethane | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 UJ | 1.3 U | 1.4 U | 1.4 UJ | 1.7 J | 1.9 J | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 UJ | 1.3 U | 1.3 U | | |
| | TO-15SIM | 0.13 | 0.32 | 0.34 | 0.19 | 0.21 | 0.44 | 0.16 | 0.2 | 0.29 | 0.11 | 0.17 | 0.1 | 0.16 | 0.17 | 0.14 | 0.17 | 0.26 | 0.14 | 0.11 | 0.15 | -- | 0.22 | 0.16 | 0.25 | 0.24 | 0.2 | | |
| cis-1,2-Dichloroethene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 40 | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 3.3 J | 5.8 | 6 | | |
| | TO-15SIM | 0.03 U | 0.024 U | 0.03 U | 0.023 U | 0.028 U | 0.056 | 0.028 U | 0.023 U | 0.03 U | 0.029 U | 0.03 U | 0.025 U | 0.023 U | 0.023 U | 0.023 U | 0.028 U | 0.028 U | 0.032 U | 0.029 | 0.048 | -- | 0.28 | 0.78 | 4.3 | 12 | 5.6 | | |
| cis-1,3-Dichloropropene | TO-15 | -- | -- | 1.3 U | 1.4 U | 1.3 U | 1.4 U | 1.4 U | 4.6 U | 14 U | 14 U | 1.3 U | 1.3 U | 1.3 U | 1.4 U | 1.4 U | 1.1 U | 1.2 U | 1.4 U | 1.4 U | 12 U | 1.3 U | -- | 1.2 U | 2.4 U | 1.3 U | 1.3 U | | |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 6/20/2007 | | | | 6/21/2007 | | | | | |
|--|----------------------------------|-------------------------------------|------------------|------------------------------|----------------------------------|---------------------|------------------------------|-------------------------------------|---------------------|------------------------------|
| Station ID: | SP-104a | SP-109a | | | SP-104a | | | SP-109a | | |
| Location: | Post -FTO | Post-Carbon | | | Post-FTO | | | Post-Carbon | | |
| Dioxins / PCDDs | Post-FTO 6/20/07 (µg/dscm) | Post-Carbon 6/20/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-FTO 6/21/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 6/21/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) |
| 2,3,7,8-TCDD | NA | 3.40E-06 | 1 | 3.40E-06 | ND 7.78E-07 | 1 | 3.89E-07 | ND 4.14E-07 | 1 | 2.07E-07 |
| 1,2,3,7,8-PeCDD | NA | 4.85E-06 | 1 | 4.85E-06 | 1.97E-06 | 1 | 1.97E-06 | ND 6.91E-07 | 1 | 3.46E-07 |
| 1,2,3,4,7,8-HxCDD | NA | 2.22E-06 | 0.1 | 2.22E-07 | 2.48E-06 | 0.1 | 2.48E-07 | ND 6.13E-07 | 0.1 | 3.07E-08 |
| 1,2,3,6,7,8-HxCDD | NA | 3.56E-06 | 0.1 | 3.56E-07 | 3.12E-06 | 0.1 | 3.12E-07 | ND 1.12E-06 | 0.1 | 5.60E-08 |
| 1,2,3,7,8,9-HxCDD | NA | 2.99E-06 | 0.1 | 2.99E-07 | 3.28E-06 | 0.1 | 3.28E-07 | ND 1.18E-06 | 0.1 | 5.89E-08 |
| 1,2,3,4,6,7,8-HpCDD | NA | 1.02E-05 | 0.01 | 1.02E-07 | 1.67E-05 | 0.01 | 1.67E-07 | 1.83E-06 | 0.01 | 1.83E-08 |
| OCDD | NA | 1.51E-05 | 0.0003 | 4.52E-09 | 2.68E-05 | 0.0003 | 8.05E-09 | 4.37E-06 | 0.0003 | 1.31E-09 |
| Furans / PCDFs | | | | | | | | | | |
| 2,3,7,8-TCDF | NA | 1.56E-05 | 0.1 | 1.56E-06 | 2.99E-06 | 0.1 | 2.99E-07 | 1.69E-06 | 0.1 | 1.69E-07 |
| 1,2,3,7,8-PeCDF | NA | 1.44E-05 | 0.03 | 4.31E-07 | 4.03E-06 | 0.03 | 1.21E-07 | 1.19E-06 | 0.03 | 3.58E-08 |
| 2,3,4,7,8-PeCDF | NA | 1.57E-05 | 0.3 | 4.72E-06 | ND 4.67E-06 | 0.3 | 7.00E-07 | ND 8.02E-07 | 0.3 | 1.20E-07 |
| 1,2,3,4,7,8-HxCDF | NA | 7.66E-06 | 0.1 | 7.66E-07 | 5.79E-06 | 0.1 | 5.79E-07 | ND 5.91E-07 | 0.1 | 2.96E-08 |
| 1,2,3,6,7,8-HxCDF | NA | 7.88E-06 | 0.1 | 7.88E-07 | 5.66E-06 | 0.1 | 5.66E-07 | 6.26E-07 | 0.1 | 6.26E-08 |
| 2,3,4,6,7,8-HxCDF | NA | 5.86E-06 | 0.1 | 5.86E-07 | 5.02E-06 | 0.1 | 5.02E-07 | ND 5.73E-07 | 0.1 | 2.87E-08 |
| 1,2,3,7,8,9-HxCDF | NA | ND 1.26E-06 | 0.1 | 6.29E-08 | ND 1.28E-06 | 0.1 | 6.42E-08 | ND 2.48E-07 | 0.1 | 1.24E-08 |
| 1,2,3,4,6,7,8-HpCDF | NA | 1.21E-05 | 0.01 | 1.21E-07 | 1.94E-05 | 0.01 | 1.94E-07 | 1.23E-06 | 0.01 | 1.23E-08 |
| 1,2,3,4,7,8,9-HpCDF | NA | ND 1.69E-06 | 0.01 | 8.46E-09 | 3.29E-06 | 0.01 | 3.29E-08 | ND 2.92E-07 | 0.01 | 1.46E-09 |
| OCDF | NA | 2.63E-06 | 0.0003 | 7.88E-10 | 1.28E-05 | 0.0003 | 3.85E-09 | ND 1.81E-06 | 0.0003 | 2.72E-10 |
| SUM of TEQ Dioxins & Furans | | | | 1.83E-05 | | | | 6.49E-06 | | |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | 2.00E-04 | | | | n/a | | |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 8/3/2007 | | | | | | |
|--|---------------------------------|------------------|------------------------------|------------------------------------|------------------|------------------------------|--|
| Station ID: | SP-104a | | | | SP-109a | | |
| Location: | Post-FTO | | | | Post-Carbon | | |
| Dioxins / PCDDs | Post-FTO 8/3/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 8/3/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | |
| 2,3,7,8-TCDD | ND 2.49E-07 | 1 | 1.25E-07 | ND 2.67E-07 | 1 | 1.34E-07 | |
| 1,2,3,7,8-PeCDD | ND 3.24E-07 | 1 | 1.62E-07 | ND 3.26E-07 | 1 | 1.63E-07 | |
| 1,2,3,4,7,8-HxCDD | ND 3.93E-07 | 0.1 | 1.97E-08 | ND 3.89E-07 | 0.1 | 1.95E-08 | |
| 1,2,3,6,7,8-HxCDD | ND 3.80E-07 | 0.1 | 1.90E-08 | ND 3.74E-07 | 0.1 | 1.87E-08 | |
| 1,2,3,7,8,9-HxCDD | ND 3.95E-07 | 0.1 | 1.98E-08 | ND 3.89E-07 | 0.1 | 1.95E-08 | |
| 1,2,3,4,6,7,8,-HpCDD | ND 7.99E-07 | 0.01 | 3.99E-09 | 2.16E-06 | 0.01 | 2.16E-08 | |
| OCDD | ND,J,B 3.11E-06 | 0.0003 | 4.67E-10 | ND, B 2.95E-07 | 0.0003 | 4.43E-11 | |
| Furans / PCDFs | | | | | | | |
| 2,3,7,8-TCDF | ND 3.16E-07 | 0.1 | 1.58E-08 | ND 2.43E-07 | 0.1 | 1.22E-08 | |
| 1,2,3,7,8-PeCDF | ND 5.86E-07 | 0.03 | 8.79E-09 | ND 7.21E-07 | 0.03 | 1.08E-08 | |
| 2,3,4,7,8-PeCDF | ND 6.19E-07 | 0.3 | 9.28E-08 | ND 7.62E-07 | 0.3 | 1.14E-07 | |
| 1,2,3,4,7,8-HxCDF | ND, EMPC 1.44E-07 | 0.1 | 7.22E-09 | ND, EMPC 1.71E-07 | 0.1 | 8.57E-09 | |
| 1,2,3,6,7,8-HxCDF | ND 1.02E-07 | 0.1 | 5.11E-09 | ND, EMPC 1.05E-07 | 0.1 | 5.26E-09 | |
| 2,3,4,6,7,8-HxCDF | ND 1.18E-07 | 0.1 | 5.88E-09 | ND 1.34E-07 | 0.1 | 6.71E-09 | |
| 1,2,3,7,8,9-HxCDF | ND 1.47E-07 | 0.1 | 7.37E-09 | ND 1.68E-07 | 0.1 | 8.41E-09 | |
| 1,2,3,4,6,7,8-HpCDF | 3.54E-07 | 0.01 | 3.54E-09 | 4.31E-07 | 0.01 | 4.31E-09 | |
| 1,2,3,4,7,8,9-HpCDF | ND 3.89E-07 | 0.01 | 1.94E-09 | ND 2.25E-07 | 0.01 | 1.12E-09 | |
| OCDF | 2.68E-07 | 0.0003 | 8.05E-11 | ND 9.59E-07 | 0.0003 | 1.44E-10 | |
| SUM of TEQ Dioxins & Furans | | | 4.98E-07 | 5.48E-07 | | | |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | | | 2.00E-04 | |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 8/16/2007 | | | | | | | |
|--|----------------------------------|----------|------------------|------------------------------|-------------------------------------|----------|------------------|------------------------------|
| Station ID: | SP-104a | | | | SP-109a | | | |
| Location: | Post-FTO | | | | Post-Carbon | | | |
| Dioxins / PCDDs | Post-FTO 8/16/07 (µg/dscm) | | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 8/16/07 (µg/dscm) | | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) |
| 2,3,7,8-TCDD | J | 1.76E-06 | 1 | 1.76E-06 | ND | 2.84E-07 | 1 | 1.42E-07 |
| 1,2,3,7,8-PeCDD | J | 7.39E-06 | 1 | 7.39E-06 | ND | 2.10E-07 | 1 | 1.05E-07 |
| 1,2,3,4,7,8-HxCDD | J | 7.30E-06 | 0.1 | 7.30E-07 | ND | 5.81E-07 | 0.1 | 2.90E-08 |
| 1,2,3,6,7,8-HxCDD | | 1.25E-05 | 0.1 | 1.25E-06 | ND | 5.38E-07 | 0.1 | 2.69E-08 |
| 1,2,3,7,8,9-HxCDD | J | 1.22E-05 | 0.1 | 1.22E-06 | ND | 5.67E-07 | 0.1 | 2.83E-08 |
| 1,2,3,4,6,7,8,-HpCDD | | 7.39E-05 | 0.01 | 7.39E-07 | J | 8.51E-07 | 0.01 | 8.51E-09 |
| OCDD | B | 8.27E-05 | 0.0003 | 2.48E-08 | ND, J,B | 2.47E-06 | 0.0003 | 3.71E-10 |
| Furans / PCDFs | | | | | | | | |
| 2,3,7,8-TCDF | | 6.25E-06 | 0.1 | 6.25E-07 | ND | 3.56E-07 | 0.1 | 1.78E-08 |
| 1,2,3,7,8-PeCDF | J | 8.27E-06 | 0.03 | 2.48E-07 | ND | 4.89E-07 | 0.03 | 7.34E-09 |
| 2,3,4,7,8-PeCDF | J | 1.12E-05 | 0.3 | 3.36E-06 | ND | 5.00E-07 | 0.3 | 7.50E-08 |
| 1,2,3,4,7,8-HxCDF | J | 9.54E-06 | 0.1 | 9.54E-07 | ND | 1.21E-07 | 0.1 | 6.06E-09 |
| 1,2,3,6,7,8-HxCDF | J | 8.81E-06 | 0.1 | 8.81E-07 | ND | 1.12E-07 | 0.1 | 5.61E-09 |
| 2,3,4,6,7,8-HxCDF | J | 7.69E-06 | 0.1 | 7.69E-07 | ND | 1.30E-07 | 0.1 | 6.48E-09 |
| 1,2,3,7,8,9-HxCDF | J | 2.59E-06 | 0.1 | 2.59E-07 | ND | 1.54E-07 | 0.1 | 7.72E-09 |
| 1,2,3,4,6,7,8-HpCDF | | 1.89E-05 | 0.01 | 1.89E-07 | ND, EMPC | 1.89E-07 | 0.01 | 9.44E-10 |
| 1,2,3,4,7,8,9-HpCDF | J | 2.22E-06 | 0.01 | 2.22E-08 | ND | 1.82E-07 | 0.01 | 9.08E-10 |
| OCDF | J | 6.67E-06 | 0.0003 | 2.00E-09 | ND | 5.32E-07 | 0.0003 | 7.99E-11 |
| SUM of TEQ Dioxins & Furans | | | | 2.04E-05 | | | | 4.68E-07 |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | | | | | 2.00E-04 |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 9/5/2007 | | | | | |
|---|----------------------------------|------------------|------------------------------|-------------------------------------|------------------|------------------------------|
| Station ID: | SP-104a | | | SP-109a | | |
| Location: | Post-FTO | | | Post-Carbon | | |
| Dioxins / PCDDs | Post-FTO 9/05/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 9/05/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) |
| 2,3,7,8-TCDD | ND 6.95E-07 | 1 | 3.47E-07 | ND 7.42E-07 | 1 | 3.71E-07 |
| 1,2,3,7,8-PeCDD | ND 7.59E-07 | 1 | 3.79E-07 | ND 2.69E-06 | 1 | 1.35E-06 |
| 1,2,3,4,7,8-HxCDD | ND 1.65E-06 | 0.1 | 8.25E-08 | J 1.56E-06 | 0.1 | 1.56E-07 |
| 1,2,3,6,7,8-HxCDD | ND 1.53E-06 | 0.1 | 7.66E-08 | J 3.63E-06 | 0.1 | 3.63E-07 |
| 1,2,3,7,8,9-HxCDD | ND 1.61E-06 | 0.1 | 8.06E-08 | J 2.85E-06 | 0.1 | 2.85E-07 |
| 1,2,3,4,6,7,8,-HpCDD | ND 2.03E-06 | 0.01 | 1.01E-08 | 2.67E-05 | 0.01 | 2.67E-07 |
| OCDD | ND 4.84E-06 | 0.0003 | 7.26E-10 | 4.44E-05 | 0.0003 | 1.33E-08 |
| Furans / PCDFs | | | | | | |
| 2,3,7,8-TCDF | ND 1.03E-06 | 0.1 | 5.16E-08 | J 1.41E-06 | 0.1 | 1.41E-07 |
| 1,2,3,7,8-PeCDF | ND 1.29E-06 | 0.03 | 1.94E-08 | ND 1.86E-06 | 0.03 | 2.79E-08 |
| 2,3,4,7,8-PeCDF | ND 1.33E-06 | 0.3 | 1.99E-07 | J 2.46E-06 | 0.3 | 7.38E-07 |
| 1,2,3,4,7,8-HxCDF | ND 6.57E-07 | 0.1 | 3.28E-08 | J 1.62E-06 | 0.1 | 1.62E-07 |
| 1,2,3,6,7,8-HxCDF | ND 6.07E-07 | 0.1 | 3.03E-08 | ND, EMPC 1.35E-06 | 0.1 | 6.75E-08 |
| 2,3,4,6,7,8-HxCDF | ND 7.02E-07 | 0.1 | 3.51E-08 | J 1.58E-06 | 0.1 | 1.58E-07 |
| 1,2,3,7,8,9-HxCDF | ND 4.55E-07 | 0.1 | 2.28E-08 | ND 7.70E-07 | 0.1 | 3.85E-08 |
| 1,2,3,4,6,7,8-HpCDF | ND 1.65E-06 | 0.01 | 8.25E-09 | J 4.90E-06 | 0.01 | 4.90E-08 |
| 1,2,3,4,7,8,9-HpCDF | ND 6.16E-07 | 0.01 | 3.08E-09 | ND 1.39E-06 | 0.01 | 6.95E-09 |
| OCDF | ND 3.53E-06 | 0.0003 | 5.30E-10 | ND 2.94E-06 | 0.0003 | 4.41E-10 |
| SUM of TEQ Dioxins & Furans | | | 1.38E-06 | 4.19E-06 | | |
| Dioxin & Furan NESHAP Limit for Comparison ☐(not a regulatory standard) * | | | | | | 2.00E-04 |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 9/19/2007 | | | | | | |
|--|----------------------------------|------------------|------------------------------|-------------------------------------|------------------|------------------------------|----------|
| Station ID: | SP-104a | | | SP-109a | | | |
| Location: | Post-FTO | | | Post-Carbon | | | |
| Dioxins / PCDDs | Post-FTO 9/19/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 9/19/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | |
| 2,3,7,8-TCDD | ND 4.34E-07 | 1 | 2.17E-07 | ND 7.23E-07 | 1 | 3.62E-07 | |
| 1,2,3,7,8-PeCDD | ND 6.37E-07 | 1 | 3.19E-07 | ND 8.59E-07 | 1 | 4.29E-07 | |
| 1,2,3,4,7,8-HxCDD | ND 9.23E-07 | 0.1 | 4.62E-08 | J 6.97E-07 | 0.1 | 6.97E-08 | |
| 1,2,3,6,7,8-HxCDD | ND 1.08E-06 | 0.1 | 5.40E-08 | J 9.52E-07 | 0.1 | 9.52E-08 | |
| 1,2,3,7,8,9-HxCDD | ND 1.10E-06 | 0.1 | 5.50E-08 | ND 1.13E-06 | 0.1 | 5.66E-08 | |
| 1,2,3,4,6,7,8,-HpCDD | ND,EMPC 1.30E-06 | 0.01 | 6.49E-09 | J 7.33E-06 | 0.01 | 7.33E-08 | |
| OCDD | J 3.12E-06 | 0.0003 | 9.36E-10 | J 1.25E-05 | 0.0003 | 3.76E-09 | |
| Furans / PCDFs | | | | | | | |
| 2,3,7,8-TCDF | ND 1.02E-06 | 0.1 | 5.08E-08 | J 7.65E-07 | 0.1 | 7.65E-08 | |
| 1,2,3,7,8-PeCDF | ND 1.08E-06 | 0.03 | 1.62E-08 | J 6.85E-07 | 0.03 | 2.06E-08 | |
| 2,3,4,7,8-PeCDF | ND 1.14E-06 | 0.3 | 1.71E-07 | ND,EMPC 8.61E-07 | 0.3 | 1.29E-07 | |
| 1,2,3,4,7,8-HxCDF | ND 6.35E-07 | 0.1 | 3.17E-08 | ND,EMPC 5.53E-07 | 0.1 | 2.77E-08 | |
| 1,2,3,6,7,8-HxCDF | ND 5.95E-07 | 0.1 | 2.98E-08 | ND 7.35E-07 | 0.1 | 3.67E-08 | |
| 2,3,4,6,7,8-HxCDF | ND 6.59E-07 | 0.1 | 3.29E-08 | J 6.91E-07 | 0.1 | 6.91E-08 | |
| 1,2,3,7,8,9-HxCDF | ND 4.55E-07 | 0.1 | 2.27E-08 | ND 3.82E-07 | 0.1 | 1.91E-08 | |
| 1,2,3,4,6,7,8,-HpCDF | ND 1.67E-06 | 0.01 | 8.33E-09 | J 1.51E-06 | 0.01 | 1.51E-08 | |
| 1,2,3,4,7,8,9-HpCDF | ND 6.00E-07 | 0.01 | 3.00E-09 | ND 6.60E-07 | 0.01 | 3.30E-09 | |
| OCDF | ND 2.36E-06 | 0.0003 | 3.54E-10 | ND 1.88E-06 | 0.0003 | 2.81E-10 | |
| SUM of TEQ Dioxins & Furans | | | 1.07E-06 | | | 1.49E-06 | |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | | | | 2.00E-04 |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 10/4/2007 | | | | | | |
|--|----------------------------------|------------------|------------------------------|-------------------------------------|------------------|------------------------------|--|
| Station ID: | SP-104a | | | | SP-109a | | |
| Location: | Post-FTO | | | | Post-Carbon | | |
| Dioxins / PCDDs | Post-FTO 8/15/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 8/15/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | |
| 2,3,7,8-TCDD | ND 5.15E-07 | 1 | 2.57E-07 | ND 1.90E-07 | 1 | 9.51E-08 | |
| 1,2,3,7,8-PeCDD | ND 9.81E-07 | 1 | 4.91E-07 | ND 4.54E-07 | 1 | 2.27E-07 | |
| 1,2,3,4,7,8-HxCDD | ND 5.12E-07 | 0.1 | 2.56E-08 | ND 6.38E-07 | 0.1 | 3.19E-08 | |
| 1,2,3,6,7,8-HxCDD | ND 1.04E-06 | 0.1 | 5.22E-08 | ND 6.01E-07 | 0.1 | 3.00E-08 | |
| 1,2,3,7,8,9-HxCDD | ND 1.08E-06 | 0.1 | 5.42E-08 | ND 6.23E-07 | 0.1 | 3.12E-08 | |
| 1,2,3,4,6,7,8,-HpCDD | J 2.44E-06 | 0.01 | 2.44E-08 | ND 6.50E-07 | 0.01 | 3.25E-09 | |
| OCDD | J 4.49E-06 | 0.0003 | 1.35E-09 | J 1.09E-06 | 0.0003 | 3.28E-10 | |
| Furans / PCDFs | | | | | | | |
| 2,3,7,8-TCDF | J 1.02E-06 | 0.1 | 1.02E-07 | ND 2.47E-07 | 0.1 | 1.23E-08 | |
| 1,2,3,7,8-PeCDF | J 6.66E-07 | 0.03 | 2.00E-08 | ND 5.89E-07 | 0.03 | 8.84E-09 | |
| 2,3,4,7,8-PeCDF | J 8.80E-07 | 0.3 | 2.64E-07 | ND 6.20E-07 | 0.3 | 9.29E-08 | |
| 1,2,3,4,7,8-HxCDF | J 7.72E-07 | 0.1 | 7.72E-08 | ND 2.64E-07 | 0.1 | 1.32E-08 | |
| 1,2,3,6,7,8-HxCDF | J 7.24E-07 | 0.1 | 7.24E-08 | ND 2.47E-07 | 0.1 | 1.23E-08 | |
| 2,3,4,6,7,8-HxCDF | J 4.84E-07 | 0.1 | 4.84E-08 | ND 2.73E-07 | 0.1 | 1.37E-08 | |
| 1,2,3,7,8,9-HxCDF | ND 3.41E-07 | 0.1 | 1.70E-08 | ND 3.24E-07 | 0.1 | 1.62E-08 | |
| 1,2,3,4,6,7,8-HpCDF | J 1.71E-06 | 0.01 | 1.71E-08 | ND 4.07E-07 | 0.01 | 2.03E-09 | |
| 1,2,3,4,7,8,9-HpCDF | ND 4.06E-07 | 0.01 | 2.03E-09 | ND 2.54E-07 | 0.01 | 1.27E-09 | |
| OCDF | ND 2.24E-06 | 0.0003 | 3.36E-10 | ND 8.27E-07 | 0.0003 | 1.24E-10 | |
| SUM of TEQ Dioxins & Furans | | | 1.53E-06 | 5.92E-07 | | | |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | | | 2.00E-04 | |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 11/15/2007 | | | | | | |
|--|----------------------------------|------------------|------------------------------|-------------------------------------|------------------|------------------------------|--|
| Station ID: | SP-104a | | | | SP-109a | | |
| Location: | Post-FTO | | | | Post-Carbon | | |
| Dioxins / PCDDs | Post-FTO 8/15/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post-Carbon 8/15/07 (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | |
| 2,3,7,8-TCDD | ND 8.68E-07 | 1 | 4.34E-07 | ND 8.36E-07 | 1 | 4.18E-07 | |
| 1,2,3,7,8-PeCDD | ND 9.56E-07 | 1 | 4.78E-07 | ND 1.17E-06 | 1 | 5.86E-07 | |
| 1,2,3,4,7,8-HxCDD | ND 3.99E-06 | 0.1 | 2.00E-07 | ND 2.32E-06 | 0.1 | 1.16E-07 | |
| 1,2,3,6,7,8-HxCDD | ND 1.16E-06 | 0.1 | 5.78E-08 | ND 8.97E-07 | 0.1 | 4.49E-08 | |
| 1,2,3,7,8,9-HxCDD | ND 1.19E-06 | 0.1 | 5.94E-08 | ND 9.24E-07 | 0.1 | 4.62E-08 | |
| 1,2,3,4,6,7,8,-HpCDD | ND 1.42E-06 | 0.01 | 7.11E-09 | ND 1.86E-06 | 0.01 | 9.28E-09 | |
| OCDD | J 5.32E-06 | 0.0003 | 1.60E-09 | J 7.03E-06 | 0.0003 | 2.11E-09 | |
| Furans / PCDFs | | | | | | | |
| 2,3,7,8-TCDF | ND 1.33E-05 | 0.1 | 6.64E-07 | ND 1.28E-06 | 0.1 | 6.41E-08 | |
| 1,2,3,7,8-PeCDF | ND 6.92E-07 | 0.03 | 1.04E-08 | ND 9.46E-07 | 0.03 | 1.42E-08 | |
| 2,3,4,7,8-PeCDF | ND,EMPC 5.83E-07 | 0.3 | 8.74E-08 | ND 9.83E-07 | 0.3 | 1.47E-07 | |
| 1,2,3,4,7,8-HxCDF | ND 8.57E-07 | 0.1 | 4.29E-08 | ND 1.05E-06 | 0.1 | 5.26E-08 | |
| 1,2,3,6,7,8-HxCDF | ND 7.64E-07 | 0.1 | 3.82E-08 | ND 9.38E-07 | 0.1 | 4.69E-08 | |
| 2,3,4,6,7,8-HxCDF | ND 8.36E-07 | 0.1 | 4.18E-08 | ND 1.03E-06 | 0.1 | 5.13E-08 | |
| 1,2,3,7,8,9-HxCDF | ND 9.72E-07 | 0.1 | 4.86E-08 | ND 1.19E-06 | 0.1 | 5.96E-08 | |
| 1,2,3,4,6,7,8-HpCDF | ND 9.08E-07 | 0.01 | 4.54E-09 | ND 1.39E-06 | 0.01 | 6.96E-09 | |
| 1,2,3,4,7,8,9-HpCDF | ND 1.05E-06 | 0.01 | 5.27E-09 | ND 1.62E-06 | 0.01 | 8.08E-09 | |
| OCDF | ND 1.57E-06 | 0.0003 | 2.35E-10 | ND 2.08E-06 | 0.0003 | 3.12E-10 | |
| SUM of TEQ Dioxins & Furans | | | 2.18E-06 | 1.67E-06 | | | |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | | | 2.00E-04 | |

Table 3.11
PCDD and PCDF Analytical Results for Vapor Samples from SP-104a and SP-109a
Pemaco Superfund Site, Maywood, CA

| Sample Date: | 12/12/2007 | | | | | | |
|--|-----------------------|------------------|------------------------------|--------------------------|------------------|------------------------------|--|
| Station ID: | SP-104a | | | SP-109a | | | |
| Location: | Post-FTO | | | Post-Carbon | | | |
| Dioxins / PCDDs | Post FTO (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | Post Carbon (µg/dscm) | TEFs WHO 2005 | TEQ WHO 2005 (µg/dscm) | |
| 2,3,7,8-TCDD | ND 1.50E-07 | 1 | 7.50E-08 | ND 3.30E-07 | 1 | 1.65E-07 | |
| 1,2,3,7,8-PeCDD | ND 2.46E-07 | 1 | 1.23E-07 | ND 4.78E-07 | 1 | 2.39E-07 | |
| 1,2,3,4,7,8-HxCDD | ND 3.46E-07 | 0.1 | 1.73E-08 | ND 4.24E-07 | 0.1 | 2.12E-08 | |
| 1,2,3,6,7,8-HxCDD | ND 3.27E-07 | 0.1 | 1.64E-08 | ND 4.03E-07 | 0.1 | 2.01E-08 | |
| 1,2,3,7,8,9-HxCDD | ND 3.36E-07 | 0.1 | 1.68E-08 | ND 4.15E-07 | 0.1 | 2.08E-08 | |
| 1,2,3,4,6,7,8,-HpCDD | ND 3.11E-07 | 0.01 | 1.55E-09 | ND,EMPC 1.28E-06 | 0.01 | 6.38E-09 | |
| OCDD | J 3.78E-06 | 0.0003 | 1.13E-09 | ND,EMPC 3.34E-06 | 0.0003 | 5.02E-10 | |
| Furans / PCDFs | | | | | | | |
| 2,3,7,8-TCDF | J 9.46E-07 | 0.1 | 9.46E-08 | ND 3.66E-07 | 0.1 | 1.83E-08 | |
| 1,2,3,7,8-PeCDF | ND 2.32E-07 | 0.03 | 3.48E-09 | ND 4.36E-07 | 0.03 | 6.54E-09 | |
| 2,3,4,7,8-PeCDF | ND 2.41E-07 | 0.3 | 3.62E-08 | ND 4.53E-07 | 0.3 | 6.79E-08 | |
| 1,2,3,4,7,8-HxCDF | ND 2.48E-07 | 0.1 | 1.24E-08 | ND 3.01E-07 | 0.1 | 1.51E-08 | |
| 1,2,3,6,7,8-HxCDF | ND 2.20E-07 | 0.1 | 1.10E-08 | ND 2.70E-07 | 0.1 | 1.35E-08 | |
| 2,3,4,6,7,8-HxCDF | ND 2.41E-07 | 0.1 | 1.21E-08 | ND 2.95E-07 | 0.1 | 1.47E-08 | |
| 1,2,3,7,8,9-HxCDF | ND 2.81E-07 | 0.1 | 1.40E-08 | ND 3.43E-07 | 0.1 | 1.71E-08 | |
| 1,2,3,4,6,7,8,-HpCDF | ND 2.99E-07 | 0.01 | 1.50E-09 | ND 4.30E-07 | 0.01 | 2.15E-09 | |
| 1,2,3,4,7,8,9-HpCDF | ND 3.48E-07 | 0.01 | 1.74E-09 | ND 5.01E-07 | 0.01 | 2.50E-09 | |
| OCDF | ND 5.52E-07 | 0.0003 | 8.28E-11 | ND 1.22E-06 | 0.0003 | 1.83E-10 | |
| SUM of TEQ Dioxins & Furans | | | 4.38E-07 | | | 6.31E-07 | |
| Dioxin & Furan NESHAP Limit for Comparison (not a regulatory standard) * | | | | | | 2.00E-04 | |

Notes:

* Dioxin & Furan NESHAP Limit of 0.2 nanogram (ng) TEQ/ dscm (equals 2.00E-04 µg/dscm) is presented for the purpose of comparison. NESHAP is not a regulatory standard for the Pemaco Treatment Plant.

Analyses were performed by Vista Analytical Laboratory using method CARB 428.

Complete lab reports are provided in [Appendix 4](#).

ND - not detected above the stated reporting limit; For TEQ calculations half of the reporting limit was used (in blue)

EMPC - estimated maximum possible concentration; Identification of the congener was not possible due to interferences.

The congener is reported as non-detected at elevated detection limit.

CARB - California Air Resources Board

FTO - flameless thermal oxidizer

NESHAP - National Emission Standards for Hazardous Air Pollutants

PCDD - polychlorinated dibenzodioxin

J - quantitative estimate; B - result is associated with method blank contamination; NA - not applicable

µg/dscm - microgram per dry standard cubic meter

PCDF - polychlorinated dibenzofuran

TEF - toxic equivalency factor

TEQ - toxic equivalent

WHO - World Health Organization

Table 3.12
QA/QC of Analytical Results for Vapor Samples
Pemaco Superfund Site, Maywood, CA

| Sample ID | Sample Type | Date | Analyte | Concentration ¹ (ppbv) |
|------------------|-------------|------------|-------------------------|--------------------------------------|
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Cyclohexane | 1.5 |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Dimethylbutanes | 10 J |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Hexachlorobutadiene | 0.5 J |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Methylcyclopentane | 6 J |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Methylpentane | 50 J |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | n-Hexane | 12 |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Propylene | 1.1 |
| FIELDQC-070614-E | Trip Blank | 6/14/2007 | Trichloroethene | 1 |
| FIELDQC-070614-A | Trip Blank | 6/14/2007 | n-Hexane | 1 |
| FIELDQC-070614-A | Trip Blank | 6/14/2007 | Trichloroethene | 0.5 J |
| SP-109-B-070712 | Trip Blank | 7/12/2007 | Acetone | 0.8 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Acetone | 1.1 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Benzene | 0.8 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | cis -1,2-Dichloroethene | 5.1 |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Cyclohexane | 90 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Dimethylbutanes | 440 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Dimethylpentane | 99 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Methylcyclopentane | 380 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Methylhexane | 92 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Methylpentane | 3,000 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | n-Hexane | 970 |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Toluene | 110 |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Trichloroethene | 15 J |
| SP-BLANK-070731 | Trip Blank | 7/31/2007 | Vinyl chloride | 0.6 J |
| SP-BLANK-070807 | Trip Blank | 8/7/2007 | Acetone | 0.5 J |
| SP-BLANK-070807 | Trip Blank | 8/7/2007 | Tetrahydrofuran | 9.8 |
| SP-900-070814 | Trip Blank | 8/14/2007 | Acetone | 3.8 |
| SP-900-070814 | Trip Blank | 8/14/2007 | Isopropanol | 1.1 |
| SP-900-070814 | Trip Blank | 8/14/2007 | n-Hexane | 3.7 |
| SP-900-070814 | Trip Blank | 8/14/2007 | Tetrahydrofuran | 2.4 |
| SP-900-070814 | Trip Blank | 8/14/2007 | Toluene | 3 |
| SP-900-070814 | Trip Blank | 8/14/2007 | Methylbutanes | 7.8 J |
| SP-900-070814 | Trip Blank | 8/14/2007 | Methylpentane | 4.5 J |
| SP-900-20071015 | Trip Blank | 10/15/2007 | 2-Butanone | 16 |
| SP-900-20071015 | Trip Blank | 10/15/2007 | Tetrahydrofuran | 68 |
| SP-900-20071107 | Trip Blank | 11/7/2007 | 1,1-Dichloroethene | 0.9 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Benzene | 2.9 |
| SP-900-20071107 | Trip Blank | 11/7/2007 | cis -1,2-Dichloroethene | 5 |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Cyclohexane | 33 |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Dimethylbutanes | 97 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Dimethylcyclohexane | 6.6 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Dimethylpentane | 81 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | m,p-Xylene | 2.1 |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Methylcyclopentane | 200 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Methylhexane | 40 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Methylpentane | 1,220 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | n-Hexane | 380 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | o-Xylene | 0.5 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Propylene | 0.5 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Tetrahydrofuran | 0.7 J |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Toluene | 51 |
| SP-900-20071107 | Trip Blank | 11/7/2007 | Trichloroethene | 8.2 |

Table 3.12
QA/QC of Analytical Results for Vapor Samples
Pemaco Superfund Site, Maywood, CA

| Sample ID | Sample Type | Date | Analyte | Concentration ¹ (ppbv) |
|-----------------|-------------|------------|--------------------|--------------------------------------|
| SP-900-20071120 | Trip Blank | 11/20/2007 | Cyclohexane | 0.8 J |
| SP-900-20071120 | Trip Blank | 11/20/2007 | Methylpentane | 6.9 J |
| SP-900-20071120 | Trip Blank | 11/20/2007 | n-Hexane | 5.5 |
| SP-900-20071120 | Trip Blank | 11/20/2007 | Toluene | 0.8 J |
| SP-900-20071120 | Trip Blank | 11/20/2007 | Trichloroethene | 0.7 J |
| SP-900-20071204 | Trip Blank | 12/4/2007 | Acetone | 1.9 |
| SP-900-20071204 | Trip Blank | 12/4/2007 | Chloromethane | 0.5 J |
| SP-900-20071204 | Trip Blank | 12/4/2007 | Propylene | 1.2 |
| SP-900-20071220 | Trip Blank | 12/20/2007 | Cyclohexane | 1.4 |
| SP-900-20071220 | Trip Blank | 12/20/2007 | Methylcyclopentane | 3.8 J |
| SP-900-20071220 | Trip Blank | 12/20/2007 | Methylpentane | 19.7 J |
| SP-900-20071220 | Trip Blank | 12/20/2007 | n-Hexane | 16 |
| SP-900-20071220 | Trip Blank | 12/20/2007 | Toluene | 1.9 |
| SP-900-20071220 | Trip Blank | 12/20/2007 | Trichloroethene | 1 J |
| SP-900-20071227 | Trip Blank | 12/27/2007 | Cyclohexane | 0.8 J |
| SP-900-20071227 | Trip Blank | 12/27/2007 | Methylpentane | 2.6 J |
| SP-900-20071227 | Trip Blank | 12/27/2007 | n-Hexane | 5.3 |
| SP-900-20071227 | Trip Blank | 12/27/2007 | Toluene | 1.5 |

Notes:

1 - Any VOC detected in the sample (other than the common volatile laboratory contaminants), that was also detected in the trip blank, was qualified with "UJ" if the sample concentration was less than five (5) times the blank concentration. For the common laboratory contaminants (methylene chloride, acetone, 2-butanone, and cyclohexane), the results were qualified with "UJ" when the sample concentration was less than ten (10) times the blank concentration.

Analyses were performed by EPA Region 9 laboratory using EPA Method TO-15.

Complete lab reports are provided in [Appendix 4](#).

QA/QC - quality assurance/quality control; VOC - volatile organic compound

UJ - not detected at estimated reporting limit; J - quantitative estimate

ppbv - part per billion by volume

Table 3.13
Vapor Treatment System Performance
Pemaco Superfund Site, Maywood, CA

| Month | Notes | Monthly Operating Time | Monthly Percent Uptime | Average Process Flow Rate | Average Influent PID Concentration ¹ | Cumulative Vapor Volume Treated | TCE Mass Removed ² | | | | VOC Mass Removed ² | | | |
|-----------|-------|------------------------|------------------------|---------------------------|---|---------------------------------|--------------------------------|--------------|-----------------|----------------------|--------------------------------|--------------|-----------------|----------------------|
| | | | | | | | Average Influent Concentration | Monthly Mass | Cumulative Mass | Average Removal Rate | Average Influent Concentration | Monthly Mass | Cumulative Mass | Average Removal Rate |
| | | | | | | | Units: | (hours) | (%) | (scfm) | (ppmv) | (scf) | (ppmv) | (pounds) |
| May | a | 259 | 39 | 623 | 223 | 10,732,272 | 7.6 | 27 | 27 | 1.5 | 561 | 1,305 | 1,305 | 73 |
| June | b | 458 | 64 | 436 | 23 | 30,994,464 | 5.9 | 41 | 68 | 1.4 | 342 | 1,790 | 3,095 | 60 |
| July | b | 406 | 55 | 381 | 82 | 50,895,858 | 4.7 | 29 | 97 | 0.9 | 432 | 1,767 | 4,862 | 57 |
| August | c | 482 | 65 | 418 | 301 | 73,348,734 | 4.3 | 26 | 124 | 0.9 | 451 | 2,111 | 6,973 | 68 |
| September | | 719 | 100 | 650 | 582 | 101,561,346 | 2.7 | 28 | 152 | 0.9 | 412 | 2,437 | 9,410 | 81 |
| October | | 732 | 98 | 632 | 506 | 129,442,854 | 1.5 | 17 | 169 | 0.6 | 314 | 1,965 | 11,375 | 63 |
| November | d | 580 | 81 | 695 | 279 | 152,701,905 | 1.6 | 12 | 181 | 0.4 | 151 | 761 | 12,136 | 25 |
| December | | 679 | 91 | 591 | 285 | 176,696,475 | 2.1 | 16 | 197 | 0.5 | 115 | 601 | 12,736 | 19 |

| | |
|---|--------------------|
| Total Mass of TCE Removed during 2007 (pounds) | 197 |
| Total Mass of VOCs Removed during 2007 (pounds) | 12,736 |
| Average TCE Removal Rate in 2007 (lbs/day) | 0.88 |
| Average VOC Removal Rate in 2007 (lbs/day) | 56 |
| Average Vapor Flow Rate during 2007 (scfm) | 553 |
| Cumulative Volume of Vapor Treated during 2007 (scf) | 176,696,475 |
| FTO Operating Time during 2007 (hours) | 4,314 |
| FTO Percent Uptime during 2007 (%) | 74 |

Notes:

1 - Concentrations were measured with a Photoionization Detector (PID) calibrated to 100 ppmv isobutylene.

2 - Concentrations are based on the reading interpolated based on previous or subsequent readings.

Analyses for VOCs were performed by EPA Region 9 laboratory using method TO-15.

a - The vapor treatment system began operation on 5/4/07 and started 24-hour operation on 5/17/07.

b - The FTO was offline during 6/22/07 to 7/13/07 due to maintenance and condensate sump retrofit.

c - The FTO was offline during 8/21/07 to 8/31/07 due to hot spot issues on the FTO bellows.

d - The FTO was offline due to failure part repairs.

TCE - trichloroethene; VOC - volatile organic compound

lbs/day - pounds per days; ppmv = parts per million by volume; scf - standard cubic feet; scfm - standard cubic feet per minute

Table 3.14
Analytical Results for SP-104a and SP-109a Vapor Samples
Pemaco Superfund Site, Maywood, CA

| Station ID: | | | | | SP-104a | SP-109a | SP-104a | SP-109a | SP-104a | SP-109a | SP-104a | SP-109a |
|-----------------------------------|-------------------------|----------|--------------------|-------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| Description: | | | | | Post-FTO | Post-GAC | Post-FTO | Post-GAC | Post-FTO | Post-GAC | Post-FTO | Post-GAC |
| Date: | | | | | 9/5/2007 | | 9/19/2007 | | 10/4/2007 | | 11/15/2007 | |
| Analyte | Laboratory ¹ | Method | Limit ² | Units | | | | | | | | |
| Volatile Organic Compounds | | | | | | | | | | | | |
| 1,1,1-Trichloroethane | Air Toxics | TO-15SIM | 110,400 | ppbv | 0.033 U | 0.028 U | 1.7 U | 0.032 U | 0.045 U | 0.031 U | 0.13 U | 0.03 U |
| 1,1-Dichloroethane | Air Toxics | TO-15SIM | 74 | ppbv | 0.033 U | 0.028 U | 1.7 U | 0.032 U | 0.045 U | 0.031 U | 0.13 U | 0.03 U |
| 1,1-Dichloroethene | Air Toxics | TO-15SIM | 133,700 | ppbv | 0.084 | 0.014 U | 0.85 U | 0.078 | 0.023 U | 0.23 | 0.063 U | 0.29 |
| 1,2,4-Trimethylbenzene* | EPA Region 9 Lab | TO-15 | NL | ppbv | 1.4 U | 14 U | 1.4 U | 1.3 U | 3 U | 1.3 U | 1.3 U | 1.4 U |
| 1,4-Dioxane* | EPA Region 9 Lab | TO-15 | 8.4 | ppbv | 1.4 U | 14 UJ | 1.4 U | 1.3 U | 3 U | 1.3 U | 1.3 U | 1.4 U |
| 2-Butanone | Air Toxics | TO-15SIM | -- | ppbv | 4.4 | 0.45 | 74 | 0.16 U | 3.7 | 0.16 U | 19 | 0.59 |
| Acetone | Air Toxics | TO-15SIM | NL | ppbv | 14 | 4 | 160 | 0.81 U | 18 | 0.78 U | 40 | 2.6 |
| Benzene | Air Toxics | TO-15SIM | 19 | ppbv | 0.23 | 0.16 | 5.2 | 0.081 U | 0.17 | 0.078 U | 0.62 | 0.092 |
| Bromomethane | Air Toxics | TO-15SIM | -- | ppbv | 0.11 | 0.071 U | 4.2 U | 0.081 U | 0.11 U | 0.078 U | 0.32 U | 0.076 U |
| Carbon disulfide* | EPA Region 9 Lab | TO-15 | 116,100 | ppbv | 2.2 J | 14 U | 1.4 U | 1.3 U | 7.2 | 1.3 U | 1.3 U | 1.8 J |
| Chloroethane | Air Toxics | TO-15SIM | -- | ppbv | 0.083 U | 0.071 U | 4.2 U | 0.081 U | 0.36 | 0.078 U | 2.2 | 0.076 U |
| Chloroform | Air Toxics | TO-15SIM | -- | ppbv | 1 | 0.028 U | 1.7 U | 0.032 U | 1 | 0.031 U | 0.73 | 0.03 U |
| Chloromethane | Air Toxics | TO-15SIM | -- | ppbv | 0.083 U | 0.24 | 4.2 U | 0.1 | 0.47 | 0.11 | 0.73 | 0.11 |
| cis-1,2-Dichloroethene | Air Toxics | TO-15SIM | NL | ppbv | 0.033 U | 0.028 U | 1.7 U | 0.032 U | 0.045 U | 0.031 U | 0.13 U | 0.03 U |
| Dichlorodifluoromethane | Air Toxics | TO-15SIM | -- | ppbv | 0.11 | 0.035 | 1.7 U | 0.032 U | 0.13 | 0.031 U | 0.14 | 0.03 U |
| Ethylbenzene | Air Toxics | TO-15SIM | 124,800 | ppbv | 0.13 | 0.035 | 1.7 U | 0.032 U | 0.11 | 0.031 | 0.15 | 0.03 U |
| Hexachloro-1,3-butadiene* | EPA Region 9 Lab | TO-15 | NL | ppbv | 1.4 U | 14 U | 1.4 U | 1.3 U | 3 U | 1.3 U | 1.3 U | 1.4 U |
| Methylene chloride | Air Toxics | TO-15SIM | -- | ppbv | 0.72 | 0.28 U | 21 | 0.32 U | 0.45 U | 0.31 U | 1.3 U | 0.3 U |
| n-Hexane | Air Toxics | TO-15SIM | -- | ppbv | 0.18 | 0.14 U | 8.5 U | 0.16 U | 1.6 | 0.16 U | 5.3 | 0.15 U |
| Styrene | Air Toxics | TO-15SIM | -- | ppbv | 0.45 | 0.028 U | 1.7 U | 0.032 U | 0.23 | 0.14 | 0.3 | 0.03 U |
| Tert-Butyl Methyl Ether | Air Toxics | TO-15SIM | 67 | ppbv | 0.17 U | 0.14 U | 8.5 U | 0.16 U | 0.23 U | 0.16 U | 0.63 U | 0.15 U |
| Tetrachloroethene | Air Toxics | TO-15SIM | 24 | ppbv | 2.4 | 0.028 U | 1.7 U | 0.032 U | 0.045 U | 0.031 U | 0.13 U | 0.03 U |
| Toluene | Air Toxics | TO-15SIM | 143,900 | ppbv | 2.4 | 8.6 | 840 | 0.065 | 13 | 0.084 | 91 | 0.36 |
| trans-1,2-Dichloroethene | Air Toxics | TO-15SIM | NL | ppbv | 0.17 U | 0.14 U | 8.5 U | 0.16 U | 0.23 U | 0.16 U | 0.63 U | 0.15 U |
| Trichloroethene | Air Toxics | TO-15SIM | 110 | ppbv | 0.37 | 0.064 | 0.26 U | 0.0049 U | 0.046 | 0.0046 U | 0.046 | 0.0056 |
| Trichlorofluoromethane | Air Toxics | TO-15SIM | -- | ppbv | 0.23 | 0.042 | 1.7 U | 0.043 | 0.094 | 0.05 | 0.13 U | 0.036 |
| Vinyl chloride | Air Toxics | TO-15SIM | 31 | ppbv | 0.058 | 0.014 U | 0.85 U | 0.016 U | 0.023 U | 0.016 U | 0.063 U | 0.022 |
| Xylenes (total) | Air Toxics | TO-15SIM | 124,800 | ppbv | 0.58 | 0.098 | 5.1 U | 0.097 U | 0.6 | 0.32 | 0.77 | 0.091 U |
| Total VOCs | Air Toxics | TO-15SIM | 55 | lbs/day | 5.96E-03 | 3.50E-03 | 1.14E-01 | 3.10E-05 | 5.36E-03 | 1.23E-04 | 4.12E-02 | 8.29E-04 |
| Dioxins and furans | Vista | CARB 428 | 2.00E-04** | µg TEQ/dscm | 1.38E-06 | 4.19E-06 | 1.07E-06 | 1.49E-06 | 1.53E-06 | 5.92E-07 | 2.18E-06 | 1.67E-06 |

Notes:

1 - Air Toxics - Air Toxics Ltd. is located in Folsom, CA.

EPA Region 9 Lab - the EPA Region 9 Laboratory is located in Richmond, CA.

Vista - Vista Analytical Laboratory is located in El Dorado Hills, CA.

2 - Limits are based on the results of the Tier 2 Screening Risk Assessment; only analytes with limits are listed in this table. See [Appendix 5](#) for vapor discharge permit details.

* Analytes were not included in the TO-15SIM list and therefore the analytical results for samples collected from SP-104/SP-109 and analyzed by TO-15 were used.

** - Dioxin and furan NESHAP limit is presented for the purpose of comparison. NESHAP is not a regulatory standard for the Pemaco Treatment Plant.

The TO-15 results reported are from the day on or before samples were collected from SP-104a and SP-109a and analyzed by TO-15SIM.

Bolded results indicate positive detections.

FTO - flameless thermal oxidizer; GAC - granular activated carbon; NESHAP - National Emission Standards for Hazardous Air Pollutants; NL - no limit; SIM - selective ion mode; TEQ - toxic equivalent;

VOCs- volatile organic compounds

U - not detected above the stated reporting limit; J - quantitative estimate; UJ - not detected at estimated reporting limit

"--" - not available

µg TEQ/dscm - microgram of TEQ per dry standard cubic meter; lbs/day - pounds per day; ppbv - part per billion by volume

Table 3.15
Destruction and Removal Efficiency for the Vapor Treatment System
Pemaco Superfund Site, Maywood, CA

| Station ID: | | | SP-102 | SP-104a | DRE ⁵ (%) | SP-109a Post-GAC (%) | DRE ⁵ (%) | SP-102 | SP-104a | DRE ⁵ (%) | SP-109a Post-GAC (%) | DRE ⁵ (%) | SP-102 | SP-104a | DRE ⁵ (%) | SP-109a | DRE ⁵ (%) | SP-102 | SP-104a | DRE ⁵ (%) | SP-109a | DRE ⁵ (%) | | | | |
|--------------------------------|--------------------|---------|--------------|------------|-------------------------|----------------------------|-------------------------|--------------|------------|-------------------------|----------------------------|-------------------------|--------------|------------|-------------------------|--------------|-------------------------|------------|----------|-------------------------|----------|-------------------------|------------|--|--|--|
| Description: | | | Pre-FTO | Post-FTO | | | | Pre-FTO | Post-FTO | | | | Pre-FTO | Post-FTO | | Pre-FTO | | Post-FTO | | | | | | | | |
| Analysis Method ¹ : | | | TO-15 | TO-15SIM | | | | TO-15 | TO-15SIM | | | | TO-15 | TO-15SIM | | TO-15 | | TO-15SIM | | | | | | | | |
| Laboratory ² : | | | EPA Region 9 | Air Toxics | | | | EPA Region 9 | Air Toxics | | | | EPA Region 9 | Air Toxics | | EPA Region 9 | | Air Toxics | | | | | | | | |
| Date: | | | 9/5/2007 | | | | | | 9/18/2007 | | | | | | | 10/4/2007 | | | | | | | 11/15/2007 | | | |
| Analyte | Limit ³ | Units | | | | | | | | | | | | | | | | | | | | | | | | |
| Volatile Organic Compounds | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1,1-Dichloroethene | 133,700 | ppbv | 100 | 0.084 | 99.9160 | 0.014 U | 100.0000 | 270 U | 0.85 U | NA | 0.078 | NC | 270 U | 0.023 U | NA | 0.23 | NC | 240 U | 0.063 U | NA | 0.29 | NC | | | | |
| 2-Butanone | -- | ppbv | 42 | 4.4 | 89.5238 | 0.45 | 98.9286 | 270 UJ | 74 | NC | 0.16 U | NA | 270 UJ | 3.7 | NC | 0.16 U | NA | 240 UJ | 19 | NC | 0.59 | NC | | | | |
| Acetone | NL | ppbv | 33 J | 14 | 57.5758 | 4 | 87.8788 | 270 U | 160 | NC | 0.81 U | NA | 270 U | 18 | NC | 0.78 U | NA | 240 U | 40 | NC | 2.6 | NC | | | | |
| Benzene | 19 | ppbv | 190 | 0.23 | 99.8789 | 0.16 | 99.9158 | 620 | 5.2 | 99.1613 | 0.081 U | 100.0000 | 680 | 0.17 | 99.9750 | 0.078 U | 100.0000 | 240 U | 0.62 | NC | 0.092 | NC | | | | |
| Bromomethane | -- | ppbv | 14 U | 0.11 | NC | 0.071 U | NA | 270 U | 4.2 U | NA | 0.081 U | NA | 270 U | 0.11 U | NA | 0.078 U | NA | 240 UJ | 0.32 U | NA | 0.076 U | NA | | | | |
| Chloroethane | -- | ppbv | 14 U | 0.083 U | NA | 0.071 U | NA | 270 U | 4.2 U | NA | 0.081 U | NA | 270 U | 0.36 | NC | 0.078 U | NA | 240 U | 2.2 | NC | 0.076 U | NA | | | | |
| Chloroform | -- | ppbv | 39 | 1 | 97.4359 | 0.028 U | 100.0000 | 270 U | 1.7 U | NA | 0.032 U | NA | 270 U | 1 | NC | 0.031 U | NA | 240 U | 0.73 | NC | 0.03 U | NA | | | | |
| Chloromethane | -- | ppbv | 14 U | 0.083 U | NA | 0.24 | NC | 270 U | 4.2 U | NA | 0.1 | NC | 270 UJ | 0.47 | NC | 0.11 | NC | 240 U | 0.73 | NC | 0.11 | NC | | | | |
| cis- 1,2-Dichloroethene | NL | ppbv | 320 | 0.033 U | 100.0000 | 0.028 U | 100.0000 | 1,700 | 1.7 U | 100.0000 | 0.032 U | 100.0000 | 1,200 | 0.045 U | 100.0000 | 0.031 U | 100.0000 | 290 J | 0.13 U | 100.0000 | 0.03 U | 100.0000 | | | | |
| Dichlorodifluoromethane | -- | ppbv | 14 U | 0.11 | NC | 0.035 | NC | 270 U | 1.7 U | NA | 0.032 U | NA | 270 UJ | 0.13 | NC | 0.031 U | NA | 240 UJ | 0.14 | NC | 0.03 U | NA | | | | |
| Ethylbenzene | 124,800 | ppbv | 21 J | 0.13 | 99.3810 | 0.035 | 99.8333 | 270 U | 1.7 U | NA | 0.032 U | NA | 270 UJ | 0.11 | NC | 0.031 | NC | 240 U | 0.15 | NC | 0.03 U | NA | | | | |
| Methylene chloride | -- | ppbv | 14 U | 0.72 | NC | 0.28 U | NA | 270 U | 21 | NC | 0.32 U | NA | 270 U | 0.45 U | NA | 0.31 U | NA | 240 U | 1.3 U | NA | 0.3 U | NA | | | | |
| n-Hexane | -- | ppbv | 42,000 | 0.18 | 99.9996 | 0.14 U | 100.0000 | 86,000 | 8.5 U | 100.0000 | 0.16 U | 100.0000 | 130,000 J | 1.6 | 99.9988 | 0.16 U | 100.0000 | 44,000 | 5.3 | 99.9880 | 0.15 U | 100.0000 | | | | |
| Styrene | -- | ppbv | 14 U | 0.45 | NC | 0.028 U | NA | 270 U | 1.7 U | NA | 0.032 U | NA | 270 U | 0.23 | NC | 0.14 | NC | 240 U | 0.3 | NC | 0.03 U | NA | | | | |
| Tetrachloroethene | 24 | ppbv | 26 J | 2.4 | 90.7692 | 0.028 U | 100.0000 | 270 U | 1.7 U | NA | 0.032 U | NA | 270 U | 0.045 U | NA | 0.031 U | NA | 240 U | 0.13 U | NA | 0.03 U | NA | | | | |
| Toluene | 143,900 | ppbv | 11,000 | 2.4 | 99.9782 | 8.6 | 99.9218 | 20,000 | 840 | 95.8000 | 0.065 | 99.9997 | 35,000 | 13 | 99.9629 | 0.084 | 99.9998 | 4,700 | 91 | 98.0638 | 0.36 | 99.9923 | | | | |
| Trichloroethene | 110 | ppbv | 600 | 0.37 | NC | 0.064 | 99.9893 | 1,900 | 0.26 U | 100.0000 | 0.0049 U | 100.0000 | 1,200 | 0.046 | 99.9962 | 0.0046 U | 100.0000 | 1,100 | 0.046 | 99.9958 | 0.0056 | 99.9995 | | | | |
| Trichlorofluoromethane | -- | ppbv | 14 U | 0.23 | NC | 0.042 | NC | 270 U | 1.7 U | NA | 0.043 | NC | 270 U | 0.094 | NC | 0.05 | NC | 240 U | 0.13 U | NA | 0.036 | NC | | | | |
| Vinyl chloride | 31 | ppbv | 27 J | 0.058 | 99.7852 | 0.014 U | 100.0000 | 270 U | 0.85 U | NA | 0.016 U | NA | 270 U | 0.023 U | NA | 0.016 U | NA | 240 U | 0.063 U | NA | 0.022 | NC | | | | |
| Xylenes (total) | 124,800 | ppbv | 98 J | 0.58 | 99.4082 | 0.098 | 99.9000 | 540 U | 5.1 U | NA | 0.097 U | NA | 540 U | 0.6 | NC | 0.32 | NC | 490 U | 0.77 | NC | 0.091 U | NA | | | | |
| Total VOCs ⁴ | 55 | lbs/day | 45 | 5.96E-03 | 99.9868 | 3.50E-03 | 99.9922 | 29 | 1.14E-01 | 99.6098 | 3.10E-05 | 99.9999 | 88 | 5.36E-03 | 99.9939 | 1.23E-04 | 99.9999 | 31 | 4.12E-02 | 99.8668 | 8.29E-04 | 99.9973 | | | | |

Notes:

- 1 - Only analytes that were positively detected are listed in this table. Detection limits are lower for TO-15SIM than for TO-15 and therefore some DREs could not be calculated.
- 2 - Air Toxics - Air Toxics Ltd. is located in Folsom, CA.
- EPA Region 9 Lab - the EPA Region 9 Laboratory is located in Richmond, CA.
- 3 - Limits for individual analytes are based on the results of the Tier 2 Screening Risk Assessment; only analytes with limits are listed in this table. See [Appendix 5](#) for vapor discharge permit details.
- 4 - Total VOCs are based on the analytical results from samples collected from SP-104a and SP-109a for analysis by TO-15SIM only. Lighthydrocarbons and tentatively identified compounds are not included in this analysis.
- 5 - DREs are calculated only for TO-15SIM analytes.

Bolded results indicate positive detections.

DRE - destruction and removal efficiency

FTO - flameless thermal oxidizer

GAC - granular activated carbon

NA - not applicable

NC - not calculated

NL - no limit

SIM - selective ion mode

VOCs- volatile organic compounds

U - not detected above the stated reporting limit; J - quantitative estimate; UJ - not detected at estimated reporting limit

"-" - not available

lbs/day - pounds per day

ppbv - part per billion by volume

Table 4.1
Groundwater Extraction Well Field and Manifold Sampling Data
Pemaco Superfund Site, Maywood, CA

| Manifold | Well ID | Well Field Data | | | |
|--------------|-----------|---|-------------------------------|-------------------------------|-----------------------------------|
| | | Average Air Regulator Pressure (psi) | Minimum Flow Rate (gpd) | Maximum Flow Rate (gpd) | Average Flow Rate (gpd) |
| GW-1 | DAB-01 | 60 | 462.6 | 6,834 | 2,837 |
| | DAB-02 | 61 | 1401.4 | 7,284 | 5,344 |
| | DAB-03 | 61 | 0.4 | 2,815 | 1,612 |
| | DAB-04 | 64 | 0.0 | 950 | 458 |
| | DAB-05 | 61 | 549.6 | 2,668 | 1,230 |
| | DAB-06 | 59 | 0.0 | 1,577 | 498 |
| | DAB-07 | 60 | 1489.3 | 4,833 | 2,776 |
| GW-2 | DAB-08 | 65 | 0.0 | 3,480 | 1,424 |
| | DA-01 | 62 | 0.3 | 1,529 | 240 |
| | DA-02 | 63 | 0.1 | 593 | 110 |
| | DA-03 | 68 | 3.0 | 1,602 | 423 |
| | DA-04 | Closed | | | |
| | DA-05 | Closed | | | |
| | DA-06 | 59 | 0.0 | 210 | 19 |
| | DA-07 | Closed | | | |
| | DB-01 | 67 | 354.8 | 4,261 | 1,820 |
| | DB-02 | 60 | 176.2 | 686 | 293 |
| | DB-03 | 70 | 0.0 | 874 | 369 |
| | DB-04 | 60 | 0.0 | 1,718 | 562 |
| | DB-05 | 60 | 0.0 | 4,875 | 1,756 |
| | DB-06 | 60 | 14.0 | 1,042 | 430 |
| | DB-07 | 60 | 4.0 | 3,073 | 1,063 |
| GW-3 | DA-08 | 58 | 0.0 | 7 | 1 |
| | DA-09 | 69 | 0.0 | 10 | 1 |
| | DA-10 | Closed | | | |
| | DA-11 | 66 | 0.0 | 237 | 18 |
| | DA-12 | 63 | 0.0 | 521 | 79 |
| | DB-08 | 58 | 0.0 | 12,091 | 2,470 |
| | DB-09 | 65 | 0.0 | 8,875 | 1,668 |
| | DB-10 | 63 | 0.0 | 3,325 | 1,353 |
| | DB-11 | 63 | 0.0 | 2,756 | 1,220 |
| | DB-12 | 63 | 0.0 | 4,830 | 3,064 |
| | MW-24-110 | 66 | 406.5 | 10,590 | 7,572 |
| Totalizer ID | | Water Treatment System Data | | | |
| | | Minimum Flow Rate (gpd) | Maximum Flow Rate (gpd) | Average Flow Rate (gpd) | Cumulative Volume (gallons) |
| FQI-201 | | 65 | 6,852 | 1,512 | 306,150 |
| FQI-501 | | 1 | 15,329 | 4,202 | 804,501 |
| FQI-401 | | 490 | 60,632 | 33,464 | 8,079,066 |
| FQI-402 | | 1,440 | 104,153 | 48,872 | 11,460,978 |

Notes:

1 - Averages, minima, and maxima were calculated using all field data that was collected in 2007 when well was operational.

FQI-201 measures flow from non-contact water from the vapor conditioning unit.

FQI-501 measures flow from the moisture separator.

FQI-401 measures flow from all groundwater manifolds.

FQI-402 measures flow into the final holding tank prior to discharge.

gpd - gallons per day; psi - pounds per square inch

Table 4.2
Groundwater Sampling Ports
Pemaco Superfund Site, Maywood, CA

| Station ID | Monitoring Location | Analyte or Parameter | Laboratory ¹ | Purpose of Data Collection; Data Use |
|------------|---|---|-------------------------|---|
| SP-201 | From Wells, post-GW Booster Tank (T-401) | VOCs by EPA 8260B | Calscience | Extraction/Treatment system optimization; estimate of mass removal rates |
| | | 1,4-Dioxane by EPA 8270C | | |
| SP-204 | Post-condensate sump (T-201) and post-Holding Tank (T-402) | VOCs by EPA 8260B | Calscience | To determine mass removal |
| | | 1,4-Dioxane by EPA 8270C | | |
| SP-206 | Post-carbon absorber (T-403) | VOCs by EPA 8260B | Calscience | To determine carbon break-through and mass removal |
| | | 1,4-Dioxane by EPA 8270C | | |
| SP-208 | Post-carbon absorber (T-404) | VOCs by EPA 8260B | Calscience | To determine carbon break-through and mass removal |
| | | 1,4-Dioxane by EPA 8270C | | |
| SP-209 | Prior to discharge to the sanitary sewer | COD, TSS and Lead (24-hour composite) | Calscience | To evaluate compliance with the Self-Monitoring Requirements Permit No. 16961 issued by the SDLAC |
| | | pH, Dissolved Sulfide, Oil & Grease, VOCs and SVOCs | Calscience | |
| SP-210 | From Moisture Separator (SP-117); Pre-Bag Filter (F-105/F-106) | VOCs by EPA 8260B | Calscience | Treatment system monitoring |
| SP-212 | From FTO vapor conditioning (H-101); pre-Holding Tank (SP-113) or bypass to discharge | VOCs by EPA 8260B | Calscience | To determine mass removal |
| SP-213 | From Exposition Wells South Trench DAB-1 to DAB-7 (7 wells) | VOCs by EPA 8260B | Calscience | Extraction system optimization; estimate of mass removal rates |
| SP-214 | From Exposition Wells West Trench DAB-8, DA/DB-1 to DA/DB-7 (15 wells) | VOCs by EPA 8260B | Calscience | Extraction system optimization; estimate of mass removal rates |
| SP-215 | From Exposition Wells East Trench DA/DB-8 to DA/DB-12 & MW24-140 (11 wells) | VOCs by EPA 8260B | Calscience | Extraction system optimization; estimate of mass removal rates |

Notes:

1 - Calscience - Calscience Environmental Laboratory, Inc. is located in Garden Grove, CA.

SDLAC - Sanitation District of Los Angeles County

SVOCs - semi-volatile organic compounds

TDS - total dissolved solids

VOCs - volatile organic compounds

Table 4.3
VOC Analytical Results for the Groundwater Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-DCA | 1,1-DCE | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Bromodichloromethane | Bromoform | Carbon tetrachloride | Chloroform | cis-1,2-DCE | Dibromochloromethane | Dibromomethane | n-Hexane | Tetrachloroethene | Toluene | trans-1,2-DCE | Trichloroethene | Vinyl chloride |
|------------|---------------|------------|-------|---------|---------|-------------|------------|---------|---------|----------------------|-----------|----------------------|------------|-------------|----------------------|----------------|----------|-------------------|---------|---------------|-----------------|----------------|
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | |
| SP-213 | GW-1 Manifold | 5/3/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 10 | 3.6 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 28 | 0.5 U |
| | | 5/17/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 20 | 4 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 32 | 0.5 U |
| | | 6/1/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 17 | 4.8 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 40 | 0.5 U |
| | | 6/15/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 19 | 4.8 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 41 | 0.5 U |
| | | 7/11/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 12 | 3.9 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 37 | 0.5 U |
| | | 7/26/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 13 | 5.7 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 46 | 0.5 U |
| | | 8/8/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 8.5 | 5.8 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 38 | 0.5 U |
| | | 8/17/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 9.8 | 3.9 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 27 | 0.5 U |
| | | 8/21/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 4.1 | 4.7 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 35 | 0.5 U |
| | | 8/28/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 6.3 | 3.7 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 33 | 0.5 U |
| | | 9/4/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 7.9 | 5.7 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 38 | 0.5 U |
| | | 9/12/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 6.7 | 4.9 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 41 | 0.5 U |
| | | 9/19/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 6 | 4.6 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 40 | 0.5 U |
| | | 9/26/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 2.5 | 5 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 34 | 0.5 U |
| | | 10/5/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 5.4 | 5.3 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 48 | 0.5 U |
| | | 10/9/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 11 | 6.3 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 45 | 0.5 U |
| | | 10/18/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 17 | 5.7 | 1 U | 1 U | 1.3 | 1 U | 1 U | 1 U | 47 | 0.5 U |
| | | 10/24/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 5.2 | 4.9 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 35 | 0.5 U |
| | | 11/2/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 4.6 | 3.8 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 31 | 0.5 U |
| | | 11/8/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 11 | 4.9 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 38 | 0.5 U |
| | | 11/16/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 12 | 7 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 51 | 0.5 U |
| | | 11/19/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 8.4 | 4.9 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 33 | 0.5 U |
| | | 11/30/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 5.6 | 5.5 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 34 | 0.5 U |
| | | 12/5/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 9.9 | 5.2 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 46 | 0.5 U |
| | | 12/12/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 8.8 | 5.5 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 37 | 0.5 U |
| | | 12/19/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 4 | 4.3 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 32 | 0.5 U |
| | | 12/28/2007 | µg/L | 1 U | 1 U | -- | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 7.1 | 3.5 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 37 | 0.5 U |

Table 4.3
VOC Analytical Results for the Groundwater Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-DCA | 1,1-DCE | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Bromodichloromethane | Bromoform | Carbon tetrachloride | Chloroform | cis-1,2-DCE | Dibromochloromethane | Dibromomethane | n-Hexane | Tetrachloroethene | Toluene | trans-1,2-DCE | Trichloroethene | Vinyl chloride |
|------------|------------------|------------|-------|---------|---------|-------------|------------|---------|---------|----------------------|-----------|----------------------|------------|-------------|----------------------|----------------|----------|-------------------|---------|---------------|-----------------|----------------|
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | |
| SP-214 | GW-2 Manifold | 5/3/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 15 | 97 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 1,100 | 5 U |
| | | 5/17/2007 | µg/L | 6.1 | 2.1 | 50 U | 10 U | 50 U | 6.3 | 1 U | 1 U | 0.5 U | 16 | 130 | 1 U | 1 U | -- | 2.2 | 3.4 | 4.9 | 1,100 | 1.1 |
| | | 6/1/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 16 | 56 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 620 | 5 U |
| | | 6/15/2007 | µg/L | 7 | 2 U | 100 U | 20 U | 100 U | 4.4 | 2 U | 2 U | 1 U | 8.8 | 45 | 2 U | 2 U | -- | 2 U | 2 U | 2.1 | 350 | 1 U |
| | | 7/11/2007 | µg/L | 3.4 | 2 U | 100 U | 20 U | 100 U | 2.3 | 2 U | 2 U | 1 U | 17 | 43 | 2 U | 2 U | -- | 2 U | 2 U | 2 U | 480 | 1 U |
| | | 7/26/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 3.2 | 5 U | 5 U | 2.5 U | 24 | 56 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 550 | 2.5 U |
| | | 8/8/2007 | µg/L | 5.6 | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 15 | 43 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 420 | 2.5 U |
| | | 8/17/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 19 | 45 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 420 | 2.5 U |
| | | 8/21/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.7 | 5 U | 5 U | 2.5 U | 13 | 50 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 520 | 2.5 U |
| | | 8/28/2007 | µg/L | 3.7 | 2 U | 100 U | 20 U | 100 U | 2.1 | 2 U | 2 U | 1 U | 18 | 50 | 2 U | 2 U | 2 U | 2 U | 2 U | 2.3 | 380 | 1 U |
| | | 9/4/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 15 | 42 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 460 | 2.5 U |
| | | 9/12/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 10 | 29 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 260 | 2.5 U |
| | | 9/19/2007 | µg/L | 5 U | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 15 | 39 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 430 | 2.5 U |
| | | 9/26/2007 | µg/L | 5.3 | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 11 | 39 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 320 | 2.5 U |
| | | 10/5/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 12 | 47 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 500 | 2.5 U |
| | | 10/9/2007 | µg/L | 4 | 2 U | 100 U | 20 U | 100 U | 1.9 | 2 U | 2 U | 1 U | 12 | 46 | 2 U | 2 U | 2 U | 2 U | 2 U | 2.4 | 330 | 1 U |
| | | 10/18/2007 | µg/L | 5 U | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 12 | 36 | 5 U | 5 U | 7.1 | 5 U | 5 U | 5 U | 550 | 2.5 U |
| | | 10/24/2007 | µg/L | 5.4 | 2 U | 100 U | 20 U | 100 U | 1.4 | 2 U | 2 U | 1 U | 17 | 34 | 2 U | 2 U | 2 U | 2 U | 2 U | 2.1 | 240 | 1 U |
| | | 11/2/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 63 | 10 U | 10 U | 10 U | 10 U | 10 U | 10 U | 1,000 | 6.2 |
| | | 11/8/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 72 | 10 U | 10 U | 10 U | 10 U | 10 U | 10 U | 650 | 5 |
| | | 11/16/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 12 | 290 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 520 | 5.4 |
| | | 11/19/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 7.1 | 76 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 700 | 3.9 |
| | | 11/30/2007 | µg/L | 5.8 | 5 U | -- | 50 U | 250 U | 2.7 | 5 U | 5 U | 2.5 U | 8.4 | 110 | 5 U | 5 U | -- | 5 U | 5 U | 6.6 | 530 | 5.2 |
| | | 12/5/2007 | µg/L | 4.7 | 2 | -- | 27 | 250 U | 2.5 | 1 U | 1 U | 0.5 U | 7.5 | 190 | 1 U | 1 U | -- | 1.3 | 1 U | 3.5 | 610 | 7.4 |
| | | 12/12/2007 | µg/L | 5 U | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 7.9 | 120 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 430 | 4.8 |
| | | 12/19/2007 | µg/L | 5 U | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 5 U | 120 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 380 | 5.1 |
| | | 12/28/2007 | µg/L | 5 U | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 5 U | 89 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 430 | 3.2 |

Table 4.3
VOC Analytical Results for the Groundwater Extraction Manifold
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-DCA | 1,1-DCE | 1,4-Dioxane | 2-Butanone | Acetone | Benzene | Bromodichloromethane | Bromoform | Carbon tetrachloride | Chloroform | cis-1,2-DCE | Dibromochloromethane | Dibromomethane | n-Hexane | Tetrachloroethene | Toluene | trans-1,2-DCE | Trichloroethene | Vinyl chloride |
|------------|---------------|------------|-------|---------|---------|-------------|------------|---------|---------|----------------------|-----------|----------------------|------------|-------------|----------------------|----------------|----------|-------------------|---------|---------------|-----------------|----------------|
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | |
| SP-215 | GW-3 Manifold | 5/3/2007 | µg/L | 2.8 | 2.5 | 50 U | 10 U | 50 U | 0.6 | 1 U | 1 U | 0.5 U | 2.9 | 48 | 1 U | 1 U | -- | 1.8 | 1 U | 2 | 1,200 | 1.8 |
| | | 5/17/2007 | µg/L | 4.4 | 1.7 | 50 U | 10 U | 50 U | 0.86 | 1 U | 1 U | 0.5 U | 1.2 | 24 | 1 U | 1 U | -- | 1 U | 1 U | 1.3 | 190 | 0.52 |
| | | 6/1/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 34 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 1,200 | 5 U |
| | | 6/15/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 49 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 1,800 | 5 U |
| | | 7/11/2007 | µg/L | 20 U | 20 U | 1,000 U | 200 U | 1,000 U | 10 U | 20 U | 20 U | 10 U | 20 U | 28 | 20 U | 20 U | -- | 20 U | 20 U | 20 U | 910 | 10 U |
| | | 7/26/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 34 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 1,200 | 5 U |
| | | 8/8/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 170 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 1,700 | 7.1 |
| | | 8/17/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 120 | 10 U | 10 U | 10 U | 10 U | 10 U | 10 U | 1,300 | 5 U |
| | | 8/21/2007 | µg/L | 20 U | 20 U | 1,000 U | 200 U | 1,000 U | 10 U | 20 U | 20 U | 10 U | 20 U | 230 | 20 U | 20 U | -- | 20 U | 20 U | 20 U | 2,200 | 12 |
| | | 8/28/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 240 | 10 U | 10 U | 10 U | 10 U | 10 U | 10 U | 1,500 | 10 |
| | | 9/4/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 390 | 10 U | 10 U | 10 U | 10 U | 10 U | 10 U | 990 | 7.9 |
| | | 9/12/2007 | µg/L | 10 U | 10 U | 500 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 74 | 10 U | 10 U | 10 U | 10 U | 100 | 10 U | 270 | 5 U |
| | | 9/19/2007 | µg/L | 10 U | 10 U | -- | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 300 | 10 U | 10 U | 10 U | 10 U | 12 | 10 U | 1,400 | 9 |
| | | 9/26/2007 | µg/L | 10 U | 10 U | -- | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 260 | 10 U | 10 U | 10 U | 10 U | 10 U | 10 U | 960 | 7.9 |
| | | 10/5/2007 | µg/L | 5 U | 5 U | 250 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 5 U | 390 | 5 U | 5 U | 5 U | 5 U | 5 U | 5 U | 180 | 6.4 |
| | | 10/9/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1.1 | 3.9 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 47 | 0.5 U |
| | | 10/18/2007 | µg/L | 2 U | 2 U | -- | 20 U | 100 U | 1 U | 2 U | 2 U | 1 U | 2 U | 210 | 2 U | 2 U | 2.8 | 2 U | 2 U | 2 U | 160 | 4.1 |
| | | 10/24/2007 | µg/L | 1 | 1.5 | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 210 | 1 U | 1 U | 1 U | 1 U | 1.6 | 1.7 | 130 | 4 |
| | | 11/2/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 3.7 | 1 U | 1 U | 1 U | 1 U | 7.5 | 1 U | 16 | 0.5 U |
| | | 11/8/2007 | µg/L | 1 U | 1 U | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 9 | 1 U | 1 U | 1 U | 1 U | 5.6 | 1 U | 50 | 1.1 |
| | | 11/16/2007 | µg/L | 1 U | 1.8 | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1.3 | 150 | 1 U | 1 U | 1.1 | 1 U | 1 U | 1.5 | 120 | 2.5 |
| | | 11/19/2007 | µg/L | 1 U | 2.2 | 50 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 130 | 1 U | 1 U | 1 U | 1 U | 1 U | 1.7 | 260 | 4.7 |
| | | 11/30/2007 | µg/L | 10 U | 10 U | -- | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 81 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 1,500 | 8.2 |
| | | 12/5/2007 | µg/L | 1 U | 1.3 | -- | 10 U | 94 | 0.5 | 1 U | 1 U | 0.5 U | 1 U | 35 | 1 U | 1 U | -- | 1 U | 7.9 | 1.3 | 1,300 | 2.4 |
| | | 12/12/2007 | µg/L | 10 U | 10 U | -- | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 46 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 530 | 5 U |
| | | 12/19/2007 | µg/L | 10 U | 10 U | -- | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 21 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 640 | 5 U |
| | | 12/28/2007 | µg/L | 5 U | 5 U | -- | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 5 U | 27 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 400 | 2.5 U |

Notes:

Analyses were performed by Calscience Environmental Laboratories, Inc. using EPA Method 8260B.

1,1-DCA - 1,1-dichloroethane; 1,1-DCE - 1,1-dichloroethene; cis-1,2-DCE - cis-1,2-dichloroethene; trans-1,2-DCE - trans-1,2-Dichloroethene

U - not detected above the stated reporting limit; UJ - not detected at estimated reporting limit; J - quantitative estimate

--" - not available

µg/L - microgram per liter

Table 4.4
VOC Analytical Results for Groundwater Treatment System Samples
Pemaco Superfund Site, Maywood, CA

| Analyte: | | | | 1,1-DCA | 1,1-DCE | 2-Butanone | Acetone | Benzene | Bromodichloromethane | Bromoform | Carbon tetrachloride | Chloroform | cis-1,2-DCE | Dibromochloromethane | Dibromomethane | n-Hexane | Tetrachloroethene | Toluene | trans-1,2-DCE | Trichloroethene | Vinyl chloride | 1,4-Dioxane | |
|------------|-------------------------|-----------|-------|-----------|---------|------------|---------|---------|----------------------|-----------|----------------------|------------|-------------|----------------------|----------------|----------|-------------------|---------|---------------|-----------------|----------------|-------------|--|
| Method: | | | | EPA 8260B | | | | | | | | | | | | | | | | | | EPA 8270 | |
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | | |
| SP-201 | Influent | 5/3/2007 | µg/L | 2 | 1.5 | 10 U | 50 U | 1.4 | 1 U | 1 U | 0.5 U | 9.3 | 44 | 1 U | 1 U | -- | 1.2 | 1 U | 2.1 | 670 | 0.88 | 5.5 | |
| SP-204 | Pre-GAC | 5/3/2007 | µg/L | 2 | 1.4 | 10 U | 50 U | 1.2 | 1 U | 1 U | 0.5 U | 8.4 | 42 | 1 U | 1 U | -- | 1.3 | 1 U | 1.8 | 710 | 0.94 | 50 U | |
| SP-206 | Post-Primary GAC | 5/3/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 2.2 | |
| SP-208 | Post-Secondary GAC | 5/3/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 2 U | |
| SP-204 | Pre-GAC | 5/10/2007 | µg/L | 10 U | 10 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 10 U | 51 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 970 | 5 U | 8.8 | |
| SP-201 | Influent | 5/17/2007 | µg/L | 3.3 | 1.2 | 10 U | 50 U | 2.4 | 1 U | 1 U | 0.5 U | 17 | 59 | 1 U | 1 U | -- | 1.1 | 1.4 | 2.3 | 550 | 0.63 | 10 | |
| SP-204 | Pre-GAC | 5/18/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 1 U | 0.5 U | 9.4 | 42 | 5 U | 5 U | -- | 5 U | 15 | 5 U | 700 | 2.5 U | 250 U | |
| SP-206 | Post-Primary GAC | 5/18/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 5 U | 2.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 11 | |
| SP-208 | Post-Secondary GAC | 5/17/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 4.1 | |
| SP-210 | Post-Moisture Separator | 5/18/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.59 | 1 U | 1 U | 0.5 U | 1 U | 14 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 110 | 0.5 U | 50 U | |
| SP-212 | VCP Drainage | 5/18/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-204 | Pre-GAC | 5/24/2007 | µg/L | 10 U | 10 U | 100 U | 500 U | 5 U | 10 U | 10 U | 5 U | 14 | 32 | 10 U | 10 U | -- | 10 U | 10 U | 10 U | 560 | 5 U | 500 U | |
| SP-212 | VCP Drainage | 5/24/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-201 | Influent | 6/1/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 8.8 | 27 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 610 | 2.5 U | 100 | |
| SP-204 | Pre-GAC | 6/1/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 7.4 | 24 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 490 | 2.5 U | 250 U | |
| SP-206 | Post-Primary GAC | 6/1/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 2 | 2 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 5 | 0.5 U | 72 | |
| SP-208 | Post-Secondary GAC | 6/1/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 20 | |
| SP-210 | Post-Moisture Separator | 6/1/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 28 | 1 U | 1 U | -- | 1 | 1 U | 1.3 | 150 | 0.5 U | 50 U | |
| SP-212 | VCP Drainage | 6/1/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-204 | Pre-GAC | 6/7/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 5.9 | 22 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 320 | 2.5 U | 250 U | |
| SP-210 | Post-Moisture Separator | 6/7/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 41 | 1 U | 1 U | -- | 1 U | 5 | 1.3 | 140 | 0.5 U | 50 U | |
| SP-212 | VCP Drainage | 6/7/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-201 | Influent | 6/15/2007 | µg/L | 1.6 | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 6.1 | 18 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 260 | 0.5 U | 98 | |
| SP-204 | Pre-GAC | 6/15/2007 | µg/L | 1.3 | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 5 | 16 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 190 | 0.5 U | 62 | |
| SP-206 | Post-Primary GAC | 6/15/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 3 | 4.5 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 6.7 | 0.5 U | 72 | |
| SP-208 | Post-Secondary GAC | 6/15/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 59 | |
| SP-210 | Post-Moisture Separator | 6/15/2007 | µg/L | 1 U | 1 U | 10 U | 82 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 31 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 79 | 0.5 U | 50 U | |
| SP-212 | VCP Drainage | 6/15/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-204 | Pre-GAC | 6/20/2007 | µg/L | 1.1 | 1.1 | 10 U | 66 | 0.5 U | 1 U | 1 U | 0.5 U | 3.7 | 16 | 1 U | 1 U | -- | 6.2 | 1 U | 1 U | 150 | 0.5 U | 93 | |
| SP-210 | Post-Moisture Separator | 6/20/2007 | µg/L | 1 U | 1 U | 10 U | 160 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 28 | 1 U | 1 U | -- | 4.1 | 22 | 1 U | 66 | 0.5 U | 66 | |
| SP-212 | VCP Drainage | 6/20/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 3 | 1 U | 1 U | 4.3 | 0.5 U | 50 U | |
| SP-204 | Pre-GAC | 7/6/2007 | µg/L | 2 U | 2 U | 20 U | 100 U | 1 U | 2 U | 2 U | 1 U | 9.2 | 13 | 2 U | 2 U | -- | 2 U | 2 U | 2 U | 170 | 1 U | 100 U | |
| SP-210 | Post-Moisture Separator | 7/6/2007 | µg/L | 2 U | 2 U | 20 U | 220 | 1 U | 2 U | 2 U | 1 U | 2 U | 4.4 | 2 U | 2 U | -- | 2 U | 3.8 | 2 U | 15 | 1 U | 100 U | |
| SP-212 | VCP Drainage | 7/6/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-201 | Influent | 7/11/2007 | µg/L | 2 U | 2 U | 20 U | 100 | 1 U | 2 U | 2 U | 1 U | 4.7 | 17 | 2 U | 2 U | -- | 2 U | 2 U | 2 U | 230 | 1 U | 82 | |
| SP-204 | Pre-GAC | 7/11/2007 | µg/L | 1 | 1 U | 10 U | 130 | 0.56 | 1 U | 1 U | 0.5 U | 4.6 | 17 | 1 U | 1 U | -- | 1 U | 2.4 | 1 U | 240 | 0.5 U | 83 | |
| SP-206 | Post-Secondary GAC | 7/11/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 14 | |
| SP-208 | Post-Primary GAC | 7/11/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 48 | |
| SP-210 | Post-Moisture Separator | 7/11/2007 | µg/L | 1 U | 1 U | 10 U | 390 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 17 | 1 U | 1 U | -- | 1 U | 36 | 1 U | 40 | 0.5 U | 130 | |
| SP-212 | VCP Drainage | 7/11/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U | |
| SP-204 | Pre-GAC | 7/18/2007 | µg/L | | | | | | | | | | | | | | | | | | | | |

Table 4.4
VOC Analytical Results for Groundwater Treatment System Samples
Pemaco Superfund Site, Maywood, CA

| Analyte: Method: | | | | 1,1-DCA | 1,1-DCE | 2-Butanone | Acetone | Benzene | Bromodichloromethane | Bromoform | Carbon tetrachloride | Chloroform | cis-1,2-DCE | Dibromochloromethane | Dibromomethane | n-Hexane | Tetrachloroethene | Toluene | trans-1,2-DCE | Trichloroethene | Vinyl chloride | 1,4-Dioxane |
|---------------------|------------------------|------------|-------|----------|---------|------------|---------|---------|----------------------|-----------|----------------------|------------|-------------|----------------------|----------------|----------|-------------------|---------|---------------|-----------------|----------------|-------------|
| | | | | | | | | | | | | | | | | | | | | | | |
| EPA 8260B | | | | EPA 8270 | | | | | | | | | | | | | | | | | | |
| Station ID | Description | Date | Units | | | | | | | | | | | | | | | | | | | |
| SP-201 | Influent | 10/24/2007 | µg/L | 1.1 | 1 U | 10 U | 96 | 0.51 | 36 | 45 | 0.5 U | 20 | 76 | 65 | 1 U | 1 U | 1 U | 3.2 | 1.5 | 120 | 1.1 | 49 |
| SP-204 | Pre-GAC | 10/24/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.75 | 1 U | 11 | 0.5 U | 3.8 | 70 | 1.9 | 1 U | 1 U | 1 U | 18 | 1 U | 92 | 0.81 | 63 |
| SP-206 | Post-Primary GAC | 10/24/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 5.1 | 28 | 1 U | 1.4 | 1 U | 1 U | 1 U | 1 U | 2.4 | 0.83 | 42 |
| SP-208 | Post-Secondary GAC | 10/24/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 14 |
| SP-210 | Post-Moisture Sperator | 10/24/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 1.2 | 1 U | 1 U | 0.5 U | 1 U | 10 | 1 U | 1 U | 1 U | 1 U | 29 | 1 U | 11 | 0.5 U | 81 |
| SP-212 | VCP Drainage | 10/24/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U |
| SP-201 | Influent | 11/2/2007 | µg/L | 1 U | 1 | 10 U | 53 | 0.5 U | 6.7 | 30 | 0.5 U | 6.5 | 17 | 24 | 1 U | 1 U | 1 U | 8.1 | 1 U | 230 | 1.4 | 81 |
| SP-204 | Pre-GAC | 11/2/2007 | µg/L | 2 U | 2 U | 20 U | 100 U | 1 U | 2 U | 71 | 1 U | 5 | 19 | 14 | 2 U | 2 U | 2 U | 8.1 | 2 U | 250 | 1.4 | 100 U |
| SP-208 | Post-Primary GAC | 11/2/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.6 | 32 |
| SP-210 | Post-Moisture Sperator | 11/2/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 3.8 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 8.9 | 0.5 U | 50 U |
| SP-212 | VCP Drainage | 11/2/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U |
| SP-201 | Influent | 11/8/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.51 | 1 U | 2 | 0.5 U | 3.3 | 31 | 1.6 | 1 U | 1 U | 1 U | 4.9 | 1 U | 150 | 3.1 | 71 |
| SP-204 | Pre-GAC | 11/8/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.53 | 1 U | 4.4 | 0.5 U | 3.7 | 25 | 1.7 | 1 U | 1 U | 1 U | 5.7 | 1 U | 130 | 1.7 | 82 |
| SP-206 | Post-Secondary GAC | 11/8/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 6.5 |
| SP-208 | Post-Primary GAC | 11/8/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.71 | 31 |
| SP-210 | Post-Moisture Sperator | 11/8/2007 | µg/L | 1 U | 1 U | 35 | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1.4 | 0.5 U | 200 |
| SP-212 | VCP Drainage | 11/8/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U |
| SP-201 | Influent | 11/16/2007 | µg/L | 1.2 | 1 U | 33 | 50 U | 0.68 | 1 U | 2.7 | 0.5 U | 5.7 | 54 | 1 U | 2.9 | 1 | 1 U | 2.3 | 1.3 | 290 | 2.2 | 10 |
| SP-204 | Pre-GAC | 11/16/2007 | µg/L | 1 U | 1 U | 10 U | 56 | 0.55 | 1 U | 2.7 | 0.5 U | 4.6 | 40 | 1 U | 2.2 | 1 | 1 U | 5.6 | 1 U | 230 | 1.6 | 9.8 |
| SP-206 | Post-Secondary GAC | 11/16/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 26 |
| SP-208 | Post-Primary GAC | 11/16/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.79 | 36 |
| SP-210 | Post-Moisture Sperator | 11/16/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 3.1 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 7.7 | 0.5 U | 50 U |
| SP-201 | Influent | 11/19/2007 | µg/L | 2 U | 2 U | 20 U | 100 U | 1 U | 2 U | 2 U | 1 U | 6.8 | 55 | 2 U | 2 U | 2 U | 2 U | 2 U | 2 U | 290 | 2.2 | 9.6 |
| SP-204 | Pre-GAC | 11/19/2007 | µg/L | 2 U | 2 U | 20 U | 100 U | 1 U | 4.8 | 12 | 1 U | 10 | 54 | 9.4 | 2 U | 2 U | 2 U | 2 U | 2 U | 250 | 1.5 | 10 |
| SP-206 | Post-Secondary GAC | 11/19/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 28 |
| SP-208 | Post-Primary GAC | 11/19/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.78 | 26 |
| SP-210 | Post-Moisture Sperator | 11/19/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 2.4 | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 7.8 | 0.5 U | 50 U |
| SP-212 | VCP Drainage | 11/19/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 1 U | 0.5 U | 50 U |
| SP-201 | Influent | 11/30/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 40 | 2.5 U | 5 U | 35 | 5.2 | 5 U | -- | 5 U | 6.4 | 5 U | 470 | 2.5 U | 73 |
| SP-204 | Pre-GAC | 11/30/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 34 | 2.5 U | 5 U | 36 | 5.8 | 5 U | -- | 5 U | 6 | 5 U | 440 | 2.5 U | 77 |
| SP-208 | Post-Secondary GAC | 11/30/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 2 U |
| SP-210 | Post-Moisture Sperator | 11/30/2007 | µg/L | 1 U | 1 U | 15 | 300 | 0.65 | 69 | 6.9 | 0.5 U | 120 | 3.7 | 51 | 1 U | -- | 1 U | 42 | 1 U | 8.6 | 0.5 U | -- |
| SP-212 | VCP Drainage | 11/30/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | -- |
| SP-201 | Influent | 12/5/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 17 | 72 | 2.5 U | 7.3 | 49 | 59 | 5 U | -- | 5 U | 5 U | 5 U | 570 | 2.5 U | 9.5 |
| SP-204 | Pre-GAC | 12/5/2007 | µg/L | 1.1 | 1 U | 10 U | 110 | 0.55 | 17 | 140 | 0.5 U | 7 | 45 | 63 | 1 U | -- | 1 U | 2 | 1.2 | 490 | 1.8 | 10 |
| SP-206 | Post-Primary GAC | 12/5/2007 | µg/L | 1 U | 1 U | 10 U | 130 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 61 |
| SP-208 | Post-Secondary GAC | 12/5/2007 | µg/L | 1 U | 1 U | 10 U | 53 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 5.3 |
| SP-210 | Post-Moisture Sperator | 12/5/2007 | µg/L | 2 U | 2 U | 20 U | 200 | 1 U | 56 | 5.8 | 1 U | 83 | 3.5 | 36 | 2 U | -- | 2 U | 32 | 2 U | 9.8 | 1 U | -- |
| SP-212 | VCP Drainage | 12/5/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | -- |
| SP-201 | Influent | 12/12/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 5 U | 2.5 U | 5 U | 40 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 320 | 2.5 U | 38 |
| SP-204 | Pre-GAC | 12/12/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 11 | 2.5 U | 5 U | 34 | 5 U | 5 U | -- | 5 U | 5 U | 5 U | 260 | 2.5 U | 41 |
| SP-206 | Post-Primary GAC | 12/12/2007 | µg/L | 1 U | 1 U | 10 U | 160 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 51 |
| SP-208 | Post-Secondary GAC | 12/12/2007 | µg/L | 1 U | 1 U | 10 U | 97 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 21 |
| SP-210 | Post-Moisture Sperator | 12/12/2007 | µg/L | 2 U | 2 U | 20 U | 360 | 1 U | 69 | 4.8 | 1 U | 130 | 4.3 | 45 | 2 U | -- | 2 U | 27 | 2 U | 12 | 1 U | -- |
| SP-212 | VCP Drainage | 12/12/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | -- |
| SP-201 | Influent | 12/19/2007 | µg/L | 5 U | 5 U | 50 U | 360 | 2.5 U | 20 | 75 | 2.5 U | 5.3 | 25 | 62 | 5 U | -- | 5 U | 7.8 | 5 U | 320 | 2.5 U | 51 |
| SP-204 | Pre-GAC | 12/19/2007 | µg/L | 5 U | 5 U | 50 U | 250 U | 2.5 U | 5 U | 62 | 2.5 U | 5 U | 25 | 18 | 5 U | -- | 5 U | 7.3 | 5 U | 260 | 2.5 U | 46 |
| SP-206 | Post-Primary GAC | 12/19/2007 | µg/L | 1 U | 1 U | 10 U | 110 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.51 | 36 |
| SP-208 | Post-Secondary GAC | 12/19/2007 | µg/L | 1 U | 1 U | 10 U | 86 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 27 |
| SP-210 | Post-Moisture Sperator | 12/19/2007 | µg/L | 1 U | 1 U | 10 U | 93 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 2.5 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 10 | 0.5 U | -- |
| SP-212 | VCP Drainage | 12/19/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | -- |
| SP-201 | Influent | 12/28/2007 | µg/L | 2 U | 2 U | 20 U | 100 U | 1 U | 2.8 | 150 | 1 U | 4.8 | 44 | 17 | 2 U | -- | 2 U | 2 U | 2 U | 330 | 2.6 | 21 |
| SP-204 | Pre-GAC | 12/28/2007 | µg/L | 2 U | 2 U | 20 U | 110 | 1 U | 2 U | 180 | 12 | 4 | 29 | 20 | 2 U | -- | 2 U | 3.7 | 2 U | 270 | 1.7 | 33 |
| SP-206 | Post-Primary GAC | 12/28/2007 | µg/L | 1 U | 1 U | 10 U | 110 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.82 | 39 |
| SP-208 | Post-Secondary GAC | 12/28/2007 | µg/L | 1 U | 1 U | 10 U | 85 | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 1 U | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 1 U | 0.5 U | 33 |
| SP-210 | Post-Moisture Sperator | 12/28/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | 1 U | 2.2 | 1 U | 1 U | -- | 1 U | 1 U | 1 U | 13 | 0.5 U | -- |
| SP-212 | VCP Drainage | 12/28/2007 | µg/L | 1 U | 1 U | 10 U | 50 U | 0.5 U | 1 U | 1 U | 0.5 U | | | | | | | | | | | |

Notes:
Bolded results indicate positive detections.
Only analytes with at least one positive detection in 2007 are listed in this table. For complete lab reports, see [Appendix 4](#).
Analyses were performed by Calscience Environmental Laboratories, Inc. located in Garden Grove, CA.
1,1-DCA - 1,1-dichloroethane; 1,1-DCE - 1,1-dichloroethene; cis-1,2-DCE - cis-1,2-dichloroethene; trans-1,2-DCE - trans-1,2-dichloroethene
GAC - granular activated carbon
VCP - vapor conditioning package
U - not detected above the stated reporting limit; UJ - not detected at estimated reporting limit; J - quantitative estimate
"--" - not available
µg/L - microgram per liter

Table 4.5
Groundwater Treatment System Performance
Pemaco Superfund Site, Maywood, CA

| Month | Notes | Monthly Operating Time | Monthly Percent Uptime | Average Flow Rates | | | | Cumulative Groundwater Volume Treated | TCE Mass Removed | | | | | VOC Mass Removed | | | | |
|-----------|--------|------------------------|------------------------|--------------------|---------|---------|---------|---------------------------------------|---|---|--------------|-----------------|--------------|---|---|--------------|-----------------|--------------|
| | | | | FQI-401 | FQI-201 | FQI-501 | FQI-402 | | Average TCE Concentration (SP-201) ¹ | Average TCE Concentration (SP-210) ² | Monthly Mass | Cumulative Mass | Removal Rate | Average Total VOC Concentration (SP-201) ¹ | Average Total VOC Concentration (SP-210) ² | Monthly Mass | Cumulative Mass | Removal Rate |
| | Units: | (hours) | (hours) | (gpm) | (gpm) | (gpm) | (gpm) | (gallons) | (µg/L) | (µg/L) | (pounds) | (pounds) | (lbs/day) | (µg/L) | (µg/L) | (pounds) | (pounds) | (lbs/day) |
| April | a | 144 | 100 | 16.6 | 0.0 | 0.3 | 20.4 | 205,838 | NA | NA | 0.84 | 0.84 | 0.08 | NA | NA | 0.93 | 0.93 | 0.09 |
| May | | 732 | 98 | 17.6 | 2.8 | 1.2 | 29.9 | 1,400,260 | 610.0 | 110.0 | 4.57 | 5.42 | 0.11 | 618.5 | 110.0 | 5.14 | 6.07 | 0.13 |
| June | b | 511.5 | 71 | 15.2 | 1.0 | 2.6 | 23.2 | 2,474,225 | 435.0 | 108.8 | 3.11 | 8.53 | 0.07 | 435.0 | 114.3 | 4.02 | 10.09 | 0.09 |
| July | | 741 | 100 | 24.6 | 0.7 | 2.7 | 33.3 | 3,934,100 | 360.0 | 29.5 | 2.64 | 11.17 | 0.08 | 360.0 | 65.5 | 4.34 | 14.43 | 0.12 |
| August | | 738 | 99 | 23.6 | 0.3 | 3.4 | 33.5 | 5,484,900 | 562.5 | 29.3 | 4.63 | 15.80 | 0.11 | 566.0 | 129.0 | 5.35 | 19.78 | 0.12 |
| September | c | 652 | 91 | 25.0 | 1.1 | 3.4 | 33.3 | 6,934,790 | 407.5 | 15.6 | 3.49 | 19.29 | 0.10 | 460.8 | 141.7 | 11.71 | 31.49 | 0.34 |
| October | | 741 | 100 | 22.2 | 0.9 | 1.9 | 30.5 | 8,388,205 | 135.0 | 9.1 | 1.57 | 20.86 | 0.03 | 172.5 | 329.0 | 6.16 | 37.65 | 0.13 |
| November | | 693.8 | 96 | 25.4 | 1.1 | 1.1 | 35.9 | 9,831,202 | 286.0 | 6.9 | 2.04 | 22.91 | 0.06 | 300.0 | 231.0 | 3.42 | 41.07 | 0.11 |
| December | | 713.5 | 96 | 24.0 | 1.1 | 2.3 | 36.5 | 11,460,978 | 385.0 | 11.2 | 3.24 | 26.15 | 0.10 | 468.5 | 108.0 | 6.04 | 47.11 | 0.16 |

| | |
|--|------------|
| Total Mass of TCE Removed during 2007 (pounds) | 26.2 |
| Total Mass of VOCs Removed during 2007 (pounds) | 47.1 |
| Average TCE Removal Rate during 2007 (lbs/day) | 0.08 |
| Average VOC Removal Rate during 2007 (lbs/day) | 0.14 |
| Average Groundwater Flow Rate during 2007 (gpm) | 31 |
| Cumulative Volume of Water Treated during 2007 (gallons) | 11,460,978 |
| Water Treatment Plant Operating Time during 2007 (hours) | 5,667 |
| Water Treatment Plant Percent Uptime during 2007 (%) | 94 |

Notes:

- 1 - Sample collected from combined flow from all extraction wells into the treatment system.
- 2 - Sample collected from liquid stream leaving the moisture separator.
- a - The groundwater treatment system began operation on 4/25/07.
- b - The groundwater system was offline from 6/22/07 to 6/29/07 due to maintenance and GAC vessel repair.
- c - The groundwater system was offline from 9/7/07 to 9/10/07 due to air compressor maintenance.
- FQI-201 measures flow from non-contact water from the vapor conditioning unit; FQI-501 measures flow from the moisture separator; FQI-401 measures flow from all groundwater manifolds; and FQI-402 measures flow into the final holding tank prior to discharge.
- Analysis for VOCs was performed by Calscience Environmental Laboratories, Inc. using EPA 8260B.
- GAC - granular activated carbon
- TCE - trichloroethene
- VOC - volatile organic compound
- NA - not applicable
- µg/L - microgram per liter
- gpm - gallons per minute
- lbs/d - pounds per day

Table 4.6
Sewer Discharge Analytical Results for Effluent Groundwater Samples from SP-209
Pemaco Superfund Site, Maywood, CA

| | | | Station ID: | SP-209 | SP-209 | SP-209 |
|--------------------------------|--------------|--------------------|-------------|-----------|-----------|------------|
| | | | Date: | 4/25/2007 | 8/23/2007 | 11/20/2007 |
| | | | Units: | µg/L | µg/L | µg/L |
| Analyte | Method | Limit ¹ | | | | |
| Volatile Organic Compounds | | | | | | |
| Bromodichloromethane | EPA 8260B | -- | 1 U | 16 | 1 U | |
| Bromoform | EPA 8260B | -- | 1 U | 40 | 1 U | |
| Chloroform | EPA 8260B | -- | 1 U | 9 | 1 U | |
| Dibromochloromethane | EPA 8260B | -- | 1 U | 34 | 1 U | |
| Total VOCs ² | EPA 8260B | 1,000 µg/L | 1 U | 90 | 1 U | |
| Semivolatile Organic Compounds | | | | | | |
| Bis(2-Ethylhexyl) phthalate | EPA 8270C | -- | 10 U | 10 U | 21 | |
| Total SVOCs ² | EPA 8270C | 1,000 µg/L | 10 U | 10 U | 21 | |
| General Chemistry Parameters | | | | | | |
| | | | Units: | mg/L | mg/L | mg/L |
| Dissolved Sulfide | SM 4500 S2-D | 0.1 mg/L | 0.05 U | 0.05 U | 0.05 U | |
| Oil and Grease | SM 5520 B | -- | 1.4 | 2.4 | 1 U | |
| Chemical Oxygen Demand | EPA 410.4 | -- | 5 | 26 | 23 | |
| Lead | EPA 6010B | 40 mg/L | 0.01 U | 0.01 U | 0.01 U | |
| Total Suspended Solids | SM 2540 D | -- | 4.9 | 3.1 | -- | |
| pH | SM 4500 H+B | 6.5 - 8.5 | 7.03 | 7.11 | 7.71 | |
| Physical Data | | | | | | |
| Total Wastewater Flow Rate | NA | 57,600 gpd | 26,784 | 28,510* | 46,335 | |
| Peak Wastewater Flow Rate | NA | 40 gpm | 18.6 | 19.8* | 32.2 | |
| Temperature | NA | < 140°F | -- | 96 | 84 | |
| Closed Cup Flash Point | NA | > 140°F | -- | -- | -- | |

Notes:

1 - Limits are based on the water discharge permit issued by the Sanitation District of Los Angeles County.

See [Appendix 5](#) for groundwater discharge permit details.

2 - Total VOCs were calculated using only individual VOC concentrations that were greater than 10 µg/L.

* - Estimated based on the Operation Summary Report ([Appendix 7](#)).

Analyses were performed by Calscience Environmental Laboratories, Inc. in Garden Grove, CA.

Only analytes with at least one positive detection in 2007 are listed in this table. For complete lab reports, see [Appendix 4](#).

Bolded results indicate positive detections.

SVOCs - semivolatile organic compounds

VOCs - volatile organic compounds

NA - not applicable

U - not detected above the stated reporting limit

--" - not available

µg/L - microgram per liter

°F- degree Fahrenheit

gpd - gallons per day

gpm - gallons per minute

lbs/d - pounds per day

mg/L - milligram per liter

Table 4.7
DRE of the Gourndwater Treatment System
Pemaco Superfund Site, Maywood, CA

| Station ID: | | | SP-201 ³ | SP-210 ⁴ | Total | SP-209 | DRE (%) | SP-201 ³ | SP-210 ⁴ | Total | SP-209 | DRE (%) | SP-201 ³ | SP-210 ⁴ | Total | SP-209 | DRE (%) |
|----------------------------|--------------------|-------|---------------------|---------------------|---------|----------|---------|---------------------|---------------------|---------|----------|---------|---------------------|---------------------|---------|----------|---------|
| Description: | | | Influent | Moisture Separator | Pre-GAC | Post-GAC | | Influent | Moisture Separator | Pre-GAC | Post-GAC | | Influent | Moisture Separator | Pre-GAC | Post-GAC | |
| Date ¹ : | | | 4/25/2007 | | | | | 8/23/2007 | | | | | 11/20/2007 | | | | |
| Analyte | Limit ² | Units | | | | | | | | | | | | | | | |
| Volatile Organic Compounds | | | | | | | | | | | | | | | | | |
| 1,1-Dichloroethane | -- | µg/L | 2 | 1 U | 2 | 1 U | 100.0 | 5 U | 1 U | 5 U | 1 U | NA | 2 U | 1 U | 2 U | 1 U | NA |
| 1,1-Dichloroethene | -- | µg/L | 1.5 | 1 U | 1.5 | 1 U | 100.0 | 5 U | 1 U | 5 U | 1 U | NA | 2 U | 1 U | 2 U | 1 U | NA |
| 1,4-Dioxane* | -- | µg/L | 5.5 | 50 U | 5.5 | 2 U | 100.0 | 2.9 | 72 | 74.9 | 28 | 62.6 | 9.6 | 50 U | 9.6 | 28 | NC |
| Benzene | -- | µg/L | 1.4 | 0.59 | 1.99 | 0.5 U | 100.0 | 2.5 U | 1 | 1 | 0.5 U | 100.0 | 1 U | 0.5 U | 1 U | 0.5 U | NA |
| Bromodichloromethane | -- | µg/L | 1 U | 1 U | 1 U | 1 U | NA | 5 U | 4.1 | 4.1 | 16 | NC | 2 U | 1 U | 2 U | 1 U | NA |
| Bromoform | -- | µg/L | 1 U | 1 U | 1 U | 1 U | NA | 5 U | 5.6 | 5.6 | 40 | NC | 2 U | 1 U | 2 U | 1 U | NA |
| Chloroform | -- | µg/L | 9.3 | 1 U | 9.3 | 1 U | 100.0 | 7.6 | 11 | 18.6 | 9 | 51.6 | 6.8 | 1 U | 6.8 | 1 U | 100.0 |
| Dibromochloromethane | -- | µg/L | 1 U | 1 U | 1 U | 1 U | NA | 5 U | 5.6 | 5.6 | 34 | NC | 2 U | 1 U | 2 U | 1 U | NA |
| Tetrachloroethene | -- | µg/L | 1.2 | 1 U | 1.2 | 1 U | 100.0 | 5 U | 1 U | 5 U | 1 U | NA | 2 U | 1 U | 2 U | 1 U | NA |
| Toluene | -- | µg/L | 1 U | 1 U | 1 U | 1 U | NA | 5 U | 59 | 59 | 1 U | 100.0 | 2 U | 1 U | 2 U | 1 U | NA |
| trans-1,2-Dichloroethene | -- | µg/L | 2.1 | 1 U | 2.1 | 1 U | 100.0 | 5 U | 1 U | 5 U | 1 U | NA | 2 U | 1 U | 2 U | 1 U | NA |
| Trichloroethene | -- | µg/L | 670 | 110 | 780 | 1 U | 100.0 | 730 | 7.4 | 737.4 | 1 U | 100.0 | 290 | 7.8 | 297.8 | 1 U | 100.0 |
| Vinyl chloride | -- | µg/L | 0.88 | 0.5 U | 0.88 | 0.5 U | 100.0 | 3.1 | 0.5 U | 3.1 | 0.5 U | 100.0 | 2.2 | 0.5 U | 2.2 | 0.5 U | 100.0 |
| Total VOCs | 1,000 | µg/L | 694 | 111 | 804 | 1 U | 100.0 | 744 | 166 | 909 | 118 | 87.0 | 309 | 8 | 316 | 28 | 91.2 |

Notes:
1 - Samples from SP-201 were collected on 5/3/07, 8/21/07, and 11/19/07.
 Samples from SP-210 were collected on 5/18/07, 8/21/07, and 11/19/07.
 Samples from SP-209 were collected on the date shown.
2 - Limits are based on the water discharge permit issued by the Sanitation District of Los Angeles County. See [Appendix 5](#) for groundwater discharge permit details.
3 - Sample collected from combined flow from all extraction wells into the treatment system.
4 - Sample collected from liquid stream leaving the moisture separator.
* - Samples collected from SP-209 were not analyzed for 1,4-dioxane; concentrations shown are from the post-secondary GAC samples from SP-208 (on 5/3/2007 and 8/21/07) and from SP-206 (on 11/19/07)
Analyses were performed by Calscience Environmental Laboratories, Inc. in Garden Grove, CA using method EPA 8260B.
Only anaytes with at least one positive detection in 2007 are listed in this table. For complete lab reports, see [Appendix 4](#).
Bolded results indicate positive detections.
DRE - destruction and removal efficiency
GAC - granular activated carbon
NA - not applicable
NC - not calculated
VOCs - volatile organic compounds
U - not detected above the stated reporting limit
"--" - not available
µg/L - microgram per liter

Table 6.1
Optimization & Maintenance of the Treatment System Summary
Pemaco Superfund Site, Maywood, CA

| Item No. | Description | Details |
|----------|--|--|
| 1 | Solar Panel Construction | A 20 kWh/day solar system was installed to meet EPA sustainability goals. |
| 2 | Structural Modification to Roof for Scrubber | Performed custom sheet metal fabrication to house the scrubber loop. |
| 3 | DPE-Sumps & VE-Sumps Retrofit | 1. Pressure tested existing system and repaired leaks 2. Replaced DPE-A level gauge 3. Retrofitted VE-3 & 4 valving to be compatible with ERH system 4. Installed four (4) pneumatic pumps with level controls in 4 DPE-sumps, to automate water removal |
| 4 | Moisture Separator T-101 Replacement | The first T-101 failed because it did not meet the required 29 in Hg vacuum specification. The tank replacement was performed by ERM under warranty. The second tank T-101 had to be reinforced by a steel "belt" around the tank after showing signs of structural stress. |
| 5 | Earthwork | 1. Spread gravel outside the Treatment Compound to create a maintenance free compound yard 2. Installed a vault for the water meter to protect from the Treatment Compound traffic 3. Repaired PD-4 well vault to eliminate irrigation water infiltration |
| 6 | Dekker Pump Oil Blow by Remedy | 1. Installed six (6) additional scavenge lines to capture excess oil 2. Replaced leaking Dekker filter 3. Installed additional Solberg demisting inserts in the oil filters F-103 and 104 4. Added vacuum gauges (0-30 in w.c.) to Solberg F-103 and F-104 to more accurately gauge headloss |
| 7 | Potable Water Pressure Boost System for FTO | Installed a water pressure boost system to maintain the water supply pressure per FTO operation requirements. |
| 8 | FTO Evaluation - Flow Meter, Fuel Sensitivity | Added manual magnehelic gauge. Inspected and optimized the gas control valve settings, burner temperature, checked influent vapor pressure alarms. |
| 9 | FTO-VCP Interface | TN&A installed the following items to allow the FTO to operate in tandem with the vapor conditioning package: 1. PS-101 pressure switch, wiring, and PLC interlock reprogramming 2. Barometric damper 3. Differential pressure gauge 4. Moisture drain valve for VE-201 5. PLC interlocks and reprogramming |
| 10 | FTO Valve Switch FCV-400 and XV-401 | Retrofitted location of valve to match Anguil construction drawings. |
| 11 | FTO Bellows Insulation Remedy | 1. Adjusted quench chamber spray nozzles and replaced the broken quench chamber insulation inside the FTO bellows in August 2007 2. Discovered another hot spot on the flexible duct on 12/18/07. The hot spot was caused by misalignment of #1B nozzle. Patched ceramic fiber blanket as a temporary repair of hot spot. |
| 12 | Raise T-402 LSHH Elevation | Increased virtual tank capacity, provided additional buffer against HH alarms in T-402. |
| 13 | 7 QED Pumps Removal/Repaired | Sediment build up in downhole pumps caused pump shut down. Seven pumps were pulled, valves replaced, and the pumps were reinstalled several feet higher in the wells. |
| 14 | Electrical Related Retrofit and Repair | The following items were installed or retrofitted: 1. Two (2) underground junction boxes, conduit and wire for (2) telephone circuits and control wiring between MCP and the ERH area 2. One hand-off-auto switch at sump pump (P-502) 3. Two 100 watt 90 minute battery back-up emergency light fixtures in Treatment Compound 4. One 90 minute battery back-up battery for (1) control room light fixture 5. Conduit and wire from VCP to one (1) pressure switch at FTO 6. Two (2) broken conduits at FTO were replaced with steel conduits 7. Conduit and type J thermocouple wire from existing thermal couple at H-202 to MCP |
| 15 | Re-route Air-line to Double Diaphragm Pumps | Required to keep DD pumps operating after GW system shuts down, such as during GW tank High-High alarm. |
| 16 | Silencers for Dilution Valves | Added silencers for the dilution valves V-112 and V-319 to reduce noise while operating. |
| 17 | Moisture Traps for Magnahelic Gauges | Installed moisture traps to prevent unintended exhaust blower (B-301) ramp up. |
| 18 | Line Reactor for Potable Boost Pump | Installed manufacturer's recommended fix to control SCE voltage spikes |
| 19 | Resistor Package for P-402 | Installed manufacturer's recommended fix to control SCE voltage spikes |
| 20 | GAC Vessel T-403 and T-404 Repair | Repaired broken fittings that attached the screen/filter inside of the carbon vessels. The replacement was required because the original fittings did not meet the manufacturer's specs. |
| 21 | Anti-Siphon for PVC line linking T-401 and T-402 | Installed a PVC vacuum breaker/air relief valve for PVC line linking T-401 and T-402. |
| 22 | T-401 Chlorine Injection System | Installed a chlorine injection system to control algae build up in the holding tanks and reduce the filter bag consumption. |
| 23 | Security System for ERH Area | Installed a double-beam system with interlocks and alarm for safety concerns. The system automatically shuts down the ERH system and power supply if an intrusion occurs. |
| 24 | ERH Fence Extension along the Bike Path | Installed additional fence extension along the bike path to discourage unauthorized entry to the ERH area. |
| 25 | Custom Sample Ports for Dioxin Testing | Installed two custom 8 in diameter fiberglass spools with opposing 3 in diameter flanged sample ports for dioxin sampling. |
| 26 | GAC Backwash System | Performed conceptual design of GAC backwash system to resolve numerous high level shut downs of the treatment plant caused by excessive sediment in the pumped groundwater. |
| 27 | MW Well Cap retrofit in ERH Area | Retrofitted 20 monitoring wellheads to be compatible with ERH heat and pressure generation. |
| 28 | Upgrade MW-24-110 to Extraction Well | Installed pump and plumbing from MW-24-110, aboveground, to vault at MW-24-140. Installed air regulator and controller. |
| 29 | FE-101 Reporting Incorrect Air Flow | Relocated dPIT-101 to measure more accurate air flow. |
| 30 | LRP Oversize Sheaves Replacement | Replaced Dekker Liquid Ring Pump B-101/B-102 oversize sheaves (10 7/8") with new sheaves (9 ¾"). The oversize sheaves caused the two blower motors to run at a higher than specified ampacity. The high ampacity caused excess heat in the LRP electrical panel, necessitating the replacement of the motor overload protection models, some wiring, and the addition of a panel fan. In hindsight, Dekker did not catch the oversize sheave during QA/QC at the assembly shop. |
| 31 | FTO Broken Part Replacements | 1. SV-844 Solenoid Valve (twice). 2. 3/4" Leaking CPVC Fittings (FTO Blowdown Line next to SV-844). 3. FSL-872 3/4" NPT Flow Switch (twice). 4. LE-832 Level Transmitter. 5. Starter for the FTO recirculation pump. |
| 32 | Well RW-01-70 Retrofit | Well RW-01-70 is an A-Zone well in ERH area that went dry retrofitted as a SVE well. |

NOTES

- CPVC - chlorinated polyvinyl chloride

DD - double diaphragm

DPE - dual-phase extraction

ERH - electrical resistance heating

FTO - flameless thermal oxidizer

GAC - granular activated carbon

GW - groundwater;

kWh/day - kiloWatt hours per day
- LRP - liquid ring vacuum pump;

MCP - main control panel

PLC - programmable logic controller

PVC - polyvinyl chloride

SCE - Southern California Edison Inc.

SV - solenoid valve

VCP - vapor conditioning package;

VE - vapor extraction

Table 6.2
Daily and Weekly Maintenance Summary
Pemaco Superfund Site, Maywood, CA

| No. | Operation and Maintenance Task | Frequency | Crew |
|-----|--|-----------|------------|
| 1 | Change filter bags for F-401/F-402, F-403/F-404, and F-501/F-502 as required. Check before leaving every day. | Daily | M. Tabora |
| 2 | Record differential pressure of T-403 and T-404 (carbon vessels for GW). Scrape carbon as needed. | Daily | M. Tabora |
| 3 | Inspect water softner F-801, add salt to the brine tank as needed. | Daily | M. Tabora |
| 4 | Inspect secondary containment sump. Pump down the sump as needed. | Daily | M. Tabora |
| 5 | Inspect of DPE and VE condensate sumps. Pump down the sumps and remove scale as needed. | Daily | M. Tabora |
| 6 | Inspect the water level in cooling tower CT-201 and check recirculating pump pressure differential. | Daily | M. Tabora |
| 7 | Add chlorine to T-101 using granular chlorine (6 oz per day) or liquid chlorine (8 oz). | Daily | M. Tabora |
| 8 | Inventory management of PPE, chlorine liquid, granules, tablets, oil & lubricants, filter bags, and spare parts. | Daily | M. Tabora |
| 9 | Check chlorine injection system, look for air pockets in line. Repair as needed. | Daily | M. Tabora |
| 10 | Take chlorine residual readings after T-402. The chlorine should maintain 1.5 to 2.0 ppm. Adjust chlorine injection pump speed and stroke as needed. | Daily | E. Moncayo |
| 11 | Inspect operation of FTO and check for hot spots and other problems with ceramic burner elements. | Daily | E. Moncayo |
| 12 | Conduct daily tailgate safety meetings, practice hazard communication and complete Daily QC report. | Daily | M. Prostko |
| 13 | Inspect ERH Security System | Daily | M. Prostko |
| 14 | All Sampling and Forms (#1 ~ #13) | Weekly | M. Prostko |
| 15 | Perform FTO Weekly Maintenance Checks | Weekly | E. Moncayo |
| 16 | Record differential pressure of oil mist filters F-103/F-104. Change filter element as needed. Inspect of oil scavenge lines for leaks and proper functioning. | Weekly | M. Tabora |
| 17 | Inspect GW-3 secondary containment overflow, pump water if necessary. | Weekly | M. Tabora |
| 18 | Complete - Exposition Wells, Perched Wells, ERH VR Wells /Electrode Well forms | Weekly | E. Moncayo |
| 19 | Record differential pressure of T-301 and T-302 (carbon vessels for Vapor). Scrap carbon as needed. | Weekly | M. Tabora |
| 20 | Grease motors in TC. | Weekly | E. Moncayo |
| 21 | Complete Weekly QC Report, Labor Schedule, and Weekly BMP Inspection. | Weekly | M. Prostko |
| 22 | Track all gov owned small tools that should be on the site . | Weekly | M. Prostko |

Notes:

BMP - best management practices; DPE - dual-phase extraction; ERH - electrical resistance heating; FTO - flameless thermal oxidizer
 GW - groundwater; QC - quality control; TC - treatment compound; VE - vapor extraction; VR - vapor recovery
 ppm - part per million by volume

Table 6.3
Equipment Maintenance Schedule
Pemaco Superfund Site, Maywood, CA

| Equipment ID | Description | Manufacturer/Model | Maintenance Parts | Maintenance Type | Frequency Required | Date Performed in 2007 | | Comments |
|------------------------------|----------------------------------|--------------------------------------|-------------------|---|--|-----------------------------------|------------------------------------|---|
| B-101 B-102 | Liquid Ring Vacuum Pump | Dekker VMX1103K | Pump Bearings | High Temperature Lithium Based Grease of #2 Consistency | Every 3,000 hours | 10/8/07 | 1/15/2008 B-101 oil changed | |
| | | | Sealing Fluid | Vmaxol Sealing Fluid | Every 10,000 hours | | | |
| B-301 | Positive Displacement Blower | Roots Rotary Blower Size 615 | | ROOTS Synthetic Oil | Every 4,000 to 8,000 hours | 8/17/07 | | Oil changed 8/17/07 |
| P-201 | Cooling Tower Transfer Pump | SCOT ARDOX Motorpump - 1750 RPM | | Inspection | Every 3 months | 10/8/07 | 12/20/07 | Does not require lubrication |
| P-202 | Refrigerated Chiller Pump | ITT Goulds Pump - 2ST1H5B4 | Bearing Frame | #2 Sodium or Lithium Based Grease | Every 2,000 hours | 10/8/07 | 12/20/07 | |
| P-203 | VC Package Condensate Pump | Pacer Pump - Z-40 | | Inspection | Every 3 months | 10/8/07 | 12/20/07 | Does not require lubrication |
| P-401 | Booster Tank Pump | ITT Goulds Pump - 2ST1H2B4 | Bearing Frame | #2 Sodium or Lithium Based Grease | Every 2,000 hours | 10/8/07 | 12/20/07 | |
| P-402 | Holding Tank Pump | ITT Goulds Pump - 2ST1JSA4 | Bearing Frame | #2 Sodium or Lithium Based Grease | Every 2,000 hours | 10/8/07 | 12/20/07 | |
| P-501 | Moisture Separator Transfer Pump | AMT 282B-98 | | Inspection | Every 3 months | 10/8/07 | | Does not require lubrication |
| P-502 | Secondary Sump Pump | Gorman-Rupp Pump S2H54 E1 | Seal Cavity | Inspection | Every 3 months | 10/8/07 | | Does not require lubrication |
| P-901 | Metering Pump | MiltonRoy D7988PE1NIN | | Inspection | Every 3 months | 10/8/07 | | Does not require lubrication |
| K-601 | Air Compressor | Kaeser AS-30 | | Service | Every 2 months | 9/7/2007 (American Compressor) | 12/3/2007 (American Compressor) | Changed oil and air filter was replaced 9/7/07. |
| F-801 | Water Softner | U.S. Filter KF Series KFZSD021FPZVCX | Manual Valves | Inspection | Inspect Every 6 months | | | |
| CT-201 | Cooling Tower | Aqua-Loop MB-300 | V-Belt | Inspection | Every 5,000 to 10,000 hours | | | |
| H-201 | Heat Exchanger | Xchanger TV-275 | | Inspection | Every 3 months | 10/8/07 | | Does not require lubrication |
| H-401 | Heat Exchanger | Xchanger LC-24-2 | | Lubrication | Refer to the maintenance instructions provided with the motors | 10/8/07 | | |
| RC-201 | Refrigerated Chiller | Zarsky ACWC-300-E | Condenser Coils | Inspection/Clean | Every 6 months | | | |
| NA | Water Pressure Boost Pump | Goulds 3SVB-4ST6 | | Lubrication | Every 6 months | 10/8/07 | | |

Notes:

NA - not applicable

Table 6.4
FTO Maintenance Schedule
Pemaco Superfund Site, Maywood, CA

| Description | Action Required | Frequency | Date Performed in 2007 | |
|--------------------------------------|---|-------------------|------------------------|--|
| General | | | | |
| Weekly Maintenance Checks | Follow Anguil weekly inspection instruction. | Weekly | NA | |
| System Fan/Blower | | | | |
| Fan and Motor Bearing Lubrication | Follow blower and motor manufacturer's instructions | Every 2,000 Hours | 10/8/07 | |
| Fan Wheel | Check and clean quarterly. If worn out or out of balance (excessive vibration) contact Anguil. | Quarterly | 10/8/07 | |
| Air Proving Switch | Check for proper operation by increasing set point until the switch trips. | Semi-annually | | |
| Inlet Filter | Check every 30 days of operation. Clean or replace, if required. | 30 Days | 10/8/07 | |
| Belt/Power Band | Inspect for proper belt tension monthly or 2-3 days after any belt replacement, as applicable to your specific unit. Tighten or replace as necessary, following manufacturer's instructions. | 30 Days | 10/8/07 | |
| Controllers | | | | |
| Configuration/Calibration | Check and adjust quarterly. Check for proper air flow measurement/recording. Calibrate transmitter, as necessary. | Quarterly | | |
| Controllers | Check for proper air flow measurement/recording. Calibrate transmitter, as necessary. | Quarterly | | |
| Burner | | | | |
| UV Scanner/Spark Ignitor | Inspect UV scanner and spark ignitor quarterly. Clean if necessary, replace yearly. | Quarterly | | |
| Burner | Have burner tuning checked yearly by Anguil or qualified Alzeta Burner Technician. Technician should also check operation of burner assembly parts, such as the check valve, pilot assembly and fuel train. | Yearly | | |
| Fuel Train | | | | |
| Shut Off Valve | Check main shut off valve for leakage semi-annually. | Semi-annually | | |
| Pressure Switch | Check high and low gas pressure switches. Verify proper operation by adjusting set point up or dwn until the switch open. | Semi-annually | | |
| Gas Pressure | Verify that all gas pressures are within previously recorded parameters. | Semi-annually | | |
| Firing Rate Valve | Check operation of firing rate valve and actuator. Use controller manual mode to run it through its full stroke. Check linkage for blinding, slippage, wear and corrosion. Replace if necessary. | Semi-annually | | |
| Dampers | | | | |
| | Check system inlet, dilution air and bypass dampers for free movement. Check linkage for blinding, slippage, wear and corrosion. Replace if necessary. | Semi-annually | 10/8/07 | |
| General | | | | |
| Nuts and Bolts | Quarterly inspect locations for tightness, as applicable to your specific unit. Tighten, as necessary. | Quarterly | 10/8/07 | |
| Mounting Plate of Burner | Quarterly inspect locations for tightness, as applicable to your specific unit. Tighten, as necessary. | Quarterly | 10/8/07 | |
| Ductwork to Burner | Quarterly inspect locations for tightness, as applicable to your specific unit. Tighten, as necessary. | Quarterly | 10/8/07 | |
| Top and Bottom Reactor Doors | Quarterly inspect locations for tightness, as applicable to your specific unit. Tighten, as necessary. | Quarterly | 10/8/07 | |
| Hot Air Bypass Inner and Outer Doors | Quarterly inspect locations for tightness, as applicable to your specific unit. Tighten, as necessary. | Quarterly | 10/8/07 | |
| Stack and Stack Transition | Quarterly inspect locations for tightness, as applicable to your specific unit. Tighten, as necessary. | Quarterly | 10/8/07 | |
| Safety Review | | | | |
| Safety Review Meeting | A yearly safety review of the equipment should consist of a meeting with all operation and maintenance personnel to review hazards. | Yearly | | |
| Anguil Service Annual Visit | Annual visit by trained Anguil Service Technician for check of system balance and control calibration | Yearly | | |

Notes:

FTO - flameless thermal oxidizer

NA - not applicable

T N & Associates, Inc.

Table 8.1
Resource and Utility Usage Summary
Pemaco Superfund Site, Maywood, CA

| | Water Usage (thousand gallons) | Gas Usage (cubic feet) | Treatment Plant Electric Usage (kWh) | ERH Electric Usage (kWh) | Number of Filter Bags Used ¹ | Number of 55- pound Bags of Salt ² | Caustic Solution ³ (gallon) |
|---------------|--------------------------------------|---------------------------|--|--------------------------------|--|---|---|
| January | 6 | -- | -- | -- | -- | -- | -- |
| February | 5 | -- | 1,120 | -- | -- | -- | -- |
| March | 5 | -- | 240 | -- | -- | -- | -- |
| April | 49 | -- | 5,440 | -- | 14 | -- | 800 |
| May | 356 | 3,784 | 43,520 | -- | 105 | 34 | -- |
| June | 435 | 5,773 | 105,840 | -- | 152 | 27 | -- |
| July | 532 | 7,477 | 65,280 | -- | 219 | 39 | -- |
| August | 556 | 8,475 | 135,833 | -- | 119 | 72 | 1,055 |
| September | 853 | 11,027 | 107,608 | -- | 56 | 69 | -- |
| October | 583 | 11,996 | 159,660 | 655,506 | 77 | 83 | -- |
| November | 1,082 | 10,550 | 129,817 | 869,931 | 131 | 68 | 1,055 |
| December | 760 | 11,383 | 139,406 | 794,433 | 221 | 75 | 1,055 |
| TOTAL: | 5,222 | 70,465 | 893,764 | 2,319,870 | 1,094 | 467 | 3,965 |

Notes:

1 - Filter bags were used for F-401, F-402, F-403, F-404, F-501, and F-502 bag filters.

2 - Salt was used for F-801 water softener in the treatment plant.

3 - Caustic solution (25% NaOH with 10% sodium thiosulfate) was used for FTO scrubber operation.

ERH - electrical resistance heating

FTO - flameless thermal oxidizer

kWh - kiloWatt hour

Table 10.1
Waste GAC and Filter Bag Disposal Summary
Pemaco Superfund Site, Maywood, CA

| Date | Liquid/Vapor | Vessel ID | Volume/Quantity | Subcontractor | TSDFs (treatment, storage, and disposal facilities) | Manifest Number |
|----------------------------|--------------|-----------|-----------------|-------------------|---|-----------------|
| GAC Disposal | | | | | | |
| 6/20/2007 | Liquid Phase | T-403 | 3,000 pounds | Prominent Systems | Chemical Waste Management, Inc., Kettleman City, CA | NH08280702 |
| 7/17/2007 | Liquid Phase | T-404 | 3,000 pounds | Prominent Systems | Chemical Waste Management, Inc., Kettleman City, CA | NH08280702 |
| 11/2/2007 | Liquid Phase | T-403 | 3,000 pounds | Prominent Systems | Chemical Waste Management, Inc., Kettleman City, CA | NH12170701 |
| 11/27/2007 | Liquid Phase | T-404 | 3,000 pounds | Prominent Systems | Chemical Waste Management, Inc., Kettleman City, CA | NH12170701 |
| Filter Bag Disposal | | | | | | |
| 7/13/2007 | NA | NA | 285 | Haz Mat Trans | Siemens Water Technologies Corp., Vernon, CA | NH54754-A |
| 8/10/2007 | NA | NA | 255 | Haz Mat Trans | Siemens Water Technologies Corp., Vernon, CA | NH54974-A |
| 11/8/2007 | NA | NA | 222 | Haz Mat Trans | Siemens Water Technologies Corp., Vernon, CA | NH55802-A |

Notes:

Analytical reports for filter bag and carbon profiles issued by Calscience Environmental Laboratories are included in [Appendix 6](#).

GAC - granular activated carbon

TSDf - Treatment Storage and/or Disposal Facility

Table 11.1
Sample Daily Report
Pemaco Superfund Site, Maywood, CA

| RAPID RESPONSE QUALITY CONTROL DAILY REPORT | | |
|--|--------------------------|---------------------|
| Contractor's Name: T N & Associates | | |
| Contract Number: DACA45-00-D-0006 | | |
| Site Name & Location: Pemaco; Maywood, CA | | |
| INSTRUCTIONS | | |
| The contractor shall submit this form daily at the close of business to the on-site COE representative. Concurrently, the contractor shall provide electronic access to the completed forms to the COE district office and the area office. | | |
| Report #: 20071203 | Delivery Order #:06 | Date: 12-03-2007 |
| Weather: Sunny | Temp. (max & min): 53-72 | Rainfall (in): 1.03 |
| <p>1. Work performed today by primary contractor on site and/or off site:</p> <ol style="list-style-type: none"> 1) Mark Prostko, Dave Allen, Edwin Moncayo, Miguel Tabora and John Wingate onsite at various times from 0630 to ~1700 to perform O&M and process sampling. Mark Wanek and Ali Kaseeh (TN&A) on site for quarterly GW sampling with Blaine Technical Services (BTS). 2) Refer to Operations Summary Table rev 12/03/07 for filter bag changes, chlorine dosing, FQI-402 meter readings and significant operational changes. Note: Vapors are being extracted from the electrodes and all CVR/VR wells from the ERH area. Vapors being pulled from VE-3, DPE-A, DPE-B, and DPE-D. ERH area condenser VE-3 pitot tube measured today 1519 hours at 1.45" Hg; 17" Hg and 78 degrees F. 3) FTO was shut down today for approximately 5 hours to inspect the electrical connections within the peckerheads of the motors and also at the starter/thermal overload areas. Jeffries Electric replaced the thermal overload for B-101 and replaced the relay for B-102 cooling fan motor. Also ID'd source of "mystery" E-stop alarm, linked to GFI Circuit #1 in LC-1 panel. Mike Ebner contacted for troubleshooting, further follow-up required to understand link between LC-1 and PLC panel. 4) Dekker Vacuum Technologies shipped incorrect retrofit sheaves for the pumps B-101/B-102. Parts could only be ID'd as incorrect after plant shut-down and belt guards were removed, allowing access. JW is coordinating with Dekker and MK Environmental for correct sheaves and will plan installation for Wednesday. Follow-up correspondence to be provided by JW. 5) American Compressor technician on site for scheduled 2,000 service on plant air compressor K-601. This also required plant shut down and was timed to blower maintenance. 6) MP checked operations and went over the plant before leaving the site at ~1615 hours. Mark Wanek and Ali Kaseeh on site with BTs sampler. GW and FTO systems running well. | | |

Table 11.1
Sample Daily Report
Pemaco Superfund Site, Maywood, CA

2. Work performed by subcontractors on site and/or off site (include a complete description):

Subcontractors:

EarthTech (Subcontractor)

09:00 AM to 5:00 PM

Edwin on site. Worked with JW inspecting new sheaves for B-101/B-102. Took apart QED pump for condensate sump DPE-B. Cleaned pump put back on line.

CLEVECO (Subcontractor)

08:00 AM to 5:00 PM

Miguel on site for continued O/M training. Working with Edwin and collecting daily readings. Change filter bags and helped MP load salt bags that were drop shipped to the site on Saturday by Eversoft.

Jeffries Electrical(Subcontractor)

11:30 AM TO 2:30 PM

Tony on site today to install new thermal overload and relay for B-101 within the LRP panel. Also worked with JW troubleshooting the E-stop alarm that occurred over the weekend and its relation to GFI circuit #1 in LC-1 Panel.

Blaine Technical Services, Inc. (Subcontractor)

07:00 AM to ~5:00 PM

One technician with sampling truck on site today to begin gauging all wells on site.

American Compressor (Subcontractor)

08:30 AM to 10:00 AM

Technician on site as scheduled by MP to complete routine 2,000 maintenance service on K-601.

TRS/ERG (Subcontractor)

Not on site today.

3. Complete and attach the daily personnel cost report at the end of this document and label as Appendix 1.

[PROVIDED IN SEPARATE BINDER]

4. On-site conditions which resulted in delayed progress:

None

Table 11.1
Sample Daily Report
Pemaco Superfund Site, Maywood, CA

5. Type and results of inspections (indicate whether: P-Preparatory, I-Initial, or F-Final and include satisfactory work completed or deficiencies with action to be taken):

Deficiencies (Ongoing list and newly identified)

Work Check List

1. REFER TO SEPARATE O&M CHECKLIST O&M to be provided one time per week (Thursday) to coincide with our RA Update Meetings.

Certification: I CERTIFY THAT THE ABOVE REPORT IS COMPLETE AND CORRECT AND THAT I, OR MY AUTHORIZED REPRESENTATIVE, HAVE INSPECTED ALL WORK PERFORMED THIS DAY BY THE PRIMARY CONTRACTOR AND EACH SUBCONTRACTOR AND HAVE DETERMINED THAT ALL MATERIALS, EQUIPMENT, AND WORKMANSHIP ARE IN STRICT COMPLIANCE WITH THE PLANS AND SPECIFICATIONS, EXCEPT AS NOTED ABOVE.

Mark Prostko

Contractor's designated quality control representative

Table 11.2
Sample Operation Summary Report
Pemaco Superfund Site, Maywood, CA

Rev: 1/02/08

| Date | Vapor System Runtime (hr) | GW System Runtime (hr) | FQI-402 Cumulative (gal) | Liquid Phase GAC Lead Vessel | Vapor Phase GAC Lead Vessel | F-801 Salt Refill (no. of 50lb bags) | Filter Bag Change-Out | | | | | | | | | | | | Chlorination | | | | | | | O&M Comments |
|----------|---------------------------|------------------------|--------------------------|------------------------------|-----------------------------|--------------------------------------|-----------------------|-----|-------|-----|-------|-----|-------|-----|-------|-----|-------|-----|-------------------------|-----|--------------------------------|-----------|--------|-----|-----------|--|
| | | | | | | | F-401 | | F-402 | | F-403 | | F-404 | | F-501 | | F-502 | | T-101 | | T-401 Dose 402 Conc. | | CT-201 | | T-202 | |
| | | | | | | | Micro | No. | Micro | No. | Micro | No. | Micro | No. | Micro | No. | Micro | No. | Dose | ppm | Dose | ppm | Dose | ppm | Algaecide | |
| 12/1/07 | 22.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 2 | 5/1 | 2 | 5/1 | 2 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 50% speed 45% stroke | 1.5 | N/A | N/A | N/A | Miguel monitoring plant operations. T-202 High High level took down FTO. FTO restarted within 2 hours. |
| 12/2/07 | 19.0 | 19.0 | N/A | T-403 | T-301 | 5 | 25/10 | 6 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 50% speed 45% stroke | 1.5 | N/A | N/A | N/A | Miguel monitoring plant operations. E-Stop alarm and possible power outage at ~955 AM. FTO and GW down for 5 hours. Plant restarted at 200 PM. |
| 12/3/07 | 19.0 | 24.0 | 10,012,295 | T-403 | T-301 | 3 | 25/10 | 2 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 50% speed 45% stroke | 1.5 - 2.0 | N/A | N/A | N/A | FQI reading at 1430 hours. Shut down FTO for 5 hours to work on electrical at LRP panel (B-101/B-102) and attempt sheave install. Installed new thermal overload for B-101. WW Henry plant is running today. Compressor 2000 Hour Service performed. |
| 12/4/07 | 24.0 | 24.0 | 10,057,231 | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 50% speed 45% stroke | 1 - 2.5 | N/A | N/A | N/A | FQI reading at 0900 hours. Added 12 ounces granular chlorine to T-401 in AM to boost chlorine residuals. WW Henry plant is running today. |
| 12/5/07 | 20.5 | 23.0 | 10,116,772 | T-403 | T-301 | 6 | 25/10 | 0 | 25/10 | 0 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 50% speed 45% stroke | 3.0 | N/A | N/A | N/A | FQI reading at 0900 hours. PT-201 backed up in AM trying to pump to drain. FTO down for 1.5 hours. Water from T-201 being directed to T-402 now. Pressure washed ~ 50' of sewer line from sample box exit point. FQI-402 had a broken disc inside, clogging flow to the sample box. SSV sampling today. WW Henry plant is running today. |
| 12/6/07 | 24.0 | 24.0 | 10,169,505 | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 30% speed 30% stroke | 1.0 -2.0 | N/A | N/A | N/A | FQI-402 reading at 0930 hours. 1500 hours changed sheaves on motors for B-101/B-102 (using smaller diameter sheaves). B-101/B-102 operating at ~ 90 A. PID readings in ERH area zones 802, 803 and 805. WW Henry plant is running today. |
| 12/7/07 | 24.0 | 24.0 | 10,228,900 | T-403 | T-301 | 5 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 reading at 0930 hours. Completed tedlar/PID readings in ERH area at zones 801 and 804. Pressure washed cooling tower protective outer mesh. WW Henry plant is running today. |
| 12/8/07 | 24.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 2 | 5/1 | 2 | 5/1 | 2 | 25/10 | 0 | 25/10 | 0 | 6 oz granular chlorine | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | Miguel monitoring plant operations. All systems running well. High pressure at T-404 (plant sewer from sample box to street manhole line needs total cleaning out). Will be done on Monday with pressure washer. WW Henry plant is running today. |
| 12/9/07 | 8.5 | 8.5 | N/A | T-403 | T-301 | 7 | 25/10 | 0 | 25/10 | 0 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 0 | N/A | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | Miguel monitoring plant. FQI-402 failed at 815 hours effectively choking off the discharge line from the plant to the sewer box. This shut down the FTO. Will replace FQI-402 with upgraded internal parts next week. |
| 12/10/07 | 14.0 | 15.0 | 10,358,246 | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 is broken no reading today. Plant was shut down Sunday due to mechanical problems with FQI-402. Removed broken parts from meter and restarted FTO anddGW systems. BEGI TROUBLESHOOTING FTO pH ISSUE - checked on calibrated of pH probe. Normal. Reset chiller RC-201. WW Henry plant is running today. |
| 12/11/07 | 24.0 | 24.0 | 10,409,535 | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 waiting for repair kit. Added 200 gallons 25% NAOH to T-901 today. WW Henry plant is running today. |
| 12/12/07 | 24.0 | 24.0 | 10,474,247 | T-403 | T-301 | 5 | 25/10 | 8 | 25/10 | 2 | 5/1 | 1 | 5/1 | 1 | 25/10 | 2 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | Repaired FQI-402. FQI-402 reading at 1530 hours. SSV sampling today (SSV-04 to SSV-09). Almega sampling in TC today. Condensate sump pump DPE-B not working. Scraped the top of T-403 GAC bed/backflushed with potable water.WW Henry plant is running today. |

Pemaco Superfund Site, Maywood, CA

Rev: 1/02/08

| Date | Vapor System Runtime (hr) | GW System Runtime (hr) | FQI-402 Cumulative (gal) | Liquid Phase GAC Lead Vessel | Vapor Phase GAC Lead Vessel | F-801 Salt Refill (no. of 50lb bags) | Filter Bag Change-Out | | | | | | | | | | | | Chlorination | | | | | | | | O&M Comments |
|----------|---------------------------|------------------------|--------------------------|------------------------------|-----------------------------|--------------------------------------|-----------------------|-----|-------|-----|-------|-----|-------|-----|-------|-----|-------|-----|-------------------------|-----|--------------------------------|---------|--------|-----|-----------|---|--------------|
| | | | | | | | F-401 | | F-402 | | F-403 | | F-404 | | F-501 | | F-502 | | T-101 | | T-401 Dose 402 Conc. | | CT-201 | | T-202 | | |
| | | | | | | | Micro | No. | Micro | No. | Micro | No. | Micro | No. | Micro | No. | Micro | No. | Dose | ppm | Dose | ppm | Dose | ppm | Algaecide | | |
| 12/13/07 | 24.0 | 24.0 | 10,522,664 | T-403 | T-301 | 0 | 25/10 | 2 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 30% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 reading at 1230 hours. Changed setpoints LSL832A to 19" and LSH832A to 20". Calibrated conductivity probe with 5000 micro siemens buffer solution. WW Henry plant is running today. | |
| 12/14/07 | 20.0 | 24.0 | 10,573,913 | T-403 | T-301 | 5 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 1.0 | N/A | N/A | N/A | FQI-402 broke at ~0630 hours shutting down FTO/GW systems. Restarted GW system immediately. FTO back on at ~1100 hours. Increased speed to 35%. Set freeze-stat on RC-201 to 50 degrees F. Scraped the top of T-403 GAC bed/backflushed with potable water. WW Henry plant is running today. | |
| 12/15/07 | 24.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 0 | 25/10 | 0 | 5/1 | 0 | 5/1 | 0 | 25/10 | 0 | 25/10 | 0 | N/A | N/A | Injection 35% speed 30% stroke | 1.0 | N/A | N/A | N/A | Miguel supervised the plant Saturday/changed filter bags. | |
| 12/16/07 | 24.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 0 | 25/10 | 0 | 5/1 | 0 | 5/1 | 0 | 25/10 | 0 | 25/10 | 0 | N/A | N/A | Injection 35% speed 30% stroke | 1.0 | N/A | N/A | N/A | Danny Chen supervised the plant/changed filter bags. | |
| 12/17/07 | 24.0 | 24.0 | 10,705,839 | T-403 | T-301 | 8 | 25/10 | 4 | 25/10 | 2 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 under maintenance. WW Henry plant is running today. Performed pH testing and caustic pump testing. Determined FTO pH screen reading is 1 pH unit less than manual readings. Caustic pump troubleshooting performed. | |
| 12/18/07 | 22.5 | 24.0 | 10,749,613 | T-403 | T-301 | 0 | 25/10 | 2 | 25/10 | 0 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 under maintenance. WW Henry plant is running today. Discovered a hot spot on the FTO bellows. Alzeta onsite and shut the FTO off for inspection. The bellow insulation was temporarily repaired (see Daily Report for details). FTO back online within 2 hours. | |
| 12/19/07 | 23.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 under maintenance. SSV sampling on Walker and 59th Place. Shut FTO down for 1 hour while scraping/removing GAC at T-403. Repaired DD pump. Opened DPE-B and DPE-D today. Pulling from DPE-A, DPE-B, DPE-D and VE-3.WW Henry plant is running today. | |
| 12/20/07 | 24.0 | 24.0 | N/A | T-403 | T-301 | 7 | 25/10 | 0 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 2.0 | N/A | N/A | N/A | FQI-402 under maintenance. JW/EM makes adjustments to calibration of pH probe at FTO to read 8.4. Opened DPE-C today. Pulling from DPE-A, DPE-B, DPE-C, DPE-D and VE-3. WW Henry plant is running today. | |
| 12/21/07 | 24.0 | 24.0 | 10,910,166 | T-403 | T-301 | 3 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 35% stroke | 1.0 | N/A | N/A | N/A | FQI-402 under maintenance. Increased stroke to 35% from 30% for chlorine injection pump. Added 3 tablets chlorine to T-402. Scraped another 3" of GAC at T-403 due to bio-fouling layer. Added 55-gallons glycol to RC-201 water system. Same vacuum extraction headers online as yesterday. WW Henry plant is running today. | |
| 12/22/07 | 24.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 1.0-2.0 | N/A | N/A | N/A | Edwin supervised the plant Saturday/changed filter bags. Same vacuum extraction headers online as yesterday. | |
| 12/23/07 | 17.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 30% stroke | 1.0-2.0 | N/A | N/A | N/A | Edwin supervised the plant Sunday/changed filter bags. FTO was shut down for 7 hours for faulty flow switch at FTO quench line (switch was replaced last month). Pulling from DPE-A, DPE-B, DPE-D and VE-3 after repairs to FTO. | |
| 12/24/07 | 21.8 | 24.0 | N/A | T-403 | T-301 | 6 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 35% stroke | 1.0-2.0 | N/A | N/A | N/A | Miguel supervised the plant Monday/changed filter bags. FTO down for 2.25 hours as pump for T-201 seemed to lose prime. Pulling from DPE-A, DPE-B, DPE-D and VE-3 | |
| 12/25/07 | 24.0 | 24.0 | N/A | T-403 | T-301 | 0 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 0 | 25/10 | 0 | 6 oz. granular chlorine | N/A | Injection 35% speed 35% stroke | 2.0 | N/A | N/A | N/A | Miguel supervised the plant Tuesday/changed filter bags. Pulling from DPE-A, DPE-B, DPE-D and VE-3 | |
| 12/26/07 | 23.0 | 24.0 | 11,189,078 | T-403 | T-301 | 5 | 25/10 | 4 | 25/10 | 1 | 5/1 | 1 | 5/1 | 1 | 25/10 | 1 | 25/10 | 1 | 6 oz. granular chlorine | N/A | Injection 35% speed 35% stroke | 2.0 | N/A | N/A | N/A | JW/MP supervised plant and troubleshooting NAOH pump control/stroke issues affecting pH of system. Pulling from DPE-A, DPE-B, DPE-D and VE-3 | |

T N & Asscociates, Inc.

Page 2 of 3

Rev: 1/02/08

[illegible]

1. N/A = Data Not Available.
2. Shaded rows are weekends.
3. X indicates algaeicide added per manufacturer recommendations.
4. FQI-402 readings in red were collected from sum of FQI-401 and FQI-501 plus estimated water from FTO ~10 gpm.


Table 11.3
Sample Project Schedule
Pemaco Superfund Site, Maywood, CA

| ACTIVITY & Detail | WEEK OF NOV 19 to NOV 25, 2007 | | | | | | | WEEK OF NOV 26 to DEC 02, 2007 | | | | | | | WEEK OF DEC 03 to DEC 09, 2007 | | | | | | |
|---|--------------------------------|------------------------------|--------------------|-----|-------------|-------------|--------------|---|---|---------------------------|---------------|-----|-----|-----|---------------------------------|-----------------------|--------------------|-----|-----|-----|-----|
| | MON | TUE | WED | THU | FRI | SAT | SUN | MON | TUE | WED | THU | FRI | SAT | SUN | MON | TUE | WED | THU | FRI | SAT | SUN |
| | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| O&M Manual Review & Construction Completion Report Returned O&M Manual comments to ERM/J&H to finalize the final O&M Manual. Received a response on Tuesday 11/21, from ERM requesting additional information before they begin revisions. TN&A will provide info by Tuesday Nov. 27. | | | | | | | | | TN&A to provide ERM with additional comment info. | | | | | | | | | | | | |
| Health and Safety Audit TN&A will conduct an in-house H&S audit beginning with AHA's, Site Documentation, and Sampling Safety SOPs. | | | | | | | | | H&S Audit TBD | H&S Audit TBD | H&S Audit TBD | | | | | | | | | | |
| Misc. Construction Items Implement BMP weekly inspection + Post-Rain Event Monitoring. Diaphragm pump repair successful. Will operate on second pump once retrofit kit is procured. Will need 3000 psi pressure washer and reverse head sprayer attachment in order to clear scale from 4 perched zone wells. Pressure washer can also be used to clean T-401/402 and eliminated confined space entry. | FTO Troubleshoot with Angull | FTO Troubleshoot with Angull | | | | | | Procurement tasks for pressure washer and O&M parts | | Retrofit second DD pump. | | | | | | | | | | | |
| Plant Optimization Tasks SCADA flow calibrated and working well. TRS must clean their level controls for the condenser pump. Will return stainless steel strainer basket for FTO, need a different size than what was provided by Hayward. Level controls in secondary containment sump need to be continually checked because of inconsistent operation. | Clean T-402 | SS Strainer Basket Delivery | Clean T-401 | | Dave Onsite | Mark Onsite | Edwin Onsite | | GAC Changeout on T-404 | | | | | | | | | | | | |
| GAC Backwash Remedy Back On Optimization List to avoid confined space entries and reduce H&S risks. May consider future GAC backwash system placement at location of FTO - once removed. Tetrasolve still required to replace Tank innards with SS screen to meet backwash pressures. Received sand filter quote from Tetrasolv on 11/14. | | | | | | | | | | | | | | | | | | | | | |
| ERH Weekly Reports Sent out on Mondays. Summarize in meetings. | 8th Weekly ERH Progress Report | | | | | | | 9th Weekly ERH Progress Report | | | | | | | 10th Weekly ERH Progress Report | | | | | | |
| ERH Monitoring & Optimization Optimizing GW extractions, vapor extraction, and ERH operations. | | | | | | | | | | | | | | | | | | | | | |
| ERH Area Sampling Monthly vapor sampling from VMP wells. Bi-weekly ERH GW sampling. | | | | | | | | | | Bi-weekly ERH GW sampling | | | | | | | | | | | |
| Plant Process & Groundwater Sampling Weekly - influent (SP-201), pre primary carbon (SP-204), post primary carbon (SP-206), effluent (SP-208), post T-101 moisture separator (SP-210), post T-201 (SP-212), and GW manifolds (SP-213 through SP-215); Weekly well field sampling of physical parameters per SAP (SP-203, 204, 205); ROI of VES for SSVs and select extraction wells. Quarterly - SP-209 (Discharge Permit - next Nov. 12&13). Quarterly Site-Wide GW Sampling Dec. 3. | QRTLY Permit Sampling | QRTLY Permit Sampling | Weekly GW Sampling | | | | | | | Weekly GW Sampling | | | | | | | Weekly GW Sampling | | | | |
| Plant Process & Vapor Sampling SSV reduction from 10 locations to 3 locations, to be performed for next 2-3 weeks, prior to next review. Daily - plant influent (SP-102) via Reg. 9 Lab TO-15 regular. Weekly - all major headers (influent & effluent) Reg. 9 lab; SP-104 - post FTO & SP-109 post carbon for TO-15 (Reg 9) and TO-15 SIM (Air Toxics). ROI vapor measurements for ERH well field. | | Weekly Vapor Sampling | | | | | | | Weekly Vapor Sampling | | | | | | | Weekly Vapor Sampling | | | | | |
| FTO Dioxin Test Dioxin sampling on hold until Nov., contingent on total halogenated concs. approx 500 ppmv. | | | | | | | | | | | | | | | | | | | | | |
| C-Zone Sampling & Activities Bi-weekly Sampling | | | | | | | | | Bi-weekly C-Zone sampling | | | | | | | | | | | | |
| WEB Site Optimization Continuing with comments. Performed retroactive flow correction. Calculation need to be QC'd by JW & DC in order to remove this task from the list. | | | | | | | | | | | | | | | | | | | | | |
| Solar Panel Construction & Rebate Application Rebate application is pending until California Solar Engineering gets paid required by rebate requirements. | | | | | | | | | | | | | | | | | | | | | |
| EPA Visits, Filming Activity, and Community Meeting Next Community Meeting is January 31st. | | | | | | | | | | | | | | | | | | | | | |

Notes:
BMP - best management practices; ERH - electrical resistance heating; FTO - flameless thermal oxidizer; GAC - granular activated carbon; GW - groundwater; O&M - operation and maintenance; TBD - to be determined; VMP - vacuum monitoring probe

GRAPHS

Graph 3.1
Vapor Influent VOC Concentrations and VOC Mass Removal Trends
Pemaco Superfund Site, Maywood, CA





Notes:

TCE - trichloroethane

VOCs - volatile organic compounds

ppbv - part per billion by volume


Graph 3.2
Vapor Extraction Volumes and Cumulative VOC Mass Removal
Pemaco Superfund Site, Maywood, CA



Notes:

TCE - trichloroethane
VOCs - volatile organic compounds
scf - standard cubic feet

Graph 4.1
Groundwater Influent VOC Concentrations and VOC Mass Removal Trends
Pemaco Superfund Site, Maywood, CA





Notes:

TCE - trichloroethane

VOCs - volatile organic compounds

$\mu\text{g/L}$ - microgram per liter

Graph 4.2
Groundwater Extraction Volumes and Cumulative VOC Mass Removal
Pemaco Superfund Site, Maywood, CA



Notes:

TCE - trichloroethane

VOCs - volatile organic compounds