

Safety Overview

Floor Fire Operations – Kidney Center of Savannah

1. Area inspected for all slip-trip-fall items and removal of any items will occur prior to entry by fire technicians.
2. Area inspected for hazards which might damage air line or fuel supply line.
3. Area to be “cooked” by fire technician clearly marked.
4. Fire Team will consist of the following:
 - a. Fire Technician
 - b. Fire Watch Technician
 - c. Hose Control Technician
5. In addition to the 3 (Three) person fire team there will be no less than two rescue technicians dressed and ready to make entry to effect a rescue as directed by the Site Safety Officer or OSC.
6. Duration of entry will be determined based upon Heat Category as established in the Health and Safety Plan and confirmed by the Site Safety Officer but will not exceed 45 (Forty-Five) minutes.
7. Dress for this operation will be Modified Level B – NOMEX suit and Cascade System to deliver breathing air. Rescue team members will wear NOMEX suit and SCBA.
8. There will be not less than 5 fire extinguisher (ABC) present including one carried by the Fire Watch Technician.
9. Fuel supply will be a portable propane tank.
10. Local fire department will be notified prior to fire operations.
11. Building fire alarm and fire suppression system will be confirmed “DISABLED” prior to start of fire operations.
12. Proper decontamination protocol will be followed when fire operations ends.
13. Air venting from building, as well as work zone air, will be monitored via LUMEX meter prior to, during, and immediately following fire operations to insure the safety of all support personnel.