

**United States Environmental Protection Agency  
Region VI  
POLLUTION REPORT**

**Date:** Saturday, July 25, 2009

**From:** Mark Hayes

**To:** R6 PolRep TX, Response and Prevention Branch  
Sam Coleman, Superfund Division

Debbie Dietrich, Office of Emergency Management  
Chris Petersen, Superfund Division

**Subject:** Citgo Refinery Fire  
1801 Nueces Bay Blvd, Corpus Christi, TX  
Latitude: 27.8093090  
Longitude: -97.4266880

<b>POLREP No.:</b>	4	<b>Site #:</b>	
<b>Reporting Period:</b>		<b>D.O. #:</b>	
<b>Start Date:</b>	7/19/2009	<b>Response Authority:</b>	CERCLA
<b>Mob Date:</b>	7/20/2009	<b>Response Type:</b>	Emergency
<b>Demob Date:</b>		<b>NPL Status:</b>	
<b>Completion Date:</b>		<b>Incident Category:</b>	
<b>CERCLIS ID #:</b>		<b>Contract #</b>	
<b>RCRIS ID #:</b>			

**Site Description**

On 19 July 2009, at approximately 0835 hours, an equipment failure resulted causing a fire of released Butane and a potential release of Hydrogen Fluoride from a #2 Alkylation Unit at the Citgo Corpus Christi east plant. Perimeter monitoring conducted by TCEQ and Citgo did not detect any VOCs or Hydrogen Fluoride. The fire fighting and water spray suppression appear to have prevented any releases from being detectable at the site perimeter. One injury resulted from the initial fire.

**Current Activities**

On 24 July 2009 EPA perimeter air monitoring for VOCs and HF continues to reflect non-detect of HF. On 23 July 2009 CITGO continues to discharge the seawater used in fire fighting and vapor suppression through Outfall 004, a storm water outfall at approximately 3,000 gpm. CITGO samples the Outfall 004 at 4 hour intervals for the parameters for storm water plus pH and fluoride. TCEQ is grabbing split samples and analyzing for the waste water parameters in CITGO's discharge permit. TCEQ will grab samples twice a day. At the 1900 briefing CITGO identified that Sealtech, the company contracted to seal the HF leaks on the Alkylation Unit, had sealed 3 of the 4 known leaks. CITGO now uses 3,000 gpm of seawater for vapor suppression and may continue until the unit's internal monitoring system in the area of where the fire occurred is restored. CITGO monitoring at the perimeter of the Alkylation Unit has not identified any airborne releases. CITGO is depressurizing the unit through an acid gas removal system and flaring the remaining gas through the flare.

**Planned Removal Actions**

Incident response is being monitored. None planned by EPA at this time.

**Next Steps**

Continue perimeter monitoring until hydrogen fluoride leaks have been secured and coordinate with other state and federal agencies.

**Key Issues**

There has been a non-detect of VOCs and HF from air monitoring around the perimeter of the facility. Unauthorized discharge of water containing elevated levels of fluoride into the nearby ship channel is on-going.

**Estimated Costs \***

	Budgeted	Total To Date	Remaining	% Remaining
<b>Extramural Costs</b>				

<b>Intramural Costs</b>				
<b>Total Site Costs</b>	\$0.00	\$0.00	\$0.00	0.00%

\* The above accounting of expenditures is an estimate based on figures known to the OSC at the time this report was written. The OSC does not necessarily receive specific figures on final payments made to any contractor(s). Other financial data which the OSC must rely upon may not be entirely up-to-date. The cost accounting provided in this report does not necessarily represent an exact monetary figure which the government may include in any claim for cost recovery.

[response.epa.gov/CitgoRefineryFireCorpus](http://response.epa.gov/CitgoRefineryFireCorpus)

POLREP #4 Last Updated 7/25/2009