

U.S. ENVIRONMENTAL PROTECTION AGENCY
POLLUTION/SITUATION REPORT
Compass Plaza Well TCE Site - Removal Polrep
Initial Removal Polrep



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region VII

Subject: POLREP #1
Initial
Compass Plaza Well TCE Site
A7W2
Rogersville, MO
Latitude: 37.1169950 Longitude: -93.0557343

To:
From: Doug Ferguson, OSC
Date: 2/11/2011
Reporting Period: 08/16/2010-02/11/2011

1. Introduction

1.1 Background

Site Number:	A7W2	Contract Number:	
D.O. Number:		Action Memo Date:	7/21/2010
Response Authority:	CERCLA	Response Type:	Time-Critical
Response Lead:	EPA	Incident Category:	Removal Action
NPL Status:	Non NPL	Operable Unit:	
Mobilization Date:	8/16/2010	Start Date:	8/16/2010
Demob Date:		Completion Date:	
CERCLIS ID:	MON000706143	RCRIS ID:	
ERNS No.:		State Notification:	
FPN#:		Reimbursable Account #:	

1.1.1 Site Description

In March 2010, the Missouri Department of Natural Resources (MDNR) Public Drinking Water Branch (PDWB) found trichloroethylene (TCE) in two non-community wells and an irrigation well on the western edge of Rogersville, Missouri. MDNR's Superfund Section initiated a combined Preliminary Assessment/Site Investigation (PA/SI) integrated Removal Site Evaluation (RSE) on March 24, 2010. Initial sampling events found 13 of the 100 wells sampled have detectable concentrations of TCE. Five drinking water wells within that sampling group had TCE concentrations above the maximum contaminant level (MCL) of 5 parts per billion (ppb). The source of the TCE release is unknown at this time. MDNR requested EPA to provide alternate water supply to the households drinking contaminated water. EPA currently plans to continue the well water and source assessment work at the site.

2. Current Activities

2.1 Operations Section

2.1.1 Narrative

The week of August 16, 2010, EPA installed 5 water treatment systems in private residences with TCE concentrations above the MCL. Analytical results of post treatment water samples indicate the systems are effective in removing TCE. Sampling to identify other impacted wells found one additional drinking water well with TCE, but the TCE concentration was below the MCL.

During the week of October 4, 2010 EPA sampled 51 private drinking water wells. There were no detections of TCE in these samples.

During the week of December 13, 2010, EPA in cooperation with MDNR, Greene County Resource Management and the Natural Resource Conservation Service (NRCS) plugged a well with high concentrations of TCE to protect groundwater resources. These same agencies also oversaw EPA's construction of a new drinking water well at the same location. No TCE was detected in the new well. Also during this week, 65 well water samples were collected from previously unsampled wells and wells where TCE was previously detected. All treatment systems are effectively removing TCE from the groundwater. One additional well was found to have TCE below the MCL. This well is located in the same general area as wells previously found to have TCE contamination.

EPA plans to sample additional wells the week of February 21, 2011. Treatment systems will be installed at private residences with TCE concentrations above the MCL.

This site is being considered for the National Priorities List (NPL).

2.1.3 Enforcement Activities, Identity of Potentially Responsible Parties (PRPs)

The source of the contamination has not been determined, but sampling efforts to find the source will continue.

2.1.4 Progress Metrics

<i>Waste Stream</i>	<i>Medium</i>	<i>Quantity</i>	<i>Manifest #</i>	<i>Treatment</i>	<i>Disposal</i>

2.2 Planning Section

2.2.1 Anticipated Activities

EPA will continue to sample wells in the area. To date, about 210 of the 500 wells within a four mile radius of the initial area of detection have been sampled.

2.2.1.1 Planned Response Activities

EPA will continue to install water treatment systems on residential drinking water wells with concentrations of TCE that exceed the MCL.

2.2.1.2 Next Steps

This site is being considered for the National Priorities List (NPL).

2.2.2 Issues

The feasibility of extending municipal water lines to residences with TCE concentrations exceeding the MCL is being studied.

2.3 Logistics Section

No information available at this time.

2.4 Finance Section

No information available at this time.

2.5 Other Command Staff

No information available at this time.

3. Participating Entities

3.1 Unified Command

3.2 Cooperating Agencies

Missouri Department of Natural Resources
Greene County
Agency for Toxic Substances and Disease Registry

4. Personnel On Site

Emergency Response and Removal Services (ERRS) Contractor Response Manager Dave Brinkmeyer
Superfund Technical Assistance and Response Team (START) Contractor Project Manager Tom Scroggins
Greene County Resource Management-Danny Tavares
Plumbing Contractor
Well Plugging Contractor
Well Drilling Contractor

5. Definition of Terms

No information available at this time.

6. Additional sources of information

No information available at this time.

7. Situational Reference Materials

No information available at this time.