

**United States Environmental Protection Agency
Region VIII
POLLUTION REPORT**

Date: Thursday, December 22, 1994
From: Craig Myers

Subject: Progress POLREP
Aspen Park Solvents
Aspen Park, Conifer, CO
Latitude: 39.5414000
Longitude: -105.2936000

POLREP No.:	2	Site #:	08-6D
Reporting Period:		D.O. #:	
Start Date:	10/25/1994	Response Authority:	CERCLA
Mob Date:		Response Type:	Time-Critical
Demob Date:		NPL Status:	Non NPL
Completion Date:		Incident Category:	Removal Action
CERCLIS ID #:		Contract #	
RCRIS ID #:			

Site Description

The Site is a residential sub-division near Conifer, Colorado. The Site consists of residences and buildings/businesses typical of a small mountain community.

In 1994 a sampling of a drinking water well by the Colorado Department of Health (CDH), in accordance with Colorado drinking water regulations for "non-transient non-community" systems, showed the well containing CCl₄ in concentrations (9 parts per billion [ppb]) above the Maximum Contaminant Level (MCL) [5 ppb]. Four other drinking water wells within a 1/2 mile radius also were tested with no detections of CCl₄.

Current Activities

On 10/25/94, EPA 8 initiated the Removal and began supplying bottled water to 25 residences. During November, EPA 8 conducted two community/public meetings so as to provide updates to the local residents.

A Treatability Study, to determine the best method of removing the CCl₄ from the water system was conducted by the EPA-ERT.

Surface geophysics were conducted by the EPA-ERT, and EPA-TAT arranged for aerial photographs/surveys of the area.

Planned Removal Actions

Determine the number of homes requiring remediation (when compared to the threshold/triggering criteria), and install the required treatment systems.

Next Steps

Continue with Site investigations, using downhole geophysics.

response.epa.gov/AspenParkSolvents