

United States Environmental Protection Agency
Region IX
POLLUTION REPORT

Date: Tuesday, January 8, 2008

From: Robert Wise

To:

ERT Support,	Steve Calanog, EPA
Paul Casa Grande, EPA	Eugene Rainwater, EPA
Barbara Lee, EPA	Ivania Brown, EPA
Peggy De La Torre, EPA	Pat Port, DOI
Sherry Fielding, EPA	Carole Kirby, Cinninatti Finance, USEPA
Harvey Packard, RWQCB	Harry Allan, ERS
Hedy Salter, USEPA R9	Craig Benson, ERS
Daniel Meer, US EPA R9	Peter Guria, ERS
Lt. Brian Gollhopher, CADFG	Mark Samolis, USEPA
Mary Simms, EPA	Steven John, EPA
Jason Musante, ERS	Kenneth Wilson, DFG
Melissa Boggs-Blalack, DFG	Jim Hanson, EPA
Joshua Curtis, CADFG-OSPR	Donn Zuroski, ERS
John Holland, DFG	Damian Higgins, USFWS
Rich Martyn, EPA	Will Duncan, ERS
Janet Yocum, ERS	Michelle Rogow, ERS
Martin Powell, ERS	Tom Dunkelman, ERS
Peter Reich, EPA	Greg Haas, Congressional Staffer
Josh Neipp, SBCOFD	Richard Todd, SBCoFD
Kate Sulka, SBCFD	Michael Massey, EPA ORC
Mike Connell, CADFG OSPR	Steve Nailor, SBCOFD
Todd Stanley, CCRWQCB	Terry Snyder, APCD
Pam McNulty, SBCO Petroleum Office	Mike Zimmer, SBCO Petroleum Office
Denise Steurer, USFWS	Ian Zelo, NOAA
Steffanie Wood, EPA	

Subject: Continuing Site Cleanup
Greka Energy Zaca Lease Davis Tank Battery 2008 Spill
5017 Zaca Station Road, Los Olivos, CA
Latitude: 34.7265878
Longitude: -120.1471478

POLREP No.:	2	Site #:	
Reporting Period:	01/08/2008	D.O. #:	
Start Date:	1/5/2008	Response Authority:	OPA
Mob Date:	1/6/2008	Response Type:	Emergency
Demob Date:		NPL Status:	Non NPL
Completion Date:		Incident Category:	Removal Action
CERCLIS ID #:		Contract #	
RCRIS ID #:		Reimbursable Account #	
FPN#	E08903		

Site Description

On January 5, 2007, an oil spill occurred in the Davis Tank Battery on the Greka Energy Zaca Lease. The spill report stated that 20 barrels of crude oil and 50 barrels of produce water were spilled. The spill was the result of the over filling of a produce waste water tank. The tank overflowed for approximately 13 hours before being discovered. The oil and produce water spilled into the secondary containment of the Davis Tank Battery. The containment of the tank battery was compromised by an unvalved 12" diameter drainage conduit that allowed the spilled material to exit the secondary containment. The oil and produce water exited the secondary containment and migrated through a Santa Barbara Co. Roads Yard, through a winery equipment storage yard and finally into an unnamed tributary to Zaca Creek. The oil initially traveled approximately 1/2 mile down the creek.

The Santa Barbara Co. Fire Department and the California Department of Fish and Game (DFG) responded to the spill. The DFG directed Greka to retain a contractor to cleanup the creek. Greka retained Advanced Cleanup Technologies (ACTI). Due to rainy conditions, Greka built to dams to prevent the oil from migrating further down the creek. On Saturday night, due to flash flood conditions in the creek bed, the dams were compromised and the oil flowed approximately another 3/4 mile downstream.

Current Activities

Greka staff continued to decontaminate the tank farm using a steam cleaner and manual labor. Greka and ACTI staff removed the oil and waste water temporary containment area set up on the effluent end of the drainage conduit that drained the tank farm secondary containment. Waste oil and sediment was placed in the roll-off bins for off-site disposal to Chemical Waste Management, Kettleman Hills, CA. No bins will leave the site until oil quantification by DFG.

Greka worked on the decontamination of the impacted winery equipment.

Greka welded a steel cap on the influent end of the drainage conduit to prevent any future migration of oil out of the secondary containment.

ACTI continued to remove oil from the creek. The oil is removed by manual laborers digging it up and placing it in plastic bags. The bags were then placed on plastic sheets outside of the creek or in the roll-off-bins.

After examining Greka's capabilities to conduct the permit required confined space entry underneath the County Road Maintenance building to remove oil that migrated during the spill, Greka was directed to have their contractor clean under the building. Greka did not meet the requirements pursuant to 29 CFR 1910.146.

The news media from the local newspaper and UNIVISION, the Spanish language station was on-site. The press was managed by DFG.

EPA's Oil Program Inspector was on-site to begin SPCC inspections of the tank batteries.

Planned Removal Actions

1. Remove all oil contamination from the creek, tank farm and adjacent areas.
2. Restore the creek to its natural condition.
3. Fill the conduit with concrete to permanently close it.

Next Steps

1. Complete the gross contamination removal from the creek.
2. Complete decontamination of the tank farm and adjacent areas.

Key Issues

OSC Wise issued a NOFI to Greka.

Estimated Costs *

	Budgeted	Total To Date	Remaining	% Remaining
Extramural Costs				
Intramural Costs				
Total Site Costs	\$0.00	\$0.00	\$0.00	0.00%

* The above accounting of expenditures is an estimate based on figures known to the OSC at the time this report was written. The OSC does not necessarily receive specific figures on final payments made to any contractor(s). Other financial data which the OSC must rely upon may not be entirely up-to-date. The cost accounting provided in this report does not necessarily represent an exact monetary figure which the government may include in any claim for cost recovery.

